

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

November 12, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 644
NO/JHL:acm
Docket No. 50-338
License No. NPF-4

Gentlemen:

AMENDMENT TO OPERATING LICENSE NPF-4
NORTH ANNA POWER STATION UNIT NO. 1
PROPOSED TECHNICAL SPECIFICATIONS CHANGE

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment in the form of changes to the Technical Specifications, to Operating License NPF-4 for North Anna Power Station, Unit No. 1. The proposed Technical Specification changes are enclosed.

The proposed changes are to delete Technical Specifications 3.4.10.1.d and 4.4.10.1 which require the ultrasonic examination of flow straighteners whenever a reactor coolant pump shaft deflection of greater than 20 mils is indicated and at least per 18 months. The proposed change would also delete Technical Specification 3.3.3.9 which requires a Loose Parts Monitoring System to promptly detect any loose parts. The proposed Technical Specification change is enclosed in Attachment 1. A discussion of the proposed change is enclosed in Attachment 2.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff. It has been determined that this request does not involve an unreviewed safety question as defined in 10 CFR 50.59.

We have evaluated this request in accordance with the criteria in 10 CFR 170.22. Since this request involves a safety issue which the staff should be able to determine does not pose a significant hazard consideration for Unit 1, a Class III license amendment fee is required for Unit 1. Accordingly, a voucher check in the amount of \$4,000 is enclosed in payment of the required fees.

Very truly yours,

W. L. Stewart
W. L. Stewart

A001
w/check:
\$ 4000.00

VIRGINIA ELECTRIC AND POWER COMPANY TO Harold R. Denton

Attachments

1. Proposed Technical Specification Changes
2. Discussion of Proposed Technical Specification Changes
3. Voucher Check No. 84653 for \$4,000

cc: Mr. James P. O'Reilly
Regional Administrator
Region II