

NOV 01 1982

Docket/License: 50-412/CPFR-106

Duquesne Light Company
ATTN: Mr. E. J. Woolever
Vice President
Nuclear Construction
Beaver Valley Two Project
Duquesne Light Company
Robinson Plaza Building No. 2
Suite #210, PA Route 60
Pittsburgh, PA 15205

Gentlemen:

Subject: Inspection No. 50-412/82-11

This refers to the routine resident safety inspection conducted by Mr. G. Walton of this office on September 1 - October 1, 1982, at the Beaver Valley Power Station, Unit 2, Shippingport, Pennsylvania, of activities authorized by NRC License No. CPFR-105 and to the discussions of our findings held by Mr. Walton with Mr. E. Ewing of your staff.

Areas examined during this inspection are described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examination of procedures and representative records, interviews with personnel, and observations by the inspector.

Based on the results of this inspection, it appears that one of your activities was not conducted in full compliance with NRC requirements, as set forth in the Notice of Violation, enclosed herewith as Appendix A. This violation has been categorized by severity level in accordance with NRC Enforcement Policy (10 CFR 2 Appendix C) published in the Federal Register Notice (47 FR 9987) dated March 9, 1982. You are required to respond to this letter and in preparing your response, you should follow the instructions in Appendix A.

Your attention is directed toward Details, Paragraph 4 of the enclosed inspection report which discusses our review of support attachments for HVAC systems. Due to the nature and number of inconsistencies among procedures, drawings, specifications, supporting calculations (including assumptions used in calculational techniques), and installation practices identified (and listed in Details, Paragraph 4.7), we are concerned about the adequacy of your management control system and Quality Assurance Program. Therefore, your response to this letter should also address these matters.

The responses requested by this letter are exempt from the Office of Management and Budget's clearance procedures under the Paperwork Reduction Act of 1980, PL 96-511.

8211190233 821101
PDR ADOCK 05000412
Q PDR

IEOI

OFFICIAL RECORD COPY

NOV 01 1982

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1). The telephone notification of your intent to request withholding or any request for an extension of the 10 day period which you believe necessary, should be made to the Supervisor, Files, Mail and Records, USNRC Region I, at (215) 337-5233.

Your cooperation is appreciated.

Sincerely,

Original Signed By:

Richard W. Starostecki, Director
Division of Project and Resident
Programs

Enclosures:


- 1. Appendix A, Notice of Violation
- 2. NRC Region I Inspection Report No. 50-412/82-11


cc w/encl:

- E. Ewing, Quality Assurance Manager
- R. J. Washabaugh, Project Manager
- E. J. Kurtz, Jr., Manager, Regulatory Affairs
- H. M. Siegel, Manager, Engineering
- Public Document Room (PDR)
- Local Public Document Room (LPDR)
- Nuclear Safety Information Center (NSIC)
- Commonwealth of Pennsylvania

bcc w/encl:

- Region I Docket Room (with concurrences)
- Chief, Operational Support Branch (w/o encls)


 RI:DPRP
 Walton/lp
 10/27/82


 RI:DPRP
 Tripp
 10/28/82


 RI:DPRP
 Keimig
 10-28-82


 RI:DPRP
 Starostecki
 10/29/82