

DISTRIBUTION

Docket File (50-413/414)  
NRC PDR  
L PDR  
PRC Sys  
NSIC  
LB#4 Reading  
EAdensam  
MDuncan  
KJabbour  
DEisenhut/RPurple  
Attorney, OELD  
ELJordan, DEQA:IE  
JMTaylor, DRP:IE  
ACRS (16)

NOV 16 1982

Docket Nos.: 50-413/414

Mr. H. B. Tucker, Vice President  
Nuclear Production Department  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Request for Additional Information - Catawba Nuclear Station

In the performance of the Catawba Station licensing review, the NRC staff has identified the need for additional information in the Power Systems area (Enclosure). We request that you provide the information herein requested no later than December 17, 1982. If you require any clarification of this matter, please contact the project manager, Kahtan Jabbour, at (301) 492-7821.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

Elinor G. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing

Enclosure:  
As stated

cc: See next page

8211220033 821116  
PDR ADOCK 05000413  
A PDR

OFFICE	DL:LB#4	DL:LB#4	DL:LE#4				
SURNAME	KJabbour	MDuncan	EAdensam				
DATE	11/15/82	11/15/82	11/15/82				

CATAWBA

Mr. H. B. Tucker, Vice President  
Nuclear Production Dept.  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242

cc: William L. Porter, Esq.  
Duke Power Company  
P.O. Box 33189  
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.  
Debevoise & Liberman  
1200 Seventeenth Street, N.W.  
Washington, D. C. 20036

North Carolina MPA-1  
P.O. Box 95162  
Raleigh, North Carolina 27625

Mr. F. J. Twogood  
Power Systems Division  
Westinghouse Electric Corp.  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230

Mr. J. C. Plunkett, Jr.  
NUS Corporation  
2536 Countryside Boulevard  
Clearwater, Florida 33515

Mr. Jesse L. Riley, President  
Carolina Environmental Study Group  
854 Henley Place  
Charlotte, North Carolina 28208

Richard P. Wilson, Esq.  
Assistant Attorney General  
S.C. Attorney General's Office  
P.O. Box 11549  
Columbia, South Carolina 29211

Mr. Henry Presler, Chairman  
Charlotte - Mecklenburg Environmental  
Coalition  
943 Henly Place  
Charlotte, North Carolina 28207

North Carolina Electric Membership  
Corp.  
3333 North Boulevard  
P.O. Box 27306  
Raleigh, North Carolina 27611

Saluda River Electric Cooperative,  
Inc.  
207 Sherwood Drive  
Laurens, South Carolina 29360

Mr. Peter K. VanDoorn  
Route 2, Box 179N  
York, South Carolina 29745

James P. O'Reilly, Regional Administrator  
U.S. Nuclear Regulatory Commission,  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Robert Guild, Esq.  
314 Pall Mall  
Columbia, South Carolina 29201

Palmetto Alliance  
2135 1/2 Devine Street  
Columbia, South Carolina 29205

ELECTRICAL SECTION  
POWER SYSTEMS BRANCH

- 430.107 In FSAR revision 5 the interlocks shown in Figure 8.3.2-3 associated with the vital dc system spare battery charger circuit breakers have been changed. The new interlocking scheme does not preclude powering the spare charger from an AC division which is redundant to that of the DC division which the charger feeds. Since this could result in a challenge to the independence between redundant divisions, you should describe the basis for the interlocks chosen and describe how the cross connection between divisions will be prevented.
- 430.108 Provide the location of underground cabling at Catawba. Describe the proximity of underground Class 1E cables to piping, roads or non-Class 1E cables and describe the qualification and design criteria used for the underground system.
- 430.109 The load sequencing system at Catawba has an "accelerated sequence" feature which shortens the time intervals between load sequencing steps if system voltage and frequency setpoints are satisfied. Describe this feature in the Catawba FSAR and provide an analysis showing that the loads will be satisfactorily sequenced with no degradation to either the loads or the diesel generator.