

September 5, 1979

MEMORANDUM FOR: S. Eilperin, OGC  
FROM: J. T. Collins, Deputy Director, TMI-Support  
THRU: R. H. Vollmer, Director, TMI-Support  
SUBJECT: DRAFT RESPONSE TO INTERROGATORIES FROM THE CITY OF  
LANCASTER

In response to your request we have prepared and enclosed draft responses to interrogatories from the City of Lancaster dated May 24, 1979.

J. T. Collins, Deputy Director  
TMI-Support

cc: R. Vollmer  
R. Weller  
TMI R/F

DISTRIBUTION:  
Central File  
NRR RDg. File  
TMI/SEP r/f  
TMI Site r/f  
PSB/TMI R/F

8211220070 790905  
PDR ADOCK 05000320  
G PDR

TMI-Support

JTCollins:jb

9/ /79

RESPONSE TO INTERROGATORIES FROM THE CITY OF LANCASTER

INTERROGATORY NO. 1

1. Has defendant permitted or approved the discharge of any water from Reactor No. 2 at the Three Mile Island ("TMI") nuclear generating plant referred to in plaintiffs' Complaint and Application herein since May 20, 1979?

RESPONSE:

Since May 20, 1979, the NRC ~~onsite support~~ staff has approved the processing through EPICOR-1 and subsequent discharge of some low-level\* radioactive liquid waste originating in Three Mile Island (TMI) Unit 2.

INTERROGATORY NO. 2

2. If the answer to Interrogatory No. 1 is affirmative,
- (a) State how much water (in gallons) was discharged and the origin within Reactor No. 2 of such water;
  - (b) State whether any analysis was performed with respect to that water prior to its discharge, and if so, state in detail:
    - (i) the exact analysis performed, the person(s) who performed the analysis, the employer(s) of such person(s), and the amount (in gallons) of water analyzed; and
    - (ii) the complete findings resulting from the analysis, including the designation of all radioactive isotopes, and the extent of their radioactivities, which were found in the water; and

---

\*Low-level radioactive liquid waste is waste in which, prior to processing, the highest concentration of any radionuclide is less than 1 uCi/ml.



(c) State the basis for defendant having given its permission or approval for the discharge of that water.

RESPONSE:

(a) As shown in enclosure 1, approximately 13,900 gallons of low-level radioactive waste from the Unit 2 contaminated drain tanks were discharged after processing through EPICOR-1. The waste water which collects in the contaminated drain tanks is from the secondary side of the plant.

(b) As indicated in enclosure 1, all water processed through EPICOR-1 for subsequent discharge was sampled and analyzed prior to transfer to EPICOR-1, during processing, and prior to discharge from the plant. The water was analyzed for radionuclide distribution and concentration, pH, conductivity, gross beta activity, and boron, as indicated, in Enclosure 2. The person/group performing the analysis and the amount of water analyzed is also listed in Enclosure 2. All analyses were performed by Metropolitan Edison or contractor personnel. The sample results, including the radionuclide distribution and concentration, are contained in Enclosure 2. The analyses and description of each release to the Susquehanna River are described in Enclosure 3.

(c) The NRC ~~onsite support~~ staff has approved the processing through EPICOR-1 and subsequent discharge of water originating in TMI Unit 2 which is exempted from the Commission's order of May 25, 1979, namely, low level radioactive liquid waste as defined in the response to Interrogatory No. 1.

INTERROGATORY NO. 3

3. Does defendant know of any discharge of water from Reactor No. 2 at TMI since May 20, 1979?

RESPONSE:

See response to Interrogatory No. 1.

INTERROGATORY NO. 4

4. If the answer to Interrogatory No. 3 is in the affirmative,
- (a) State the amount of water discharged,
  - (b) State whether defendant was requested to take any action concerning such discharge, and
  - (c) If defendant received such a request, state what action defendant took, if any.

RESPONSE:

- (a) See response to Interrogatory No. 2'
- (b) The NRC was not requested to take any actions concerning the discharge of waste made in accordance with the existing Technical Specifications and Federal regulations.

INTERROGATORY NO. 5

5. State whether there has been any construction or installation of water decontamination facilities, or any facilities related thereto, at TMI since May 20, 1979.

RESPONSE:

In relation to the operation of EPICOR-II, the licensee has begun construction of an engineered <sup>solid waste ~~stac~~ staging</sup> facility for the temporary storage of spent resin liners <sup>prior to shipment off site to a licensed burial ground.</sup>

INTERROGATORY NO. 6

6. If the answer to Interrogatory No. 5 is in the affirmative,
- (a) Describe in detail the construction or installation activities involved.
  - (b) State whether defendant has given approval for such construction or installation activities, and
  - (c) If defendant has given such approval, state whether defendant has granted an amendment to the Metropolitan Edison Company's operating licensing and/or construction permit.

RESPONSE:

Construction activities to date on the engineered solid waste <sup>staging</sup> storage facility included required excavation of soil, placement of the facility drain pipe and reinforcing steel for the slab, and the pouring of approximately 600 cubic yards of concrete for the facility base slab.

The NRC ~~onsite support~~ staff has provided design criteria for the facility and approval for its construction.

Concerning the construction of the engineered solid waste <sup>staging</sup> storage facility, the licensee did not provide an amendment to their operating license since a discussion of a facility for the storage of solid waste is already presented

in the Final Safety Analysis Report (Chapter 11)<sup>1</sup> on the operation of TMI Unit 2. The staff's safety evaluation of the facility provided for solid waste storage is contained in the Safety Evaluation Report<sup>2</sup> (Section 11.4) related to the operation of TMI Unit 2. The original storage facility and the facility under construction are designed to the same criteria and, thus, the construction of the new facility does not represent an unreviewed safety matter.

---

1  
Final Safety Analysis Report, Three Mile Island Nuclear Station, Unit 2, April 4, 1974.

2  
Safety Evaluation Report Related to Operation of Three Mile Island Nuclear Station, Unit 2, NUREG-0107, U. S. Nuclear Regulatory Commission, September 1976.

INTERROGATORY NO. 7

7. Has defendant permitted or approved, or does defendant intend to permit or approve, the discharge of any water from Reactor No. 2 at TMI prior to the disposition of plaintiffs' Application for a Preliminary Injunction filed herein on May 21, 1979?

RESPONSE:

With respect to water discharged from TMI Unit 2, see response to Interrogatory No. 1 and Interrogatory No. 2.

Concerning future discharges of TMI Unit 2 water, the processing and subsequent discharge of intermediate and high-level waste water is prohibited pending publication and resolution of <sup>the</sup> Environmental Assessment~~s~~ of the proposed action~~s~~, in accordance with the Commission's Order of May 25, 1979. The processing through EPICCR-I for subsequent discharge of low-level radioactive waste water which is exempted from the Commission's Order of May 25, 1979, will be approved, as necessary, to maintain needed surge capacity in Unit 2 auxiliary building tanks */so long as the ~~can~~ total activity does not exceed 1 uCi/ml.*

INTERROGATORY NO. 8

8. If the answer to Interrogatory No. 7 is in the affirmative,
- (a) State the amount of water (in gallons) which defendant has approved and/or intends to approve for discharge,
  - (b) State whether any analysis has been performed of the water to be discharged prior to permitting or approving such a discharge, and if so, state in detail:

(1) The exact analysis performed, the person(s) who performed the analysis, the employer(s) of such person(s), and the amount (in gallons) of water analyzed;

(2) The complete findings resulting from the analysis, including the designation of all radioactive isotopes, and the extent of their radioactivities, which were found in the water to be discharged; and

(c) State the basis for defendant having given or intending to give its permission or approval for the said discharge.

RESPONSE:

(a) As stated in the response to Interrogatory No. 2, the NRC has approved the discharge of 13,900 gallons of processed Unit 2 water.

Concerning approval of future processing through EPICOR-I and subsequent discharge of low-level radioactive waste from Unit 2, the NRC will continue to approve those wastes exempted from the Commission's Order of May 25, 1979, namely, those wastes defined as low-level radioactive liquid waste (see response to Interrogatory No. 1).

(b) See response to Interrogatory No. 2.

(c) The basis for NRC approval for previous and future discharges of Unit 2 water is the guidance provided in the Commission's Order of May 25, 1979, permitting the processing through EPICOR-I and subsequent discharge of water other than intermediate and high-level radioactive liquid waste (i.e., water defined as low-level radioactive liquid waste).

INTERROGATORY NO. 9

9. State whether defendant expects that there will be any construction or installation of water decontamination facilities, or any facilities related thereto, from and after the date of these Interrogatories and prior to the disposition of plaintiffs' Application for a Preliminary Injunction filed herein on May 21, 1979.

RESPONSE:

The NRC staff expects that construction of the engineered solid waste ~~storage~~<sup>staging</sup> facility will be completed prior to the disposition of plaintiffs' Application for a Preliminary Injunction filed on May 21, 1979.

INTERROGATORY 10

10. If the answer to Interrogatory No. 9 is in the affirmative, describe in detail the further construction or installation of water decontamination facilities contemplated; state whether defendant has given approval to the further contemplated construction or installation; and if such approval has been given, state whether defendant has granted to Metropolitan Edison Company an amendment to its operating license and/or construction permit.

RESPONSE:

Additional construction of the engineered solid waste ~~storage~~<sup>staging</sup> facility will include the setting of the corrugated steel cells, placement of additional reinforcing steel, addition of a sump for the facility drainage system, pouring



of concrete for the walls and spaces between storage cells, and application of a decontaminable coating to facility surfaces which may come in contact with contaminated water.

The NRC staff has given approval for the construction of the <sup>solid waste storage</sup> ~~storage~~ facility and has not required a license amendment for the facility for the reasons stated in the response to Interrogatory No. 6.

## ENCLOSURE 1

TMI UNIT 2 WATER PROCESSED  
BY EPICOR I AND RELEASED

<u>TMI Unit 2 Source</u>	<u>Date of Transfer Unit 2 to 1</u>	<u>Gallons Transferred</u>	<u>Samples Taken Prior to Transfer, During Processing, and Prior to Release</u>		<u>TMI Unit 1 WECST Released From</u>	<u>Release Permit Number</u>	<u>Date of Release</u>
Cont. Drain Tank (11B)	5/21/79	1,600	5881 6425	6452 6533	WECST 11B	79-79-L	5/24/79
Cont. Drain Tank (11A)	5/31/79	1,600	7687 7799 8195 8196	8218 8219 8258	WECST 11A	85-79-L	6/09/79
Cont. Drain Tank (11B)	6/06/79	2,000	8948 9421 9438	9439 9463 9503	WECST 11A and WECST 11B	85-79-L* and 86-79-L*	6/09/79  6/10/79
Cont. Drain Tank (11A) and	7/16/79 and	2,100 and	13687 13688	14247 14312	WECST 11A and	112-79-L* and	7/26/79 and
Cont. Drain Tank (11B)	7/17/79	2,000	13940 13962 13988 14010 14102 14194 14195 14211 14222 14223 14237 15519 15520 15774	14354 14360 14378 14388 14412 14499 14501 14424 14465 14499 14501 15431 15432 15775	WECST 11B	113-79-I.* and 116-79-L*	8/06/79 and 8/12/79

## ENCLOSURE 1 (cont.)

<u>TMI Unit 2 Source</u>	<u>Date of Transfer Unit 2 to 1</u>	<u>Gallons Transferred</u>	<u>Samples Taken Prior to Transfer, During Processing, and Prior to Release</u>		<u>TMI Unit 1 WECST Released From</u>	<u>Release Permit Number</u>	<u>Date of Release</u>
Cont. Drain Tank (11A)	8/02/79	2,000	14662 15519 15520 15521	15522 15543 15544 15773	WECST 11B	116-79-L	8/12/79
Cont. Drain Tank (11B)	8/07/79	2,400	15401 15986 16003	16004 16005 16477	WECST 11A	11-79-L	8/14/79

\* Mixing of water within tanks prevents identifying specifically during which release transferred water was sent to the river.

## ENCLOSURE 3

TMI Unit 1 Waste Evaporate Condensate Storage Tanks (WECST A &amp; B)

## Liquid Releases

Applicable to TMI Unit II Water

Processed by Epicor I

<u>Release Number</u>	<u>Source of Unit 2 Water in Release</u>	<u>Unit 2 Water Released (Gallons)</u>	<u>Total* Gallons Released</u>	<u>Date Release Started</u>	<u>Date Release Stopped</u>
79-79-L	Cont. Drain Tank (11B)	1,600	6,638	5/24/79	5/25/79
85-79-L	Cont. Drain Tank (11A)	1,600	6,638	6/09/79	6/10/79
	Cont. Drain Tank (11B)	2,000	5,798	6/10/79	6/11/79
86-79-L	Cont. Drain Tank (11B)	2,000	5,798	6/10/79	6/11/79
112-79-L	Cont. Drain Tank (11A)	2,100	3,993	7/26/79	7/26/79
113-79-L	Cont. Drain Tank (11B)	2,000	6,228	8/06/79	8/07/79
116-79-L	Cont. Drain Tank (11B)	2,200	6,403	8/12/79	8/13/79
117-79-L	Cont. Drain Tank (11B)	2,400	4,370	8/14/79	8/15/79

\* The difference between total gallons released and Unit 2 water released is water released from processing Unit 1 water and added to the WECST to accomplish a batch release.

ENCLOSURE II

Sample Results of Tanks  
and Related Locations  
Associated with Processing  
and Releasing TMI Unit II  
Water Processed by Epicor I

Note: The sample results are in numerical  
order. Refer to Enclosure I to deter-  
mine which water transfer and release  
the sample relates to.

Copy to S.F. U-2

0800 5/19

SAMPLE TIME  
5/19/79

COUNT TIME  
503 5/19/79

-----PRELIMINARY PEAK DATA-----

COUNT TIME = 33.3333 MINUTES      DECAY TIME = 223 MINUTES  
 SAMPLE VOLUME = 1000 MILLILITERS

CENTROID CHANNEL	PEAK ENERGY (KEV)	FWHM (KEV)	PEAK AREA (COUNTS)	+ OR - (1 SIG)
158.73	79.6581	2.2849	3531.0	129.7
352.86	176.6369	1.8606	653.4	116.9
563.07	284.1422	1.6446	6344.4	120.5
680.42	340.2692	1.3196	584.0	78.0
728.58	364.3238	1.3607	69130.2	275.4
1005.60	502.7095	1.9513	225.9	46.0
1126.55	563.1295	2.4548	409.2	43.1
1138.73	569.2140	1.5741	814.4	46.8
1209.62	604.6268	1.5744	4678.8	78.7
1274.27	636.9224	2.0047	3563.6	68.6
1323.62	661.5750	1.5956	16904.8	133.8
1446.23	722.8243	2.0286	823.4	34.6
1592.27	795.7780	2.1122	3215.9	60.0
1604.61	801.9424	1.3186	278.0	23.6
1822.50	810.8793	2.0629	189.4	19.2
1822.52	810.4324	1.6342	634.5	28.9
2010.10	1047.9637	2.1276	455.0	23.3
2471.68	1235.0836	2.4511	79.2	11.3
2923.00	1460.5386	1.7870	50.5	8.2

\*\*\*\*\*  
 \* PRELIMINARY PEAK IDENTIFICATION \*  
 \*\*\*\*\*

EFFICIENCY TABLE USED = 46

NUCLIDE	OBSERVED ENERGY	LIBRARY ENERGY	GAMMAS PER MIN.	UCI PER ML.
K-40	1460.53	1460.00	1155.19	4.730E-06
CO-58	810.88	810.60	2722.06	1.239E-06
GA-72	810.88*	810.20	3307.18	7.094E-05
SB-122	563.13	564.07	4478.43	3.202E-06
SB-124	722.82	722.76	10763.35	4.574E-05
I-131	284.14	284.31	36624.52	3.055E-04
I-131	364.32	364.49	495694.92	2.723E-04
I-131	636.92	637.01	42316.61	2.803E-04
I-131	722.82*	722.92	10897.70	3.068E-04



CS-134	795.78	795.84	45446.79	2.326E-05
CS-134	801.94	801.80	3953.58	1.979E-05
CS-136	176.64	176.00	2614.10	8.722E-06
CS-136	340.27	340.60	3905.00	3.953E-06
CS-136	818.43	818.50	9255.27	4.169E-06
CS-136	1047.96	1048.10	8081.04	4.522E-06
CS-136	1235.08	1235.40	1599.16	3.657E-06
CS-137	661.58	661.64	204871.70	1.073E-04
PA-233	340.27*	340.50	3887.08	4.490E-05
BR-84	810.88*	810.00	504060.53	2.523E-03

\* PEAK HAS BEEN PREVIOUSLY MATCHED

UNIDENTIFIED PEAKS

ENERGY	GAMMAS/MIN. AT COUNT TIME
79.66	++
502.71	2143.32

++ PEAK IS OUTSIDE CALIBRATED REGION

\*\*\*\*\*  
\* FINAL SUMMARY OF NUCLIDES OBSERVED \*  
\*\*\*\*\*

DATE: 5/ 19/ 79

NUCLIDE	WEIGHTED MEAN ACTIVITY	+ OR - 1 SIGMA
K-40	4.730E-06	9.610E-07
CO-58	-1.239E-06	1.961E-07
I-131	2.753E-04	3.948E-05
CS-134	2.379E-05	2.936E-06
CS-136	4.441E-06	6.842E-07
CS-137	1.073E-04	1.308E-05

\*\*\*\*\*  
\* MINIMUM DETECTABLE ACTIVITIES \*  
\* BASIS: 99% C.L. AT COUNT TIME \*  
\*\*\*\*\*

NUCLIDE	ENERGY (KEV)	ABS. EFF.	BR(%)	MDA (UCI/ML)
51	3.201E+02	4.787E-03	9.800E+00	3.854E-06
54	8.348E+02	2.042E-03	1.000E+02	1.552E-07
CO-57	1.221E+02	8.825E-03	8.700E+01	3.591E-07
FE-59	1.099E+03	1.642E-03	5.640E+01	1.531E-07
CO-60	1.173E+03	1.560E-03	1.000E+02	1.602E-07
ZR-95	7.567E+02	2.213E-03	5.460E+01	2.600E-07



6425 HALIFURTON #2 INFLUENT

#6425  
5/23  
0245

SAMPLE TIME  
400 5/ 23/ 79

COUNT TIME  
209 5/ 23/ 79

-----PRELIMINARY PEAK DATA-----

COUNT TIME = 16.6666 MINUTES  
MINUTES  
SAMPLE VOLUME = 250 MILLILITERS

DECAY TIME = 1329

CENTROID CHANNEL	PEAK ENERGY (KEV)	FWHM (KEV)	PEAK AREA (COUNTS)	+ OR - (1 SIG)
324.48	162.4583	1.1651	290.9	39.9
656.97	320.5538	1.6406	963.8	42.8
728.45	364.2598	1.3930	634.3	36.2
865.16	432.5508	2.5446	80.0	23.9
973.95	486.9003	1.6793	1504.4	46.0
994.11	496.9712	1.7531	489.8	30.5
1021.91	510.0571	2.6421	242.6	27.2
1074.53	537.1432	2.1994	365.8	27.9
1209.55	604.5918	1.5879	268.5	27.4
1323.70	661.6150	1.5716	395.5	33.9
1503.92	751.6431	1.5741	123.5	17.1
1531.32	765.3367	1.8710	127.5	18.0
1593.29	795.7880	2.1302	179.0	17.6
1621.78	810.5196	1.9132	300.6	25.4
1632.42	815.8348	1.7948	143.2	24.3
1736.38	867.7675	1.2800	106.7	15.5
1770.17	884.6472	1.7035	66.0	13.9
1851.25	925.1504	2.0020	139.5	16.6
3194.31	1596.0704	2.2655	1107.0	33.9

\*\*\*\*\*  
\* PRELIMINARY PEAK IDENTIFICATION \*

EFFICIENCY TABLE USED = 45

NUCLIDE	OBSERVED ENERGY	LIBRARY ENERGY	CANALS PER MIN.	UCI PEP ML.
Co-58	810.52	810.60	4352.28	7.921E-06
Ga-72	810.52*	810.20	12898.99	1.107E-03
Ga-72	1596.07	1596.80	77013.35	3.182E-03
Hb-95	765.33	765.79	1605.01	2.921E-06
Ru-103	496.97	497.10	4089.86	8.188E-06
Rg-110H	884.75	884.67	941.63	2.259E-06
I-131	364.26	364.49	4029.52	8.854E-06
Cs-134	604.59	604.73	2665.38	4.900E-06
Cs-134	795.79	795.84	2297.21	4.704E-06
Cs-137	661.61	661.74	7498.06	1.571E-05
Li-140	320.55	321.77	7510.55	6.265E-05
Li-140	432.55	432.97	17751.73	6.874E-05
Li-140	510.05	511.09	2703.15	8.821E-05
Li-140	537.14	537.30	3343.07	6.413E-05
Li-140	604.59	604.73	2179.59	6.890E-05
Li-140	661.61	661.74	3416.59	7.843E-05
Li-140	795.79*	795.84	3501.72	7.133E-05
Ba-140	537.14	537.30	3415.31	1.810E-05

UNIDENTIFIED PEAKS

ENERGY	COUNTS-MIN. AT COUNT TIME
102.46	866.29
432.55	567.21
510.86	2050.62

\*\*\*\*\*  
 \* FINAL SUMMARY OF NUCLIDES OBSERVED \*  
 \*\*\*\*\*

DATE: 5-23-79

NUCLIDE	WEIGHTED NEAR ACTIVITY	+ OR - 1 SIGMA
CO-58	7.921E-06	1.140E-06
ND-95	2.901E-06	5.437E-07
CS-134	4.807E-06	7.354E-07
CS-137	1.571E-05	2.059E-06
LA-140	6.953E-05	8.949E-06
SA-140	1.810E-05	2.000E-06
<b>I 131</b>	<b>8.95 E6</b>	

\*\*\*\*\*  
 \* MINIMUM DETECTABLE ACTIVITIES -  
 \* BASIS: 99% C.L. AT COUNT TIME -  
 \*\*\*\*\*

NUCLIDE	ENERGY (KEV)	ABS. EFF.	ERR. COE.	MDA (C/C-T/HL)
CR-51	3.201E+02	1.159E-02	3.000E+00	4.762E-06
HI-54	8.248E+02	4.472E-03	1.000E+02	4.147E-07
CO-57	1.221E+02	2.222E-02	3.700E+01	1.394E-07
FE-59	1.093E+03	3.477E-03	3.740E+01	1.191E-06
CO-60	1.175E+03	3.287E-03	1.000E+02	3.116E-07
ZR-95	7.567E+02	4.907E-03	5.400E+01	9.623E-07
NA-24	1.369E+03	2.393E-03	1.000E+02	8.984E-07
IR-85	5.140E+02	7.055E-03	4.700E+01	1.167E-04
XE-133	8.100E+01	1.691E-02	3.500E+01	1.112E-06
I-131	3.645E+02	1.022E-02	3.200E+01	1.120E-06
I-133	5.295E+02	6.842E-03	3.900E+01	5.005E-07
CS-136	8.185E+02	4.557E-03	1.000E+02	6.560E-07
MO-99	7.437E+02	2.159E-02	7.500E+01	3.118E-07
CE-141	1.454E+02	2.130E-02	4.300E+01	6.644E-07
ZN-65	1.115E+03	3.432E-03	4.200E+01	1.155E-06

6452 (80996)

6452

1230/5/22

SAMPLE TIME  
700 5 22 79

COUNT TIME  
1150 5 22 79

-----PRELIMINARY PEAK DATA-----

COUNT TIME = 16.666 MINUTES      DELAY TIME = 270 MINUTES  
SAMPLE VOLUME = 750 MILLILITERS

CENTROID CHANNEL	PEAK ENERGY (KEV)	AMOUNT (DPM)	PEAK AREA (COUNTS)	+ OR - (1 SIG)
324.34	162.3904	0.9695	223.0	40.4
657.18	328.6542	1.7521	805.7	40.8
728.72	364.3927	1.2646	585.1	36.0
864.20	432.0722	3.6639	124.0	27.8
974.01	486.9290	1.6450	1240.6	41.9
994.68	496.9567	1.6057	303.5	29.4
1022.19	510.9969	3.3165	310.8	30.9
1074.52	537.1382	2.4853	316.6	29.9
1209.74	604.6867	2.3670	393.2	28.5
1315.03	657.2839	1.2470	82.3	27.5
1324.03	661.7790	1.5804	509.2	36.1
1505.37	751.3684	1.7315	88.6	16.3
1530.43	764.8861	3.3944	148.2	19.5
1592.06	795.6734	2.1479	217.0	18.8
1622.07	812.6645	2.0687	617.0	30.3
1632.74	819.9946	2.0182	230.0	29.1
1736.55	867.05 5	1.1205	74.0	16.1
1770.17	884.64 2	2.1362	101.2	17.4
1851.34	925.1950	1.7115	175.0	15.9
1875.66	912.4442	1.7730	76.0	14.2
2347.97	1172.2048	2.0625	61.3	13.7
3193.93	1595.2005	2.1200	353.2	31.7

-----PRELIMINARY PEAK IDENTIFICATION-----

EFFICIENCY TABLE USED = 45

NUCLIDE	OBSERVED ENERGY	LITERARY ENERGY	COUNTS PER MIN.	UC1 PER ML.
CO-58	310.66	310.69	8066.21	1.468E-05
CO-60	1173.28	1173.20	1119.02	2.016E-06
GR-72	310.66	310.69	10112.80	3.677E-04
GR-72	1595.88	1596.20	28315.99	1.160E-03
HR-95	764.89	764.79	1837.62	3.344E-06
RU-103	496.96	497.10	3161.20	6.325E-06
RG-110H	657.28	657.24	893.00	1.704E-06
RG-110H	864.68	864.67	2508.33	6.162E-06
RG-110H	927.44	927.48	1418.07	7.428E-06
I-131	364.37	364.49	3450.20	7.669E-06
I-134	432.07	432.14	25493.69	1.437E-03
I-134	884.65	884.10	104799.80	2.361E-04
CS-134	604.69	604.70	3008.32	5.531E-06
CS-134	795.67	795.64	2742.32	5.718E-06
CS-137	661.77	661.64	6773.29	1.391E-05
EU-140	486.93	486.90	4633.53	3.865E-05
EU-140	925.19	925.18	10701.03	4.185E-05
EU-140	1595.88	1595.84	4165.21	4.067E-05
EU-140	1772.20	1772.24	3244.06	2.552E-05
EU-140	310.66	310.67	1424.31	4.302E-05
EU-140	432.07	432.14	1993.90	5.078E-05
EU-140	1595.88	1595.87	21410.05	4.559E-05
EU-140	1772.20	1772.24	2640.55	1.505E-05
EU-140	310.66	310.69	460170.21	6.943E-02

UNIDENTIFIED PEAKS

ENERGY	GAMMAS/MIN.
AT COUNT TIME	
162.39	681.79
511.00	2695.48

\*\*\*\*\*  
 \* FINAL SUMMARY OF NUCLIDES OBSERVED \*  
 \*\*\*\*\*

DATE: 5/ 22/ 79

NUCLIDE	WEIGHTED MEAN ACTIVITY	+ OR - 1 SIGMA
CO-58	1.468E-05	1.926E-06
NB-95	3.344E-06	6.000E-07
CS-134	5.620E-06	8.525E-07
CS-137	1.331E-05	1.814E-06
LA-140	4.195E-05	5.748E-06
BA-140	1.505E-05	2.289E-06

$QH = 5.37$        $B = 430$   
 $Cond = 3.17$

\*\*\*\*\*  
 \* MINIMUM DETECTABLE ACTIVITIES \*  
 \* BASIS: 99% C.L. AT COUNT TIME \*  
 \*\*\*\*\*

NUCLIDE	ENERGY* (KEV)	ABS. EFF.	BR(%)	MDA (UCI/ML)
CR-51	3.201E+02	1.159E-02	9.800E+00	5.017E-06
MH-54	8.348E+02	4.472E-03	1.000E+02	5.471E-07
CO-57	1.221E+02	2.222E-02	8.700E+01	3.428E-07
FE-59	1.099E+03	3.477E-03	5.640E+01	9.907E-07
CO-60	1.173E+03	3.287E-03	1.000E+02	1.053E-06
ZR-95	7.567E+02	4.907E-03	5.460E+01	9.702E-07
NR-24	1.369E+03	2.893E-03	1.000E+02	7.463E-07
KR-85	5.146E+02	7.055E-03	4.300E+01	1.409E-04
XE-133	8.100E+01	1.692E-02	3.500E+01	1.158E-06
I-131	3.645E+02	1.022E-02	8.200E+01	1.084E-06
I-133	5.299E+02	6.846E-03	8.900E+01	6.008E-07
CS-136	8.185E+02	4.557E-03	1.000E+02	6.722E-07
MO-99	1.403E+02	2.159E-02	9.500E+01	3.093E-07
CE-141	1.454E+02	2.130E-02	4.800E+01	6.820E-07
ZN-65	1.115E+03	3.433E-03	4.900E+01	1.138E-06

SAMPLE REQUEST TAG

Priority: 1A Date: 5/22/79 Sample No.: 6533

To be completed  
by Sample  
Coordinator

Time: 2100 Results Date: \_\_\_\_\_

Sample ID: Unit No. Cap Gun Halliburton #2  
Effluent

Requestor: Cap Gun Ext. No. 340

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

Name of Collector: \_\_\_\_\_ Date/Time: 5/22/79

To be completed  
by Sample  
Collector

Liquid Volume: 1500ml Air Volume: \_\_\_\_\_ Time On: 1930

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested:  Scan  PH  Cond.  B

Signature: \_\_\_\_\_

Scan/Chem Completed: Date/Time: 5/22/79 2200

To be  
completed  
by Lab

Counter's Signature: R. H. Fisher

Chem Results: DF = 1.13, Pm = 14.25, B = 410

\_\_\_\_\_ Please Phone Results to Sample Coordinator

Copy Description - White - Sample Coord.

Canary - With Sample

Pink - Pending

0030  
5723

SAMPLE TIME  
1980 5 22 79

COUNT TIME  
2206 5 22 79

----- PRELIMINARY PEAK DATA -----

COUNT TIME = 16.8666 MINUTES  
SAMPLE VOLUME = 250 MILLILITERS

DECAY TIME = 186 MINUTES

CENTROID CHANNEL	PEAK ENERGY (KEV)	FWHM (KEV)	PEAK AREA (COUNTS)	+ OR - (1 SIG)
657.68	328.6963	1.6527	472.5	36.0
728.52	364.2973	2.0829	335.2	31.6
854.42	427.1896	0.7936	59.8	23.8
973.91	486.8804	1.6610	742.0	35.5
994.20	497.6168	1.6867	241.0	26.6
1021.69	510.7472	2.2210	364.0	32.6
1074.14	536.9483	1.8990	118.4	22.0
1209.19	604.4120	2.1279	385.5	31.8
1314.50	657.6192	1.2325	169.2	29.1
1324.35	661.9397	1.6299	511.9	36.9
1529.60	764.1717	1.4874	52.0	17.6
1592.85	795.6681	2.1398	240.6	21.2
1621.97	818.6145	1.8994	868.5	32.7
1636.53	817.9129	1.9316	96.8	25.1
1736.46	867.9075	1.3460	51.4	12.7
1770.08	884.6623	1.7843	210.1	18.5
1851.13	925.0904	2.0724	62.5	11.7
1875.94	937.4842	1.6380	94.4	13.0
2347.75	1173.1749	2.2873	99.4	14.1
2933.78	1460.9282	3.5460	37.1	9.2
3194.31	1596.0704	2.6803	30.0	20.9

----- PRELIMINARY PEAK IDENTIFICATION -----

EFFICIENCY TABLE USEL = 45

NUCLIDE	OBSERVED ENERGY	LIBRARY ENERGY	CANALS PER MIN.	UCI PER ML.
K-40	1460.92	1460.90	809.01	1.325E-05
Co-58	810.61	810.20	11047.06	2.065E-05
Co-60	1173.17	1173.29	1814.34	3.269E-06
Gd-72	810.61	810.20	13287.05	1.140E-03
Gd-72	1596.07	1596.89	15029.42	6.273E-04
Pu-103	497.62	497.10	1904.00	3.974E-06
Hg-110H	657.62	657.74	1812.00	3.460E-06
Hg-110H	884.60	884.67	3090.71	7.415E-06
Hg-110H	937.48	937.48	1411.00	7.395E-06
I-131	364.30	364.49	1923.98	4.370E-06
I-134	804.60	804.13	41177.62	1.104E-04
Cs-134	604.41	604.70	3023.96	7.605E-06
Cs-134	795.57	795.64	3035.05	6.817E-06
Cs-136	617.91	618.50	1032.97	2.313E-06
Cs-137	661.94	661.64	5020.95	1.157E-05
Li-140	328.64	328.77	2652.10	2.212E-05
Li-140	104.30	102.24	6305.41	1.447E-05
Li-140	271.71	271.71	755.21	3.304E-05
Li-140	425.00	425.00	755.01	1.629E-05
Li-140	1596.07	1596.77	15018.40	1.500E-05
Li-140	536.95	537.29	1052.09	5.610E-06
Er-84	310.61	310.90	73264.05	1.567E-02



437.19      408.39  
 510.75      3978.13  
 784.17      641.75

\*\*\*\*\*  
 \* FINAL SUMMARY OF NUCLIDES OBSERVED \*  
 \*\*\*\*\*

DATE: 5/22/79

NUCLIDE	WEIGHTED MEAN ACTIVITY	+ OR - 1 SIGMA
E-40	<del>1.25E-05</del>	
CO-58	2.065E-05	3.674E-06
CS-134	6.692E-06	2.630E-06
CS-137	1.157E-05	9.495E-07
BH-140	5.610E-06	1.636E-06
<b>I 131</b>	<b>4.37 E-6</b>	1.247E-06

\*\*\*\*\*  
 \* MINIMUM DETECTABLE ACTIVITIES \*  
 \* BASIS: 99% C.L. AT COUNT TIME \*  
 \*\*\*\*\*

NUCLIDE	ENERGY (E.V.)	ABS. EFF.	BP (%)	MDA (DCI/ML)
CR-51	3.201E+02	1.159E-03	5.000E+00	4.592E-07
HP-54	8.343E+02	4.472E-03	1.000E+03	5.318E-07
CO-57	1.221E+02	2.222E-01	5.000E+01	3.862E-07
FE-59	1.099E+02	3.477E-03	5.000E+01	3.584E-07
CO-60	1.177E+03	3.237E-03	1.000E+02	1.110E-06
ZN-65	7.567E+02	4.367E-03	5.400E+01	5.249E-07
HE-65	7.653E+02	4.852E-04	5.000E+01	3.115E-07
Na-24	1.369E+03	2.993E-03	1.000E+02	4.715E-07
BR-80	5.146E+02	7.055E-03	5.000E+01	1.405E-06
SE-133	8.109E+01	1.671E-02	5.000E+01	1.644E-06
I-131	3.645E+02	1.622E-02	2.000E+01	3.601E-07
I-132	5.237E+02	6.842E-03	5.000E+01	6.932E-07
CS-136	3.101E+02	4.557E-03	1.000E+02	3.132E-07
NO-99	1.409E+02	2.169E-03	5.000E+01	2.963E-07
LE-141	1.451E+02	2.130E-03	4.000E+01	6.047E-07
ZH-69	1.115E+03	3.433E-03	4.000E+01	1.099E-06



SAMPLE REQUEST TAG

To be completed  
by Sample  
Coordinator

Priority: 1A Date: 5/22/79 Sample No.: 6533  
Time: 2100 Results Date: \_\_\_\_\_  
Sample ID: Unit No. CAP Gun Halliburton  
No 2 Effluent  
Requestor: CAP Gun Ext. No. 340  
Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W   
SAI \_\_\_\_\_ RMS \_\_\_\_\_  
NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: \_\_\_\_\_ Date/Time: 5/22/79  
Liquid Volume: 1.500ml Air Volume: \_\_\_\_\_ Time On: 1930  
1.250ml \_\_\_\_\_ Time Off: \_\_\_\_\_  
Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_  
Analysis Requested:  Scan  PH  Cond.  B   
Signature: \_\_\_\_\_

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: May 22, 1973 2317  
Counter's Signature: Markell Portillo  
Chem Results: \_\_\_\_\_

\_\_\_\_\_ Please Phone Results to Sample Coordinator

Copy Description - White - Sample Coord.

Canary - With Sample

Pink - Pending



SAMPLE REQUEST TAG

To be completed  
by Sample  
Coordinator

Priority: 1 Date: 5/29/79 Sample No.: 7687

Time: 1555 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. 2 Contaminated Drain  
Tank WOL-T-11A

Requestor: Rad Waste Ext. No. \_\_\_\_\_

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W \_\_\_\_\_  
SAI  RMS \_\_\_\_\_  
NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: Gordon Reider Date/Time: 1545 5/29/79

Liquid Volume: 500 ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested:  Scan  PH \_\_\_\_\_ Cond. \_\_\_\_\_ B \_\_\_\_\_

Signature: \_\_\_\_\_

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: 5/29 1936

Counter's Signature: C. Hubmann

Chem Results: \_\_\_\_\_

\_\_\_\_\_ Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending

SAMPLE REQUEST TAG

5-29  
2200

To be completed  
by Sample  
Coordinator

Priority: 1 Date: 5/29/79 Sample No.: 7687

Time: 1555 Results Date: \_\_\_\_\_

Sample ID: Unit No. 2 Contaminated Drain  
Tank WDL-T-11A

Requestor: Rad Waste Ext. No. \_\_\_\_\_

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W \_\_\_\_\_

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

*met Ed Chem -*

Name of Collector: Gordon Reidler Date/Time: 1545 5/29/79

To be completed  
by Sample  
Collector

Liquid Volume: 500 ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested: 8 Scan . PH ✓ Cond. ✓ B \_\_\_\_\_

TDS

Signature: \_\_\_\_\_

To be completed  
by Lab

Scan/Chem Completed: Date/Time: \_\_\_\_\_

Counter's Signature: 6:46 on 7925

Chem Results: PH - 4.2 Cond 624

TDS 1378

Please Phone Results to Sample Coordinator

Copy Description - White - Sample Coord.

Canary - With Sample

Pink - Pending

7799  
5/30  
14100

SAMPLE REQUEST TAG

Priority: 1 Date: 5-30-79 Sample No.: 7799

To be completed  
by Sample  
Coordinator

Time: 0845 Results Date: \_\_\_\_\_

Sample ID: Unit No. 2 Cont. Dr. Tr. A  
WDLT-11A

Requestor: RADWASTE Ext. No. \_\_\_\_\_

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W \_\_\_\_\_

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

Name of Collector: H F Date/Time: 5/30/79 @ 0845

To be completed  
by Sample  
Collector

Liquid Volume: \_\_\_\_\_ Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested:  Scan \_\_\_\_\_ PH  Cond. \_\_\_\_\_ B \_\_\_\_\_

Resample for pH Only!

Signature: H.E. Chwalick

Scan/Chem Completed: Date/Time: 5/30 0845

To be completed  
by Lab

Counter's Signature: \_\_\_\_\_

Chem Results: PH 4.73

\_\_\_\_\_ Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending









1315 6/1

SAMPLE REQUEST TAG

Priority: IA Date: 6/1/79 Sample No.: 8218

To be completed  
by Sample  
Coordinator

Time: 1130 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. Cap Gun Demo #8 EFF

Requestor: Cap Gun Ext. No. 340

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

Name of Collector: \_\_\_\_\_ Date/Time: 6/1/79

To be completed  
by Sample  
Collector

Liquid Volume: (1) 500ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: 0830

Analysis Requested:  Scan  PH  Cond.  B

Signature: \_\_\_\_\_

Scan/Chem Completed: Date/Time: 6/1/79 1300

To be  
completed  
by Lab

Counter's Signature: CEH

Chem Results: pH = 6.42, COND = .76, B = 210 μS/cm

\_\_\_\_\_ Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending



SAMPLE REQUEST TAG

\* Run First #8219  
1315 6/1

To be completed  
by Sample  
Coordinator

Priority: 1A\* Date: 6/1/79 Sample No.: 8219

Time: 1130 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. Cap Gun Demo #8 EFF.

Requestor: Cap Gun Ext. No. 340

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: \_\_\_\_\_ Date/Time: 6/1/79

Liquid Volume: (1) 500ml Air Volume: \_\_\_\_\_  
(1) 250ml

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: 1000

Analysis Requested:  Scan  PH  Cond.  B

Signature: \_\_\_\_\_

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: 6/1/79 1300

Counter's Signature: JTB

Chem Results: pH = ~~5.71~~ 5.77 B = <10 ppm

\_\_\_\_\_ Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending





SAMPLE REQUEST TAG

To be completed  
by Sample  
Coordinator

Priority: 1A Date: 6/5/79 Sample No.: 8949

Time: 1205 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. 42 CONTAMINATED DRAIN TIE  
B

Requestor: RADIATION Ext. No. \_\_\_\_\_

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: \_\_\_\_\_ Date/Time: 6/5 1540

Liquid 50ml Air \_\_\_\_\_ Time \_\_\_\_\_  
Volume: 10ml to 4 Volume: \_\_\_\_\_ On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow \_\_\_\_\_ Time \_\_\_\_\_  
Rate: \_\_\_\_\_ Off: \_\_\_\_\_

Analysis Requested:  Scan  PH  Cond.  B \_\_\_\_\_  
( 715' ) 691 kwh 32' pr.

Signature: \_\_\_\_\_

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: \_\_\_\_\_

Counter's Signature: \_\_\_\_\_

Chem Results: \_\_\_\_\_

\_\_\_\_\_ Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending







#9438  
0830 6/8

GAMMA ANALYSIS SUMMARY SHEET

ME No. 1 \_\_\_\_\_ No. 2  B&W \_\_\_\_\_ SAI \_\_\_\_\_ RMC \_\_\_\_\_ EG&G \_\_\_\_\_ NRC \_\_\_\_\_

Title Demin #8 EFF (Gate 10 area) Sample No. 9438

Time/Date Sample 0430 6/8/79 Time/Date Analysis 0621 6/8/79

Geometry 250ml bottle Counting Time 1000 sec.

Volume 250ml Analyst Peter Roberto

Air \_\_\_\_\_ (1) Liquid  (2) Other \_\_\_\_\_

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
Kr-85	7.414E-05		4.553E-05
Nb-95	6.262E-06		9.581E-07
Ru-103	4.464E-05		1.044E-05
Cs-134	3.589E-06		8.143E-07
Cs-137	1.513E-05		2.061E-06
La-140	1.785E-04		2.196E-05
Ba-140	4.149E-05		5.430E-06
I-131		9.110E-07	
Co-58		1.099E-06	
Co-60		1.039E-06	

SAMPLE REQUEST TAG

To be completed  
by Sample  
Coordinator

Priority: 1 Date: 6-8-79 Sample No.: 9439

Time: 0430 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. Demin # 8 EFF  
(Gate 10 area)

Requestor: Cap-Gun Ext. No. 340

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W X  
SAI \_\_\_\_\_ RMS \_\_\_\_\_ CHEM  
NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: \_\_\_\_\_ Date/Time: 6/8 0430

Liquid Volume: 1000 ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested: ✓ Scan \_\_\_\_\_ PH ✓ Cond. ✓ B ✓

Signature: \_\_\_\_\_

To be completed  
by Lab

Scan/Chem Completed: Date/Time: 6/8/79 0830

Counter's Signature: R. L. Fisher

Chem Results: pH = 6.38, Cond = 2.46, B = 75

\_\_\_\_\_ Please Phone Results to Sample Coordinator

Copy Description - White - Sample Coord.

Canary - With Sample

Pink - Pending













REQUEST TAG

13940  
7/17/79  
1800

To be completed  
by Sample  
Coordinator

Priority: 1 Date: 7/17 Sample No.: 13940

Time: 1445 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. 1 Neutralizer Feed Tank  
(WDLT-9)

Requestor: Marshall Ext. No. 360

Scan Sample Met-Ed No. 1  No. 2 \_\_\_\_\_ B&W \_\_\_\_\_

SAI \_\_\_\_\_ RMC \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: Met-Ed Date: \_\_\_\_\_

Liquid Volume: \_\_\_\_\_ Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested:  Scan  PH  Cond.  B

Signature: \_\_\_\_\_

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: \_\_\_\_\_

Counter's Signature: \_\_\_\_\_

Chem Results: PH - 6.85 ; Cond - 530 ; B - 36

Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending

13962  
7/18  
0500

GAMMA ANALYSIS SUMMARY SHEET

ME No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W  SAI \_\_\_\_\_ RMC \_\_\_\_\_ EG&G \_\_\_\_\_ NRC \_\_\_\_\_

Title Cap-Gun #1 Demin #9 Effluent Sample No. 13962

Time/Date Sample 0115 7/18 Time/Date Analysis 0200 7/18

Geometry 250 pbottle Counting Time 103sec

Volume 250 ml Analyst D. Benedetti

Air \_\_\_\_\_ (1) Liquid  (2) Other \_\_\_\_\_

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
Nh-95	2.948E-05		6.753E-06
Cs-134	8.035E-05		1.569E-05
Cs-137	2.999E-04		2.891E-05
Ba-140	4.876E-04		4.906E-05
La-140	1.634E-03		8.251E-05
Co-60		2.916E-05	
Co-58		3.830E-05	
I-131		1.415E-05	
#13961	results:		
	pH 5.85		
	cond 2.1		
	boron 35.3		



SAMPLE REQUEST TAG

To be completed  
by Sample  
Coordinator

Priority: IA Date: 7/18 Sample No.: 14010  
Time: 1200 Results Date: \_\_\_\_\_  
Sample ID: Unit No. CAP Gun 1 U-1  
Halliburton #2  
Requestor: CAP-GUN (L. Burgess) Ext. No. 340  
Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W   
SAI \_\_\_\_\_ RMS \_\_\_\_\_  
NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: CAP GUN Date/Time: 7/18/79 @ 1015  
Liquid Volume: 250ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_  
Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_  
Analysis Requested:  Scan  PH \_\_\_\_\_ Cond. \_\_\_\_\_ B \_\_\_\_\_  
Signature: David Hall

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: \_\_\_\_\_  
Counter's Signature: \_\_\_\_\_  
Chem Results: \_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_ Please Phone Results to Sample Coordinator

Copy Description - White - Sample Coord.

Canary - With Sample

Pink - Pending



14010

1750 7/18

GAMMA ANALYSIS SUMMARY SHEET

ME No. 1 No. 2 B&W SAI RMC EG&G NRC

Title CAP-GUN#1 Halliburton #2 Sample No. 14010

Time/Date Sample 1015 7/18/79 Time/Date Analysis 1503 7/18/79

Geometry Liquid/Plastic bottle Counting Time 10<sup>3</sup> sec

Volume 250 ml Analyst Makovey

Air (1) Liquid (2) Other

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
Cs-134	1.570E-5		5.993E-6
Cs-137	5.238E-5		6.743E-6
BA-140	1.457E-4		1.808E-5
LA-140	6.725E-4		3.889E-5
Co-60		1.382E-5	
Co-58		2.011E-5	
I-131		6.924E-6	
gH	5.52		
Cond	3.2		
Box	215		

14102  
7/19  
2230

GAMMA ANALYSIS SUMMARY SHEET

ME No. 1  No. 2  B&W  SAI  RMC  EG&G  NRC

Title weest B Sample No. 14102

Time/Date Sample 7/19/79 @1742 Time/Date Analysis 7/19/79 1848

Geometry 0 cm Counting Time 50 min

Volume 3500 Analyst \_\_\_\_\_

Air  (1) Liquid  (2) Other

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
Po-58	3.672E-6		.
Po-60	4.799E-6		
NB-95	1.259E-5		
Ru-103	2.167E-5		
Cs-134	1.482E-5		
LA-140	3.108E-4		
BA-140	1.033E-4		
Ce-141	1.504E-6		
AG-110M	6.59E-6		
Zr-95	1.438E-6		
I-131	-	4.176E-7	





SAMPLE REQUEST TAG

14195  
7/21  
0600

Priority: 1-A Date: 7-21-79 Sample No.: 14195

To be completed  
by Sample  
Coordinator

Time: 0400 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. HALLIBURTON #2 EFFLUENT

Requestor: \_\_\_\_\_ Ext. No. 341

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W X

SAI \_\_\_\_\_ RMC \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

Name of Collector: BRANDT Date: 7-21-79

To be completed  
by Sample  
Collector

Liquid Volume: 250 ml Air Volume: \_\_\_\_\_ Time On: 0330

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested: ✓ Scan \_\_\_\_\_ PH X Cond. X B X

CHEMISTRY

Signature: Roger Brandt

~~Scan/Chem Completed~~ Date/Time: 7/21/79 0555

To be completed  
by Lab

Counter's Signature: James H. Smith

Chem Results: pH 5.65 COND 2.4 umhos/cm R-50/4 ppm

\_\_\_\_\_  
Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending













SAMPLE REQUEST TAG

Priority: 1A Rush Date: 9-21-79 Sample No.: 14237

Time: 1915 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. 1 Aux Bldg Sump  
✓ 1:10 detention

Requestor: U-1 CR Ext. No. \_\_\_\_\_

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W X  
SAI \_\_\_\_\_ RMC \_\_\_\_\_  
NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Coordinator

Name of Collector: \_\_\_\_\_ Date: 9/21

Liquid Volume: 100 in 10 Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: 1440

Analysis Requested: γ Scan X PH \_\_\_\_\_ Cond. \_\_\_\_\_ B \_\_\_\_\_

Signature: \_\_\_\_\_

To be completed  
by Sample  
Collector

Scan/Chem Completed: Date/Time: \_\_\_\_\_

Counter's Signature: \_\_\_\_\_

Chem Results: \_\_\_\_\_

\_\_\_\_\_ Please Phone Results to Sample Coordinator

To be  
completed  
by Lab

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending





SAMPLE REQUEST TAG

To be completed  
by Sample  
Coordinator

Priority: 1A Rush Date: 7-21-79 Sample No.: 14247

Time: 2150 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. 1 Aux Bldg Sump

Requestor: U-1 CR Ext. No. \_\_\_\_\_

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W X  
SAI \_\_\_\_\_ RMC \_\_\_\_\_  
NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: \_\_\_\_\_ Date: 7/21

Liquid Volume: 10 ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: 2135

Analysis Requested: X Scan X PH \_\_\_\_\_ Cond. \_\_\_\_\_ B \_\_\_\_\_

Signature: \_\_\_\_\_

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: \_\_\_\_\_

Counter's Signature: \_\_\_\_\_

Chem Results: \_\_\_\_\_

\_\_\_\_\_ Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending















GAMMA ANALYSTS SUMMARY SHEET

704  
1350

ME No. 1            No. 2            B&W            SAT            RMC  EG&G            NRC           

Title Cap Green T - Demin #988 Sample No. 14412

Time/Date Sample 24 Jul 0230 Time/Date Analysis 24 Jul 0833

Geometry 500 cc bottle Counting Time 1000 sec

Volume 500 ml Analyst           

Air            (1) Liquid W3010 (2) Other           

- Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
- Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
I-131		$< 7.1 E^{-7}$	-
Cs-134	$1.0 E^{-5}$		25%
Cs-137	$3.1 E^{-5}$		25%
Co-58	$3.7 E^{-6}$	<del>4.4</del>	25%
Co-60	$2.4 E^{-6}$	<del>4.4</del>	25%
U-235M	$8.2 E^{-5}$		28%
Am-241M	$9.5 E^{-6}$		25%
K-40	$6.8 E^{-6}$		25%
Ba-140	$1.8 E^{-5}$		25%
La-140	$5.5 E^{-5}$		25%
Nb-95	$4.4 E^{-6}$		25%
Ce-144	$4.4 E^{-6}$		43%

14499  
7/25  
1800

GAMMA ANALYSIS SUMMARY SHEET

ME No: 1  No. 2  B&W  SAI  RMC  EG&G  NRC

Title WECST "B" Unit 1 Sample No. 14499

Time/Date Sample 0505 7/25 Time/Date Analysis 0520 7/25

Geometry \_\_\_\_\_ Counting Time 50 min.

Volume 3500 ml. Analyst \_\_\_\_\_

Air  (1) Liquid  (2) Other \_\_\_\_\_

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
H-3	4.26 E-3		-
Mn-54	3.29 E-7		
Co-58	2.32 E-6		
Co-60	3.23 E-6		
Cs-134	8.85 E-6		
Cs-137	1.90 E-5		
I-131		<2.22 E-7	
Ba-140	1.88 E-5		
La-140	3.88 E-5		
Zr-95	9.36 E-7		
Nb-95	5.92 E-6		
Zr-97	3.67 E-7		
Ru-103	8.16 E-6		
Ag-110M	5.46 E-6		
Ce-141	1.08 E-6		
Ce-144	1.07 E-5		

14501  
7/25  
2200

GAMMA ANALYSIS SUMMARY SHEET

ME No. 1  No. 2  B&W  SAI  RMC  EG&G  NRC

Title WPCST (A) Sample No. 14501

Time/Date Sample 1920 7/25/79 Time/Date Analysis 1927 7/25/79

Geometry 0 Counting Time 50

Volume 3500 Analyst R. J. W.

Air  (1) Liquid  (2) Other

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
MN-54	$2.329 E^{-7}$		
Co-58	$2.47 E^{-6}$		
Co-60	$2.492 E^{-6}$		
NB-95	$1.961 E^{-5}$		
Cs-134	$7.276 E^{-6}$		
LA-140	$1.156 E^{-5}$		
BA-140	$5.159 E^{-6}$		
Ce-141	$1.504 E^{-7}$		
C-144	$3.697 E^{-6}$		
I-131	-	$1.59 E^{-7}$	
Cs-137		$6.619 E^{-7}$	







# UPDATE

14499  
1130 7/2

## GAMMA ANALYSIS SUMMARY SHEET

ME No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W \_\_\_\_\_ SAI \_\_\_\_\_ RMC y EG&G \_\_\_\_\_ NRC \_\_\_\_\_

Title WECST B Sample No. 14499

Time/Date Sample 25 JUL 79 @ 0505 Time/Date Analysis 27 JUL 79 @ 0204

Geometry METAL PLANCHET Counting Time 500 SEC

Volume 100 ML EVAP. Analyst [Signature]

Air \_\_\_\_\_ (1) Liquid \_\_\_\_\_ (2) Other F5105

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
I-131		$< 2.1E-7$	.
Cs-134	$1.82E-4$		$\pm 25\%$
Cs-137	$9.86E-4$		$\pm 25\%$
Co-58		$< 1.1E-6$	
Co-60		$< 7.9E-7$	
BA-140	$1.50E-5$		$\pm 25\%$
LA-140	$5.18E-5$		$\pm 25\%$

sum of  $\delta$   $1.24 E-4$

Loss, B8

WECST B





















SAMPLE REQUEST TAG

To be con  
by Sample  
Coordinate

Priority: 1A Date: 8-5-77 Sample No.: 15431

Time: 035 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. HAT # 2  
CAP GUN I PAD

Requestor: CAP GUN I Ext. No. 341

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W X

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: Roger Brandt Date/Time: 85/0300

Liquid Volume: 250 ~~500~~ ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested: ✓ Scan X PH \_\_\_\_\_ Cond. \_\_\_\_\_ B \_\_\_\_\_

Signature: Roger Brandt

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: \_\_\_\_\_

Counter's Signature: \_\_\_\_\_

Chem Results: \_\_\_\_\_

Please Phone Results to San. Coord. Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending





SAMPLE REQUEST TAG

To be completed  
by Sample  
Coordinator

Priority: 1A Date: 8/5 Sample No.: 15432

Sample ID: \_\_\_\_\_ Time: 0350 Results Date: \_\_\_\_\_

Unit No. HALIBURTON #2

CAPGUN I PAD

Requestor: CAPGUN I Ext. No. \_\_\_\_\_

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W \_\_\_\_\_

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: R. Brandt Date/Time: 8-5/0300

Liquid Volume: 500 mls Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

~~250~~ ML

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested:  Scan \_\_\_\_\_ PH  Cond.  B

boil 100 mls on Planchet → B&W Counting for Gross β, γ

Signature: Roger Brandt

To be completed  
by Lab

~~Scan~~/Chem Completed: Date/Time: 8/5 0540

Counter's Signature: James H. Smith

Chem Results: PH 6.07 conductivity 4.5 umhos/cm

Boron 298 ppm Boil down 100 ml sample onto planchet (duplicate)

Please Phone Results to Sample Coordinator

- Copy Description - White - Sample Coord.
- Canary - With Sample
- Pink - Pending





SAMPLE REQUEST TAG

DET 10

To be completed  
by Sample  
Coordinator

Priority: 1A Date: 8-7-79 Sample No.: 15774

Time: 2230 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. HALBURTON #2 EFF

CAP GUN I

Requestor: CAP GUN I Ext. No. 340

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W \_\_\_\_\_

SAI  RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: R. Brandt Date/Time: 8-7/2145

Liquid Volume: 500 ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested:  Scan  PH \_\_\_\_\_ Cond. \_\_\_\_\_ B \_\_\_\_\_

Signature: R. Brandt

To be  
completed  
by Lab

Scan/Chem Completed: Date/Time: \_\_\_\_\_

Counter's Signature: \_\_\_\_\_

Chem Results: \_\_\_\_\_

\_\_\_\_\_ Please Phone Results to Sample Coordinator

Copy Description - White - Sample Coord.

Canary - With Sample

Pink - Pending





SAMPLE REQUEST TAG

To be completed  
by Sample  
Coordinator

Priority: 1A Date: 8-7-79 Sample No.: 15775

Time: 2230 Results Date: \_\_\_\_\_

Sample ID: \_\_\_\_\_ Unit No. HALBURTON # 2 EFF

Requestor: CAP GUN I Ext. No. 340

Scan Sample Met-Ed No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W \_\_\_\_\_

SAI \_\_\_\_\_ RMS \_\_\_\_\_

NRC \_\_\_\_\_ EG&G \_\_\_\_\_ Other: \_\_\_\_\_

To be completed  
by Sample  
Collector

Name of Collector: R Brandt Date/Time: 8-7-79 148

Liquid Volume: 500 ml Air Volume: \_\_\_\_\_ Time On: \_\_\_\_\_

Other: \_\_\_\_\_ Flow Rate: \_\_\_\_\_ Time Off: \_\_\_\_\_

Analysis Requested:  Scan \_\_\_\_\_ PH  Cond.  B

100 ml gross Beta

Signature: Roger Brandt

To be completed  
by Lab

Scan/Chem Completed: Date/Time: 8/8/79 0120

Counter's Signature: James H. Smith

Chem Results: pH 6.36 conductivity 12.0 umho/cm

Boron 315 ppm Evaporate 10 ml sample onto

Planchet for gross B8

Please Phone Results to Sample Coordinator

Copy Description - White - Sample Coord.

Canary - With Sample

Pink - Pending

GAMMA ANALYSIS SUMMARY SHEET

ME No. 1. \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W  SAI \_\_\_\_\_ RMC \_\_\_\_\_ EG&G \_\_\_\_\_ NRC \_\_\_\_\_

Title Unit 2 Cont Drain Tank "A" Sample No. 14662

Time/Date Sample 1015 7-27-79 Time/Date Analysis 1700 7-27-79

Geometry \_\_\_\_\_ Counting Time (10<sup>3</sup> sec)

Volume (250ml) Analyst MDA [Signature]

Air \_\_\_\_\_ (1) Liquid  (2) Other \_\_\_\_\_

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
Cs 137	$1.864E^{-5}$		$2.726E^{-6}$
I 131		$3.006E^{-6}$	
Cs 134		$9.004E^{-6}$	
Co 58		$4.071E^{-6}$	
Co 60		$4.997E^{-6}$	
Gross B Scan	53	$1/d/m = 2.392E^{-06} \mu Ci/m^3$	
pH	8.8		
Cond	828 $\mu mhos/cm$		
Boron	10 ppm		























15543  
8/6  
0730

GAMMA ANALYSIS SUMMARY SHEET

ME No. 1 \_\_\_\_\_ No. 2 \_\_\_\_\_ B&W  SAI \_\_\_\_\_ RMC \_\_\_\_\_ EG&G \_\_\_\_\_ NRC \_\_\_\_\_

Title Haliburton #1 Effluent Sample No. 15543

Time/Date Sample 0200 8/6 Time/Date Analysis 0540 8/6

Geometry \_\_\_\_\_ Counting Time \_\_\_\_\_

Volume 500 ml Analyst JH Smith

Air \_\_\_\_\_ (1) Liquid  (2) Other Boil down

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Isotope	Concentration	MDA	Uncertainty
pH	6.34		
conductivity	6.5 umhos/cm		
Boron	226 ppm		
Boil down 100 ml sample onto planchet for gross B&S analysis			
29051	Gross Cpm		MDA = 3.96 E-6 uci
73	Bkg/d		
28978	NET Cpm		
.677	EFF		
41457	NET Dpm		
$1.87 \times 10^{-2}$	NET uci for 100 ml sample		
$1.87 \times 10^{-4}$	uci/ml		















GAMMA ANALYSIS SUMMARY SHEET

16004  
 8/10/79  
 Ohio

ME No: 1 No. 2 B&W  SAI RMC NRC Other

Title Cay Sun Dental Effluent Sample No. 16004

Time/Date Sample 0100 8/10/79 Time/Date Analysis 0456 8/10/79

Geometry Plastic Bottle Counting Time 10<sup>3</sup> sec

Volume 250 ml Analyst CHM

Air (1) Liquid  (2) Other

1. Report MDA's for I-131 on charcoal cartridges and for Cs-134, Cs-137, Co-58 and Co-60 on particulate filters for those isotopes which are not detected in sample.
2. Report MDA's for I-131, Cs-134, Cs-137, Co-58 and Co-60 for those isotopes which are not detected in sample.

Liquid

Isotope	Concentration	LLD	Uncertainty
I-131		2.607E-06	-
Cs-134	1.842E-05		4.015E-06
Cs-137	7.849E-05		5.101E-06
Co-60		5.159E-06	
Co-58		6.740E-06	
Ka-140		1.135E-05	
Ba-140		1.111E-05	







DATE 5-23-79 TIME 0805 RE. DEST. MJ 1055 / P/B by ph...

WDL-11A TANK A  
 WDL-11B TANK B  
 WDL-12 LAUNDRY  
 Other

TANK ISOLATED & "DO NOT OPERATE" TAGGED  
 TANK LEVEL 11.8' VOLUME 7568 gal.

SIGNED [Signature] DATE 5-23 TIME 0555

(47) 30 gpm FR MAX (5-30 gpm) 250 min minimum estimated time for RELEASE

(48) ESTIMATED CURIES TO BE DUMPED .0037 x 40 = .1484 % OF QUARTERLY LIMIT  
 CURIES DUMPED TO DATE THIS QTR. — x 40 = — % OF QUARTERLY LIMIT  
78-792 LAST RELEASE # INCLUDED TOTAL 4.542 % OF QUARTERLY LIMIT

(49)  RELEASE RECOMMENDED BY [Signature] RADIATION PROTECTION SURV Foreman  
 RELEASE RECOMMENDED BY [Signature] SUP OF RAD PROT & CHEM UNIT SUPERINTENDENT  
 RELEASE APPROVED BY [Signature] SHIFT SUPERVISOR

(50) RELEASE DATA:  
 RM-L6 Setpoint Hi Alarm 3700 CPN: Alert 1500 CPN:  Initials [Signature]  
 FR-84 ALARM SET POINT AT 3200 GPM: — INITIALS  
 WARNING SIGN ("CAUTION UNIT 1 DURING LIQUID RELEASE") HUNG ON WDL-99 KEY SWITCH  
 IN UNIT 11 AUX. BLDG. INITIALS DEK  
 FR-146 ALARM SETPOINT AT 37,200 GPM:  INITIALS  
 VALV DL-V124  
 VALV DL-V125 LOADED TO 27 GPM RELEASE RATE 75 INITIALS

(51) TIME RELEASE STOPPED 0035 5/25/79 Tank Level at Start of Release 11.8 ft. 7568  
 TIME DATE Tank Level at End of Release 15 ft. 930  
 TIME DATE Tank Volume Released 11.3 ft. 6638  
 TIME DATE MDCT EFFLUENT TOTALIZER AT STOP 794816 GAL  
 MINUTES MDCT EFFLUENT TOTALIZER AT START 794229 GAL  
 TOTAL DILUTION FLOW 587 GAL

(52) FLOW AND RADIATION MONITORING RECORDER CHARTS MARKED:  
 RM-L6 Source Check Sat. Before Rel.  AT BEGINNING OF RELEASE   
 RM-L6 Alarm Returned to: Hi-Alarm = 3600 CPN:  AT END OF RELEASE   
 INSTRUMENT READINGS. Alert Alarm = 1800 CPN:  RM-L6 Filter

	EXPECTED READING	READING AT START	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	RELEASE RATE
FR 34	27 gpm	25	15	17	17	17	0
RM-L6	14,002 cpn	900	18K	20K	20K	20K	25,000
FR 146	34,200 gpm	39,000	38K	39K	39K	39K	38,000
RM L7	421.5 rpm	350	400	450	350	350	400

(53) IF CHANGES IN FLOW FROM THE MDCT (OR CHANGES IN THE RELEASE RATE (V124/V125) (non) DEVELOP DURING THE RELEASE. CALCULATION OF A NEW RATE AND SETPOINTS MUST BE MADE. THE NEW CALCULATIONS WILL BE COMPUTED ON PAGE 2 OF THIS FORM AND THE FOLLOWING TABLE WILL BE COMPLETED.

	START TIME	STOP TIME	TOTAL TIME	*ACTUAL RELEASE RATE	FR-84 SET POINT	FR-146 SET POINT	APPROVAL SHIFT SUPERVISOR
ORIGINAL							
1st CHANGE							
2nd CHANGE							

\*RELEASE RATE CANNOT BE LESS THAN 5 GPM. MDCT CANNOT BE <5000 or >35,000 rpm.

(54) RELEASE DATA COMPLETED BY [Signature] INITIALS.  
 ALL DATA REQUIRED ON THIS FORM HAS BEEN COMPLETED. [Signature]  
 SIGNATURE: PERVISCH

SPECIAL OPERATION CALCULATIONS

FOR UNEXPECTED CHANGES IN THE MDCT FLOW OR ACTUAL RELEASE RATE THE FOLLOWING CALCULATIONS MUST BE RE-COMPUTED BY THE SHIFT SUPERVISOR. THIS NEED ONLY BE DONE IF THE MDCT FLOW IS REDUCED.

1. MAXIMUM RELEASE RATE = (FR-84 SETPOINT)

$$RR - MAX = \frac{NEW MDCT FLOW GPM \times (0.9)}{REQUIRED D.F.} = \boxed{\phantom{000}} \text{ GPM}$$

2. ACTUAL RELEASE RATE + (RR MAX) x (0.9) =  $\boxed{\phantom{000}}$  GPM

3. MINIMUM FLOW FROM MDCT (FR-146 SETPOINT) = NEW MDCT FLOW x (0.9) =  $\boxed{\phantom{000}}$  GPM

USE THIS AREA FOR CALCULATIONS:

25 CHEMISTRY PARAMETERS

26 Sample Obtained By: KB Analysis Performed By: KB  
Date/Time: 5/23/79 @ 1000 Date/Time: 5/23/79 @ 1150

Dilution Factor Required Based on Boron (From Note 3)  $\boxed{1523}$

	RESULT	LIMIT
pH	<i>re-anal 6.1 @ 2100</i> <u>7.5</u>	4.5 - 9.5
Conductivity	<u>22</u>	<10 $\mu$ mho
Boron	<u>306</u>	PPM

1. Limit at tank to insure not exceeding limit of 6 - 9 pH at plant discharge.
2. Must be <10  $\mu$ mho to consider water with a pH less than 6 or greater than 9. If conductivity is >10  $\mu$ mhos, release must be approved by Chemistry Supervisor or his designee with a written evaluation attached to release form.
3. 0.7 PPM at final discharge. DF based on Boron is  $\frac{\text{Result (in PPM)}}{0.7 \text{ PPM}}$

VOLUME IN TANK 75% 5 370 2167  
 ACTUAL VOLUME RELEASED

DATE & TIME OF ANALYSIS  
 ALPHA  
 BETA

SAMPLE COLLECTED BY KB  
 DATE 5/23/79 TIME 1500

WOL-T-11A   
 WOL-T-11B   
 WOL-T-12   
 OTHER

RAD ANAL. Ref. W. 59  
 APPROVED BY: [Signature]  
 GAMMA 5/23/79 01030  
 TRITIUM 5/23/79 01400  
 Composite Sample Collected By: KB

COUNT METHOD (Procedure Number)	VOLUME OF SAMPLE USED (ml)	SAMPLE COUNT TIME (MIN)	GROSS COUNTS	NET COUNT TIME (MIN)	DKG COUNTS	SAMPLE RATE (cpm)	% ERROR	GAMMA ABUN. DANCE O KEY	SPECIFIC ACTIVITY $\mu\text{Ci/ml}$	MPC 100 $\mu\text{Ci/ml}$	SPECIFIC ACTIVITY MPC 100	EST QTY TO BE RELEASED CURIES	AC O NET CUR.
GROSS								N.A.					
GROSS								N.A.					
H-3								N.A.					
C-14								0.000320	8.95E-2	3.5	2993.3		
Mn-54								1.00E-035	6.52E-2	3.5	0.3	1.96 E-4	
Co-56								.90E-010	1.637E-6	1E-6	1.6	4.60 E-5	
Cu-60								1.00E-1332	3.053E-5	9.7	33.9	8.74 E-4	
Zn-65								.47E-1115	1.033 E-5	3E-7	34.4	2.92 E-4	
Cs-134								.90E-005	1.009 E-5	9E-8	112	2.89 E-4	
Gs-137								.85E-062	1.594 E-5	2E-7	79.7	4.57 E-4	
I-131								.82E-064	4.56 E-6	3E-9	1520	1.31 E-4	
Ba-140								.51E-037	6.333 E-6	2E-7	41.7	2.39 E-4	
Ta-140								.90E-1596	2.321 E-5	2E-7	116	6.65 E-4	
Xe-133								.37E-021		3E-8			
Xe-135								.91E-250		3E-8			
Ag-110m									1.12 E-5	3E-7	37.3	3.21 E-4	
Nb-95									5.776 E-6	1E-6	5.8	1.65 E-4	
Zr-95									1.195 E-6	6E-7	2	3.42 E-5	

4978  
 3.71  
 273 E-3

FOR WOL-T-12: IF GROSS  $\beta$  SPECIFIC ACTIVITY IS  $> 10^{-4}$  CURIES PER LITER, A REMOVAL CANNOT BE DETERMINED AND THE SAMPLE PROCESSED THROUGH THE WOL-T-12.

NAME OF  
SHIFT SUPERVISOR  
CONTACTED

- 35) CONTACT SHIFT SUPERVISOR FOR FOLLOWING DATA Crowe
- a) PRESENT MDCT FLOW 39,000 gpm.
  - b) MAX MDCT FLOW WHICH CAN BE MADE AVAILABLE 39,000 gpm.
  - c) TIME AVAILABLE FOR RELEASE 1200 min (200 to 1200 min)
  - d) MDCT Flow to use for CALCULATIONS 38,000 gpm (must be >5000; <33000)

36) MINIMUM MDCT = FR-146 ALARM SETPOINT = (0.9) (MDCT Flow From 35c) = 34,200

37) Deleted

38) Deleted

39) REVISED CALCULATIONS FOR MPC/10:  
 (D.F. FROM 23) 4978 / 10 = 497.8  
 D.F. FROM 34 1084  
 D.F. FROM 26 523

1084  
1075  
MAXIMUM = 1084  
M

40) MAX. RR = (MIN MDCT 34,200) (36) 1084 = 31.57  
 (REQUIRED D.F. FROM 39) 651 } = 52.03 = R.R. GO TO 31

41) RR MAX. = 30 GPM (5.55 to 30 GPM) = FR-64 Alarm Setpoint

42) RR Actual = (0.9) (RR MAX) = 27 GPM (5 to 27 GPM)

43) If RR Actual is based on MPC/10, Liquid Waste can be released at a rate greater than or equal to 5 GPM, but less than 42. Use this range of rates in 47.

44) Estimated time of dump = (Est. Vol. to be dumped from 3) 7568 gal / (27 GPM-RR-Actual) (42) = 280.3

45) Estimated Reading of RM-L6 13202 CPM (From 32) + 800 CPM (Background) = 14002 CPM

46) Estimated Reading of RM-L7 14002 CPM (Est. Reading of RM-L6) + 400 CPM (RM-L7) = 421.5  
 (Required D.F. From 39) 651

800  
400 18.0



(28) Isotopes Identified by Analysis (Exclude H-3)	(29) Specific Activity (From 19) $\mu\text{Ci/ml}$	(30) Sensitivity of RM-L6 to Each Isotope (From Table 1621-1)	(31) Monitor Response (CPM)
Cu-51	$6.828E-6$	$1.18E7$	81
Mn-54	$1.637E-6$	$8.8E7$	144
Co-58	$3.053E-5$	$1.17E8$	3572
Co-60	$1.033E-5$	$1.72E8$	1777
Cy-134	$1.009E-5$	$1.99E8$	2008
Cy-137	$1.594E-5$	$7.74E7$	1234
I-131	$4.56E-6$	$1.06E8$	483
Ba-140	$8.333E-6$	$7.7E7$	642
La-140	$2.321E-5$	$7.7E7$	1787
As-110m	$1.12E-5$	$7.7E7$	862
NB-95	$5.776E-6$	$8.8E7$	508
Zr-95	$1.195E-6$	$8.72E7$	104

(32)  $\Sigma = 13102$   
Estimated Reading of RM-L6 above background

(33) RM-L6 Setpoints

A. Background Limitations

1. If either the estimated monitor response or Bkg < 3600 cpm, go to (33) B.
2. If RML-6 Bkg > 3600 cpm, and 3600 cpm < Bkg < 27,000 cpm, calculate "e" in A4.
3. If Bkg > 27,000 cpm, Decon RML-6 liner and return to (33) A.
4. 
$$e = 3 \times \frac{\sqrt{(\text{Monitor Response } 13102) + (2 \times (\text{Bkg } 800))}}{(\text{Monitor Response } 13102)} = 0.03$$

NOTE: If e > 0.2, flush and/or decon RML-6 liner and return to (33) A. If e < 0.2 go to (33) B.

B. High Alarm Setpoint

$$2 \times ((\text{Monitor Response } 13102) + (\text{Bkg } 800)) = 27202$$

C. Alert Setpoint

$$\frac{(\text{High Alarm } 27202)}{2} = 13,601$$

(34) Dilution Factor Based on RML-6

$$D.F. = \frac{(\text{RML-6 High Alarm } 14002)}{21.5 \text{ cpm}} = 651$$

6/8/79

1900

RESTRICTIONS: TANK ISOLATED & "DO NOT OPERATE"

6/8/79  
1835

WDT 12 LABORATORY

TANK LEVEL 11.8

VOLUME 750

SIGNED: *[Signature]*

9.6 870 min  
14.5 HR

Minimum Estimated Time for Release

ESTIMATED CURVES TO BE DUMPED  $5.22 \times 40 = 208.8$  % OF QUARTERLY LIMIT  
CURVES DUMPED TO DATE THIS QTR.  $4.7 \times 40 = 188$  % OF QUARTERLY LIMIT  
TOTAL  $5.22 \times 40 = 208.8$  % OF QUARTERLY LIMIT

RELEASE RECOMMENDED BY: *[Signature]* RADIATION PROTECTION SUPERVISOR  
RELEASE APPROVED BY: *[Signature]* SUP OF RAD PROT & CHEM WASTE DEPARTMENT  
SHIFT SUPERVISOR

EX-54 ALARM POINT AT 9.6  
WARNING SIGN POSITION ON 0 TC  
EX-1-1000 SETPOINT AT 34,200  
TANK 1-1000 DUMPED TO 8.7 GPM RELEASE RATE ON 0 TC

TIME RELEASE STOPPED 0330 6/10/79 Tank Level at Start of Release 11.8 7568  
TIME RELEASE STARTED 1215 06/09/79 Tank Level at End of Release 1.5 930  
Tank Volume Released 11.3 6638  
TOTAL TIME OF RELEASE 915 MINUTES  
MOCT EFFLUENT TOTALIZER 804234  
MOCT EFFLUENT TOTALIZER 803888  
TOTAL DILUT 804234  
346<sup>NS</sup>

FLOW AND RADIATION MONITORING RECORDER CHARTS MARKED:  
FH-10 ON GO Check Sat. Before Rel.   
IGI-10 Alarm Returned 10: HI-Alarm = 3600 CPN   
INSTRUMENT READINGS: Alarm Alarm = 1000 CPN   
AT BEGINNING OF RELEASE   
AT END OF RELEASE   
FH-10 FLOW

	EXPECTED READING	READING AT START	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	
FH-10	8.7	6.5	6.5	6.5	6.5	
IGI-10	38,193	15,000	29,050	32,000	35,000	30,000
FH-100	46,000	38,000	38,500	38,000	38,000	38,000
FH-107	161	125	170	170	150	175
		11.8	8.9	6.0	3.1	0.5

IF CHANGES IN FLOW FROM THE MOCT, OR CHANGES IN THE RELEASE RATE (VOLUME) OCCUR DURING THE RELEASE, CALCULATION OF A NEW RATE AND SETPOINT MUST BE MADE. CALCULATIONS WILL BE COMPUTED ON FACE 2 OF THIS FORM AND THE FOLLOWING TABLE:

START TIME	STOP TIME	TOTAL TIME	ACTUAL RELEASE RATE	FR. 101 SET POINT	FR. 102 SET POINT

\*RELEASE RATE CANNOT BE LESS THAN 5 GPM. MINIMUM FLOW RATE IS 3.0 GPM.

RELEASE DATA COMPLETED BY: *[Signature]* INITIALS

ALL DATA REQUIRED ON THIS FORM HAS BEEN COMPLETED. *[Signature]*



SOIL - WATERION CALCULATIONS

OR, UNEXPECTED CHANGE IN SOIL pH TO 10.0. CORRECTIVE ACTION MUST BE TAKEN IMMEDIATELY. CALCULATIONS MUST BE RE-COMPUTED BY THE SHIFT SUPERVISOR. THIS IS TO BE DONE IF THE MFC FLOW IS REDUCED.

1. MAXIMUM RELEASE RATE = (PH-04 SETPOINT)

$MR = MFC \times \frac{NEW MFC FLOW (GPM)}{ORIGINAL MFC}$

2. ACTUAL RELEASE RATE = (MR MAX) x (0.9) =

3. NEW MFC FLOW FROM MFC (14-140 SETPOINT) = NEW MFC FLOW x (0.9) =

NOTE: IS ANY OTHER CALCULATIONS:

2. LABORATORY ANALYSIS

Sample Obtained by: DOE Analysis Performed by: same  
Date/Time: 6-27-77 / 0040 Date/Time: 6-27-77 / 11:27 AM

Dilution Factor Required Based on Boron (From Note 1)

	RESULT	UNIT
	<u>5.57</u> <sup>6.27 at 1125</sup> <sub>RE</sub>	<u>6.5 - 9</u>
	<u>4.0</u>	
	<u>.25</u>	

1. Limit at tank to insure not exceeding limit of 6 - 9 ph at plant discharge

2. Must be 14 ppm to consider water with a pH less than 6 or treated water conductivity is 200 ppm, release must be approved by Chemistry Lab. This is done with a written evaluation attached to release form.

3. 0.7 mg/l at final discharge. If based on Boron is  $\frac{Result (6.5 - 9)}{3.7 mg/l}$



NAME OF SHEET SUPERVISOR CONTACTED

35. CONTACT SHEET SUPERVISOR FOR DATA HITZ
- a) PRESENT MOIST FLOW 46,000 GPM
  - b) MAX MOIST FLOW WHICH CAN BE RELEASED 46,000 GPM
  - c) TIME AVAILABLE FOR RELEASE 1200 MIN (1000 to 1200 min)
  - d) MOIST FLOW TO USE FOR CALCULATIONS 35,000 GPM (must be >5000; <38000)

36. MINIMUM MOIST = FR-140 ALARM SETPOINT = (0.9, (MOIST Flow From 35c)) = 32,200

37. Deleted

38. Deleted

39. USE CALCULATIONS FOR MPC/10:  
 $\frac{32,200}{10} = 3,220$   
 D.F. FROM 31 = 3,553 MAXIMUM = 3,553  
 D.F. FROM 30 = 36

40. MAX. RR = (MIN MOIST 30,200) 30  
 (REQUIRED D.F. FROM 39 3,553) = 9.6 = R.R.

41. RR MAX = 9.6 GPM (5.55 to 30 GPM) = FR-84 Alarm Setpoint  
 RR MIN = (0.9) (RR MAX) = 8.7 GPM (5 to 27 GPM)

42. If RR actual is based on MPC/10, Liquid Waste can be released at a rate greater than or equal to 5 GPM, but less than 42. Use this range of rates in 47.

43. Estimated time of dump = (Est. Vol. to be dumped from 3 7568 gal) = 870  
 (8.7 GPM-RR-Actual) 42 14.5HR

44. Estimated Reading of RM-L6  
13,193 CPM (From 32) + 25000 CPM (Background) = 38,193

45. Estimated Reading of RM-L7  
38,193 CPM (Est. Reading of RM-L6) + 150 CPM (MPC/7) = 38,343  
 (Required D.F. From 39) 3,553

Isotopes Identified by Analysis (Exclud. 4-3)	Specific Activity (From 19) $\mu\text{Ci/ml}$	Sensitivity of RML-6 to Each Isotope (From Table 101-1)	Monitor Response (CPM)
MN-54	$2.51E-6$	$8.8 \times 10^7$	221
CO-58	$1.24E-5$	$1.17 \times 10^8$	1451
CO-60	$1.64E-5$	$1.72 \times 10^8$	2821
CS-134	$9.48E-6$	$1.99 \times 10^8$	1886
CS-137	$1.71E-5$	$7.74 \times 10^7$	1323
I-131	$9.36E-7$	$1.06 \times 10^8$	99
IR-140	$7.06E-6$	$7.7 \times 10^7$	543
LA-140	$2.63E-5$	$7.7 \times 10^7$	2025
AG-110	$3.10E-6$	$1.7 \times 10^7$	239
NB-95	$3.48E-6$	$8.8 \times 10^7$	306
KE-131m	$2.96E-5$	$1.7 \times 10^7$	2279

$\Sigma = 13,193$   
Estimated Reading of RML-6 above background

(23) Final Setpoints

A. Background Limitations

1.  either the estimated monitor response or Bkg < 3600 cpm, go to B.
2. If RML-6 Bkg > 3600 cpm, and  $3600 \text{ cpm} \times \text{Sk} < 27,000$  ... go to "e" in A4.
3. If Bkg > 27,000 cpm, Decan RML-6 liner and return to A.
4.  $e = 3 \times \frac{\sqrt{(\text{Monitor Response } 13,193) + 2 \times (\text{Bkg } 25000)}}{(\text{Monitor Response } 13,193)} = 1.0572$

NOTE: If  $e > 0.2$ , flush and/or decan RML-6 liner and re-  
(33) A. If  $e < 0.2$  go to (33) 3.

b. High Alarm Setpoint

$2 \times ((\text{Monitor Response } 13,193) + (\text{Bkg } 25000)) = 76,386$

c. Alert Setpoint

$\frac{(\text{High Alarm } 76,386)}{2} = 38,193$

(32) Dilution Factor Based on RML-6

D.F. =  $\frac{(\text{RML-6 High Alarm } 76,386)}{21.5 \text{ cpm}} = 3553$

6-8-79 2350 76-79-L  
 K Bryan Cytko RSP  
 X A 115 T...  
 TANK 10<sup>1</sup> VOLUME LSI  
 2245

5413 447

3400'S .0467  
 11257 31277

85 79-1  
 RELEASE RECOMMENDED BY [Signature]  
 RELEASE RECOMMENDED BY [Signature]  
 RELEASE APPROVED BY [Signature]

50270 23350  
 1449  
 2422  
 413

TIME RELEASE STOPPED 0125 6/11/79 Tank Level at Start of Release 10.5" 66286  
 TIME RELEASE STARTED 1641 6/10/79 Tank Level at End of Release .5" 430.0  
 TOTAL TIME OF RELEASE 524 MINUTES Tank Volume Released 9.8" 5798.8  
 MOET EFFLUENT TOTALIZER 804777  
 MOET EFFLUENT TOTALIZER 804566  
 TOTAL EFFLUENT 211

INSTRUMENT READINGS: AT BEGINNING 10.5  
 AT END OF 10.5  
 AT BEGINNING 10.5  
 AT END OF 10.5

	EXPECTED	READING AT START	READING AFTER COMPLETE	READING AFTER COMPLETE		
FR 31	413	10.5	11	10.5	10	
FR 32	25555	28,000	34,000	40,000	41 K	45 K
FR 33	38000	40,000	40,000	40,000	39 K	38 K
FR 34	161	2.00	1.20	2.00	1.20	1.00
		10.2"	7.2	4.8	2.4	1.5

INFLOW FOR THE MOET OR CHANGES IN THE RELEASE RATE  
 CALCULATION OF A RATE AND SETPOINTS MUST  
 BE MADE ON THE FACE 2 OF THE FORM AND THE FOLLOWING TABLE

START TIME	STOP TIME	TOTAL TIME	FACTUAL RELEASE RATE	SET POINT

RELEASE BEGAN WHEN THE MOET OR CHANGES IN THE RELEASE RATE

RELEASE COMPLETED BY [Signature] INITIALS  
 ALL DATA REQUIRED ON THIS FORM HAS BEEN COMPLETED. [Signature]



GENERAL OPERATION CALCULATIONS

DATE: 6-29-79

FOR THE RELEASES CHARGED TO THE MOIST FLOW OR ACTUAL FLOW RATE THE FOLLOWING CALCULATIONS MUST BE RE-COMPLETED BY THE SHIFT SUPERVISOR. THIS MAY ONLY BE DONE IF THE MOIST FLOW IS RECORDED.

1. MAXIMUM RELEASE RATE = (FR-39 SET POINT) = \_\_\_\_\_  
 $RR = MFR = \frac{NEW\ MOIST\ FLOW\ RATE \times (0.3)}{RECORDED\ D.F.} = \frac{\quad}{\quad} \text{ GPM}$
2. ACTUAL RELEASE RATE = (RR MFR)  $\times$  (0.3) = \_\_\_\_\_ GPM
3. ACTUAL FLOW FROM MOIST (FR-116 SETPOINT) = NEW MOIST FLOW  $\times$  (0.3) = \_\_\_\_\_ GPM

USE THIS AREA FOR CALCULATIONS:

ANALYSIS PARAMETERS

26. Sample Obtained by: JWC Analysis Performed by: DWE  
 Date/Time: 6-29-79 / 0015 Date/Time: 6-29-79 / 11-7 shift  
 Dilution Factor Required Based on Boron (From Note 3): 36

	RESULT	LIMIT
pH	5.61	6.5 - 9.5
Conductivity	3.7	5 - 10
Boron	25	DF

1. Limit at tank to insure not exceeding limit of 6 - 9 pH at plant discharge
2. Must be <10 umhos to consider water with a pH less than 6 or conductivity less than 10 umhos, release must be approved by Chemistry Supervisor. Release must be with a written evaluation attached to release form.
3. 0.7 ppm at final discharge. DF based on Boron is  $\frac{\text{Result (ppm)}}{0.7 \text{ ppm}}$





NAME OF SUPERVISOR: J. Cross  
NO. LISTED: 38  
2800  
150

35 CONTACT SHIFT SUPERVISOR FOR FOLLOWING DATA:  
a) PRESENT MDC FLOW: 38000 GPM.  
b) MAX MDC FLOW WHICH CAN BE MADE AVAILABLE: 38000 GPM.  
c) TIME AVAILABLE FOR RELEASE: 1200 MIN. (1200 MIN)  
d) MDC Flow to use for CALCULATIONS: 38000 GPM. (Must be > 3000; < 40000)

36 MINIMUM MDC = FR-146 ALARM SETPOINT = (0.9) (MDC Flow from 300)  
34200

37 Deleted

38 Deleted

39 REVISED CALCULATIONS FOR MPC/10:  
D.F. FROM 35 = 61.1  
D.F. FROM 34 = 2359  
D.F. FROM 25 = 36

40 MAX. RR = (MIN MDC 34200) 30  
(REQUIRED D.F. FROM 39 2359) = 14.49

41 RR MAX = 14.49 GPM (0.55 to 36 GPM) = 14.49

42 RR Actual = (0.9) (RR MAX) = 13 GPM (0 to 27 GPM)

43 If RR Actual is based on MPC/10, Liquid waste can be released at a rate greater than or equal to 5 GPM, but less than 42. Use this range of rates in 47.

44 Estimated time of dump = (Est. Vol. to be dumped from 30, 6511 gal.)  
(13 GPM-RR-Actual) = 501

45 Est. Reading of RM-L6  
25355 CPM (From 32) + 17000 CPM (Background) = 25355

46 Estimated Reading of RM-L7  
(25355 CPM (Est. Reading of RM-L6)) + 150 CPM (RM-L7) = 161  
(Required D.F. From 39) = 2359

(28) Isotopes Identified by Analysis (exclude H-3)	(29) Specific Activity (From 19) $\mu\text{Ci/ml}$	(30) Sensitivity of RML-6 to Each Isotope (From Table 821-1)	(31) $\mu\text{Ci/ml}$ (CPM)
CO-58	$3.24 \times 10^{-6}$	$1.17 \times 10^8$	379
CO-60	$1.55 \times 10^{-6}$	$1.73 \times 10^8$	267
MA-95	$2.35 \times 10^{-6}$	$3.8 \times 10^7$	253
RU-103	$1.39 \times 10^{-5}$	$2.7 \times 10^7$	1020
CS-134	$3.96 \times 10^{-6}$	$1.94 \times 10^8$	755
CS-137	$1.034 \times 10^{-5}$	$2.24 \times 10^7$	350
LA-140	$5.15 \times 10^{-5}$	$7.7 \times 10^7$	3456
GA-140	$1.08 \times 10^{-5}$	$7.7 \times 10^7$	332

(32) Estimated Reading = 8355  
above background

(33) RML-6 Setpoints

A. Background Limitations

1. If either the estimated monitor response or Bkg  $> 3600$  cpm, (33) b.
2. If RML-6 Bkg  $> 3600$  cpm, and  $3600 \text{ cpm} < \text{Bkg} < 27,000$  cpm, calculate "e" in A4.
3. If Bkg  $> 27,000$  cpm, Decon RML-6 liner and return to 1.
4.  $e = 3 \times \frac{\text{Monitor Response } (8355) + \text{Bkg } (17000)}{\text{Monitor Response } (8355)}$  0.734

NOTE: If  $e > 0.2$ , flush and/or decon RML-6 liner and return to 1.  
(33) A. If  $e \leq 0.2$  go to (33) 2.

B. High Alarm Setpoint

$2 \times i \text{ (Monitor Response } 8355) + (\text{Bkg } 17000) ; i = 5270$

C. Alert Setpoint

$\frac{\text{(High Alarm } 5270)}{2} = 2635$

(34) Dilution Factor Based on RML-6

D.F. =  $\frac{\text{(RML-6 High Alarm } 5270)}{21.5 \text{ cpm}} = 245$

LIQUID RELEASE PERMIT  
HPP 1021

RELEASE NUMBER

112-79 L

DATE 7-25-79 TIME 0055 REQUESTOR D. PUSTE/TELE R/P/ SHIFT SUPERVISOR

WDL-T-11A TANK A  
WDL-T-11B TANK B  
WDL-T-12 LAUNDRY  
Other  
TANK ISOLATED & "DO NOT OPERATE" Tagged DATE 7-25-79  
TANK LEVEL 11.5 ft. VOLUME 7390 gal.  
SIGNED [Signature]

ESTIMATED GPM FR MAX (5-30 gpm) 499.2 - 697 minimum Estimated time for RELEASE

ESTIMATED CURIES TO BE DUMPED 3.48E-3 x 40 = 0.1392 % OF QUARTERLY LIMIT  
CURIES DUMPED TO DATE THIS QTR. [ ] x 40 = 1.2625 % OF QUARTERLY LIMIT  
111-79 L LAST RELEASE = INCLUDED TOTAL 1.2025 % OF QUARTERLY LIMIT

RELEASE RECOMMENDED BY [Signature] RADIATION PROTECTION SUP/Foreman  
RELEASE RECOMMENDED BY [Signature] SUP OF RAD PROT & CHEM/UNIT SUPERINTENDENT  
RELEASE APPROVED BY L. Noll SHIFT SUPERVISOR

RELEASE DATA:  
RII-L6 Setpoint Hi Alarm 62270 CPM: Alert 31135 CPM: [ ] Initials PR  
FR-84 ALARM SET POINT AT 19,200 CPM: [ ] INITIALS  
WARNING SIGN ("CAUTION UNIT 1 LEAKING LIQUID RELEASE") HUNG ON WDL-89 KEY SWITCH  
IN UNIT 11 AUX. BLDG. [ ] INITIALS  
FR-146 ALARM SETPOINT AT 34,200 GPM: [ ] INITIALS  
WDL-V124 VALVE WDL-V125 LOADED TO 17.3 GPM RELEASE RATE [ ] INITIALS

TIME RELEASE STOPPED 1505 7/26/79 Tank Level at Start of Release 11.5' ft. 7390  
TIME RELEASE STARTED 8042 7/26/79 Tank Level at End of Release 4.7' ft. 3397  
TOTAL TIME OF RELEASE 590 MINUTES Tank Volume Released 6.8' ft. 3993  
MDCT EFFLUENT TOTALIZER AT STOP 831383  
MDCT EFFLUENT TOTALIZER AT START 531383  
TOTAL DILUTION FLOW 186 GALL.

FLOW AND RADIATION MONITORING RECORDER CHARTS MARKED:  
PH-L6 Source Check Sat. Before Rel. [ ] AT BEGINNING OF RELEASE [ ]  
RII-L6 Alarm Returned to: Hi-Alarm = 3600 CPM [ ] AT END OF RELEASE [ ]  
INSTRUMENT READINGS: Alert Alarm = 1800 CPM [ ] RII-L6 Flushed [ ]

	EXPECTED READING	READING AT START	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE
FR-84	146 17.3 gpm	10.0	8.7	10.2	Terminated	Terminated	
31135 - RM-L6	27135 gpm	15000	40,000	40,000			
FR-146	38000 gpm	47000	38,000	38,100			
RM-L7	765 gpm	750	800	800			

IF CHANGES IN FLOW FROM THE MDCT ICR CHANGES IN THE RELEASE RATE (V124/V125 position) DEVELOP DURING THE RELEASE, CALCULATION OF A NEW RATE AND SETPOINTS MUST BE MADE. THE NEW CALCULATIONS WILL BE COMPUTED ON PAGE 2 OF THIS FORM AND THE FOLLOWING TABLE WILL BE COMPLETED

	START TIME	STOP TIME	TOTAL TIME	*ACTUAL RELEASE RATE	FR-84 SET POINT	FR-146 SET POINT	APPROVAL BY SHIFT SUPV.
ORIGINAL	0655	1505	490 min	9.6 gpm	10.6	34,200	
1st CHANGE							
2nd CHANGE							

\*RELEASE RATE CANNOT BE LESS THAN 5 GPM. MDCT CANNOT BE < 5000 or > 25000 gpm.

RELEASE DATA COMPLETED BY [Signature] INITIALS.  
ALL DATA REQUIRED ON THIS FORM HAS BEEN COMPLETED. [Signature]

SPECIAL OPERATION CALCULATIONS

FOR UNEXPECTED CHANGES IN THE MDCT FLOW OR ACTUAL RELEASE RATE THE FOLLOWING CALCULATIONS MUST BE RE-COMPUTED BY THE SHIFT SUPERVISOR. THIS NEED ONLY BE DONE IF THE MDCT FLOW IS REDUCED.

1. MAXIMUM RELEASE RATE = (FR-84 SETPOINT)

$$RR - MAX = \frac{NEW MDCT FLOW GPM \times (0.9)}{REQUIRED D.F.} = \boxed{\phantom{000}} \text{ GPM}$$

2. ACTUAL RELEASE RATE + (RR MAX) x (0.9) =  $\boxed{\phantom{000}}$  GPM

3. MINIMUM FLOW FROM MDCT (FR-146 SETPOINT) = NEW MDCT FLOW x (0.9) =  $\boxed{\phantom{000}}$  GPM

USE THIS AREA FOR CALCULATIONS:

25 CHEMISTRY PARAMETERS

26 Sample Obtained By: KB Analysis Performed By: KB  
 Date/Time: 7/25/79 @ 0525 Date/Time: 7/25/79 @ 0530

Dilution Factor Required Based on Boron (From Note 3)  $\boxed{524}$

	RESULT	LIMIT	
pH	6.00	4.5 - 9.5	(1)
Conductivity	2.8	<10 $\mu$ mho	(2)
Boron	367	PPM	(3)

- Limit at tank to insure not exceeding limit of 6 - 9 pH at plant discharge.
- Must be <10  $\mu$ mho to consider water with a pH less than 6 or greater than 9. If conductivity is >10  $\mu$ mhos, release must be approved by Chemistry Supervisor or his designee with a written evaluation attached to release form.
- 0.7 PPM at final discharge. DF based on Boron is  $\frac{\text{Result (in PPM)}}{0.7 \text{ PPM}} = \frac{524}{0.7}$







NAME OF  
SHIFT SUPERVISOR  
CONTACTED

- 35 CONTACT SHIFT SUPERVISOR FOR FOLLOWING DATA A. W. WILSON
- a) PRESENT MDCT FLOW 4200 gpm.
- b) MAX MDCT FLOW WHICH CAN BE MADE AVAILABLE 42000 gpm.
- c) TIME AVAILABLE FOR RELEASE 1200 min (200 to 1200 min)
- d) MDCT Flow to use for CALCULATIONS 38,000 gpm (must be >5000; <38000)

36 MINIMUM MDCT = FR-146 ALARM SETPOINT = (0.9) (MDCT Flow From 35d) = 34,200

37 Deleted

38 Deleted

39 REVISED CALCULATIONS FOR MPC/10:

(D.F. FROM 23) 856.9 / 10 = 85.69

D.F. FROM 34) 1780 <sup>MC</sup> 2896

D.F. FROM 26) 524

MAXIMUM = 2896 <sup>MC</sup> / 1780 <sup>MC</sup>

40 MAX. RR = (MIN MDCT 34,200) / (REQUIRED D.F. FROM 39) 1780 <sup>MC</sup> 2896 = 11.8 / 19.2 <sup>MC</sup> = R.R. MAX GO TO 41

41 RR MAX. = 11.8 GPM (5.55 to 30 GPM) = FR-34 Alarm Setpoint

42 RR Actual = (0.9) (RR MAX) = 10.6 GPM (5 to 27 GPM)

43 If RR Actual is based on MPC/10, Liquid Waste can be released at a rate greater than or equal to 5 GPM, but less than 42. Use this range of rates in 47.

44 Estimated time of dump = (Est. Vol. to be dumped from 3) 7370 gal / (17.3 <sup>MC</sup> GPM - RR-Actual) / 10.6 = 697 / 17.3 <sup>MC</sup> = 40.3 min

45 Estimated Reading of RM-L6 11135 CPM (From 32) + 16,000 / 20,000 CPM (Background) = 31135 CPM

46 Estimated Reading of RM-L7 31135 CPM (Est. Reading of RM-L6) + 700 / 950 <sup>MC</sup> CPM (RM-L7) = 711 / 765 <sup>MC</sup> CPM

(Required D.F. From 39) 1780 <sup>MC</sup> 2896

		RM-10	RSP
	1.88E-5	7.7E7	1447.6
140	3.88E-5	7.7E7	2987.6
85	9.36E-7	8.72E7	81.6
Nb-95	5.92E-6	8.8E7	521
Zr-97	3.67E-7	8.19E7	30.1
Ru-103	8.14E-6	7.7E7	628.3
Ni-110m	5.46E-6	7.7E7	420.4
Ce-141	1.08E-6	7.7E7	83.2
Ce-144	1.07E-5	7.7E7	823.9
			<u>11135.43</u>



SPECIAL OPERATION CALCULATIONS

IF THERE IS CHANGE IN THE MDCT FLOW OR ACTUAL RELEASE RATE THE FOLLOWING CALCULATIONS MUST BE RE-COMPUTED BY THE SHIFT SUPERVISOR. THIS NEED ONLY BE DONE IF MDCT FLOW IS REDUCED.

1. MINIMUM RELEASE RATE + (FR-84 SETPOINT)

$RR - MIN = \frac{\text{NEW MDCT FLOW GPM} \times (0.9)}{\text{REQUIRED D.F.}} = \underline{\hspace{2cm}} \text{ GPM}$

2. ACTUAL RELEASE RATE + (RR MAX) x (0.9) =  $\underline{\hspace{2cm}}$  GPM

3. MINIMUM FLOW FROM MDCT (FR-146 SETPOINT) = NEW MDCT FLOW x (0.9) =  $\underline{\hspace{2cm}}$  GPM

USE THIS AREA FOR CALCULATIONS:

25 CHEMISTRY PARAMETERS

26 Sample Obtained by: E.E. Analysis Performed by: E.E.  
 Date/Time: 7/31/79 1105 Date/Time: 7/31/79 1115

Diffusion Factor Required Based on Boron (From Note 3): 251

	RESULT	LIMIT
pH	6.42	6.5 - 9.5
Conductivity	35	<10 umho
Boron	176	PPM

1. Limit at tank to insure not exceeding limit of 6 - 9 pH at plant discharge.
2. Must be <10 umho to consider water with a pH less than 6 or greater than 9. If conductivity is >10 umhos, release must be approved by Chemistry Supervisor or his designee with a written evaluation attached to release form.
3. 0.7 PPM at final discharge. DF based on Boron is  $\frac{\text{Result (in PPM)}}{0.7 \text{ PPM}}$

16.0

WOL-T-112  
 WOL-T-113  
 WOL-T-117  
 OTHER

SAMPLE COLLECTED BY: EE  
 DATE: 7/25/72 TIME: 1105  
 REP. ANAL. BY: KB  
 APPROVED BY:

COURT REPORTED BY: TA Calk  
 VOLUME OF SAMPLE USED (cc): 10  
 SAMPLE COUNT TIME (MIN): 10

ANALYSIS DATE: 7/31/72  
 ANALYSIS TIME: 7/29/72

VOL. TIME: 7569  
 ACTUAL VOLUME RELEASED:

Composite Sample Collected by: E. E. Spawler

GAMMA SOURCE RANGE	SPECIFIC ACTIVITY (dpm/cc)	SAMPLE COUNT RATE (cpm)	BKG. COUNT RATE (cpm)	BKG. COUNTY TIME (min)	CROSS COUNTS	SAMPLE COUNT TIME (min)	VOLUME OF SAMPLE USED (cc)	COURT REPORTED BY
1.00-1330	2.492E-6	2471 E-6	2389 E-7	11.6	94.7	11.6	10	TA Calk
1.331-1.662	7.276 E-6	1.59 E-7	5.59 E-6	21.7	21.7	21.7	10	TA Calk
1.663-2.004	1.968 E-5	1.968 E-5	1.508 E-7	31.8	31.8	31.8	10	TA Calk
2.005-2.346	3.697 E-6	3.697 E-6	3.697 E-6	41.9	41.9	41.9	10	TA Calk
2.347-2.688	1.508 E-7	1.508 E-7	1.508 E-7	52.0	52.0	52.0	10	TA Calk
2.689-3.030	2.471 E-6	2.471 E-6	2.471 E-6	62.1	62.1	62.1	10	TA Calk
3.031-3.372	2.492 E-6	2.492 E-6	2.492 E-6	72.2	72.2	72.2	10	TA Calk
3.373-3.714	7.276 E-6	7.276 E-6	7.276 E-6	82.3	82.3	82.3	10	TA Calk
3.715-4.056	1.968 E-5	1.968 E-5	1.968 E-5	92.4	92.4	92.4	10	TA Calk
4.057-4.398	3.697 E-6	3.697 E-6	3.697 E-6	102.5	102.5	102.5	10	TA Calk
4.399-4.740	1.508 E-7	1.508 E-7	1.508 E-7	112.6	112.6	112.6	10	TA Calk
4.741-5.082	2.471 E-6	2.471 E-6	2.471 E-6	122.7	122.7	122.7	10	TA Calk
5.083-5.424	2.492 E-6	2.492 E-6	2.492 E-6	132.8	132.8	132.8	10	TA Calk
5.425-5.766	7.276 E-6	7.276 E-6	7.276 E-6	142.9	142.9	142.9	10	TA Calk
5.767-6.108	1.968 E-5	1.968 E-5	1.968 E-5	153.0	153.0	153.0	10	TA Calk
6.109-6.450	3.697 E-6	3.697 E-6	3.697 E-6	163.1	163.1	163.1	10	TA Calk
6.451-6.792	1.508 E-7	1.508 E-7	1.508 E-7	173.2	173.2	173.2	10	TA Calk
6.793-7.134	2.471 E-6	2.471 E-6	2.471 E-6	183.3	183.3	183.3	10	TA Calk
7.135-7.476	2.492 E-6	2.492 E-6	2.492 E-6	193.4	193.4	193.4	10	TA Calk
7.477-7.818	7.276 E-6	7.276 E-6	7.276 E-6	203.5	203.5	203.5	10	TA Calk
7.819-8.160	1.968 E-5	1.968 E-5	1.968 E-5	213.6	213.6	213.6	10	TA Calk
8.161-8.502	3.697 E-6	3.697 E-6	3.697 E-6	223.7	223.7	223.7	10	TA Calk
8.503-8.844	1.508 E-7	1.508 E-7	1.508 E-7	233.8	233.8	233.8	10	TA Calk
8.845-9.186	2.471 E-6	2.471 E-6	2.471 E-6	243.9	243.9	243.9	10	TA Calk
9.187-9.528	2.492 E-6	2.492 E-6	2.492 E-6	254.0	254.0	254.0	10	TA Calk
9.529-9.870	7.276 E-6	7.276 E-6	7.276 E-6	264.1	264.1	264.1	10	TA Calk
9.871-10.212	1.968 E-5	1.968 E-5	1.968 E-5	274.2	274.2	274.2	10	TA Calk
10.213-10.554	3.697 E-6	3.697 E-6	3.697 E-6	284.3	284.3	284.3	10	TA Calk
10.555-10.896	1.508 E-7	1.508 E-7	1.508 E-7	294.4	294.4	294.4	10	TA Calk
10.897-11.238	2.471 E-6	2.471 E-6	2.471 E-6	304.5	304.5	304.5	10	TA Calk
11.239-11.580	2.492 E-6	2.492 E-6	2.492 E-6	314.6	314.6	314.6	10	TA Calk
11.581-11.922	7.276 E-6	7.276 E-6	7.276 E-6	324.7	324.7	324.7	10	TA Calk
11.923-12.264	1.968 E-5	1.968 E-5	1.968 E-5	334.8	334.8	334.8	10	TA Calk
12.265-12.606	3.697 E-6	3.697 E-6	3.697 E-6	344.9	344.9	344.9	10	TA Calk
12.607-12.948	1.508 E-7	1.508 E-7	1.508 E-7	355.0	355.0	355.0	10	TA Calk
12.949-13.289	2.471 E-6	2.471 E-6	2.471 E-6	365.1	365.1	365.1	10	TA Calk
13.291-13.632	2.492 E-6	2.492 E-6	2.492 E-6	375.2	375.2	375.2	10	TA Calk
13.633-13.974	7.276 E-6	7.276 E-6	7.276 E-6	385.3	385.3	385.3	10	TA Calk
13.975-14.316	1.968 E-5	1.968 E-5	1.968 E-5	395.4	395.4	395.4	10	TA Calk
14.317-14.658	3.697 E-6	3.697 E-6	3.697 E-6	405.5	405.5	405.5	10	TA Calk
14.659-15.000	1.508 E-7	1.508 E-7	1.508 E-7	415.6	415.6	415.6	10	TA Calk
15.001-15.342	2.471 E-6	2.471 E-6	2.471 E-6	425.7	425.7	425.7	10	TA Calk
15.343-15.684	2.492 E-6	2.492 E-6	2.492 E-6	435.8	435.8	435.8	10	TA Calk
15.685-16.026	7.276 E-6	7.276 E-6	7.276 E-6	445.9	445.9	445.9	10	TA Calk
16.027-16.368	1.968 E-5	1.968 E-5	1.968 E-5	456.0	456.0	456.0	10	TA Calk
16.369-16.710	3.697 E-6	3.697 E-6	3.697 E-6	466.1	466.1	466.1	10	TA Calk
16.711-17.052	1.508 E-7	1.508 E-7	1.508 E-7	476.2	476.2	476.2	10	TA Calk
17.053-17.394	2.471 E-6	2.471 E-6	2.471 E-6	486.3	486.3	486.3	10	TA Calk
17.395-17.736	2.492 E-6	2.492 E-6	2.492 E-6	496.4	496.4	496.4	10	TA Calk
17.737-18.078	7.276 E-6	7.276 E-6	7.276 E-6	506.5	506.5	506.5	10	TA Calk
18.079-18.420	1.968 E-5	1.968 E-5	1.968 E-5	516.6	516.6	516.6	10	TA Calk
18.421-18.762	3.697 E-6	3.697 E-6	3.697 E-6	526.7	526.7	526.7	10	TA Calk
18.763-19.104	1.508 E-7	1.508 E-7	1.508 E-7	536.8	536.8	536.8	10	TA Calk
19.105-19.446	2.471 E-6	2.471 E-6	2.471 E-6	546.9	546.9	546.9	10	TA Calk
19.447-19.788	2.492 E-6	2.492 E-6	2.492 E-6	557.0	557.0	557.0	10	TA Calk
19.789-20.129	7.276 E-6	7.276 E-6	7.276 E-6	567.1	567.1	567.1	10	TA Calk
20.131-20.472	1.968 E-5	1.968 E-5	1.968 E-5	577.2	577.2	577.2	10	TA Calk
20.473-20.814	3.697 E-6	3.697 E-6	3.697 E-6	587.3	587.3	587.3	10	TA Calk
20.815-21.156	1.508 E-7	1.508 E-7	1.508 E-7	597.4	597.4	597.4	10	TA Calk
21.157-21.498	2.471 E-6	2.471 E-6	2.471 E-6	607.5	607.5	607.5	10	TA Calk
21.499-21.840	2.492 E-6	2.492 E-6	2.492 E-6	617.6	617.6	617.6	10	TA Calk
21.841-22.182	7.276 E-6	7.276 E-6	7.276 E-6	627.7	627.7	627.7	10	TA Calk
22.183-22.524	1.968 E-5	1.968 E-5	1.968 E-5	637.8	637.8	637.8	10	TA Calk
22.525-22.866	3.697 E-6	3.697 E-6	3.697 E-6	647.9	647.9	647.9	10	TA Calk
22.867-23.208	1.508 E-7	1.508 E-7	1.508 E-7	658.0	658.0	658.0	10	TA Calk
23.209-23.550	2.471 E-6	2.471 E-6	2.471 E-6	668.1	668.1	668.1	10	TA Calk
23.551-23.892	2.492 E-6	2.492 E-6	2.492 E-6	678.2	678.2	678.2	10	TA Calk
23.893-24.234	7.276 E-6	7.276 E-6	7.276 E-6	688.3	688.3	688.3	10	TA Calk
24.235-24.576	1.968 E-5	1.968 E-5	1.968 E-5	698.4	698.4	698.4	10	TA Calk
24.577-24.918	3.697 E-6	3.697 E-6	3.697 E-6	708.5	708.5	708.5	10	TA Calk
24.919-25.259	1.508 E-7	1.508 E-7	1.508 E-7	718.6	718.6	718.6	10	TA Calk
25.261-25.602	2.471 E-6	2.471 E-6	2.471 E-6	728.7	728.7	728.7	10	TA Calk
25.603-25.944	2.492 E-6	2.492 E-6	2.492 E-6	738.8	738.8	738.8	10	TA Calk
25.945-26.286	7.276 E-6	7.276 E-6	7.276 E-6	748.9	748.9	748.9	10	TA Calk
26.287-26.628	1.968 E-5	1.968 E-5	1.968 E-5	759.0	759.0	759.0	10	TA Calk
26.629-26.969	3.697 E-6	3.697 E-6	3.697 E-6	769.1	769.1	769.1	10	TA Calk
26.971-27.312	1.508 E-7	1.508 E-7	1.508 E-7	779.2	779.2	779.2	10	TA Calk
27.313-27.654	2.471 E-6	2.471 E-6	2.471 E-6	789.3	789.3	789.3	10	TA Calk
27.655-28.000	2.492 E-6	2.492 E-6	2.492 E-6	799.4	799.4	799.4	10	TA Calk
28.001-28.342	7.276 E-6	7.276 E-6	7.276 E-6	809.5	809.5	809.5	10	TA Calk
28.343-28.684	1.968 E-5	1.968 E-5	1.968 E-5	819.6	819.6	819.6	10	TA Calk
28.685-29.026	3.697 E-6	3.697 E-6	3.697 E-6	829.7	829.7	829.7	10	TA Calk
29.027-29.368	1.508 E-7	1.508 E-7	1.508 E-7	839.8	839.8	839.8	10	TA Calk
29.369-29.710	2.471 E-6	2.471 E-6	2.471 E-6	849.9	849.9	849.9	10	TA Calk
29.711-30.052	2.492 E-6	2.492 E-6	2.492 E-6	860.0	860.0	860.0	10	TA Calk
30.053-30.394	7.276 E-6	7.276 E-6	7.276 E-6	870.1	870.1	870.1	10	TA Calk
30.395-30.736	1.968 E-5	1.968 E-5	1.968 E-5	880.2	880.2	880.2	10	TA Calk
30.737-31.078	3.697 E-6	3.697 E-6	3.697 E-6	890.3	890.3	890.3	10	TA Calk
31.079-31.419	1.508 E-7	1.508 E-7	1.508 E-7	900.4	900.4	900.4	10	TA Calk
31.421-31.762	2.471 E-6	2.471 E-6	2.471 E-6	910.5	910.5	910.5	10	TA Calk
31.763-32.104	2.492 E-6	2.492 E-6	2.492 E-6	920.6	920.6	920.6	10	TA Calk
32.105-32.446	7.276 E-6	7.276 E-6	7.276 E-6	930.7	930.7	930.7	10	TA Calk
32.447-32.788	1.968 E-5	1.968 E-5	1.968 E-5	940.8	940.8	940.8	10	TA Calk
32.789-33.129	3.697 E-6	3.697 E-6	3.697 E-6	950.9	950.9	950.9	10	TA Calk
33.131-33.472	1.508 E-7	1.508 E-7	1.508 E-7	961.0	961.0	961.0	10	TA Calk
33.473-33.814	2.471 E-6	2.471 E-6	2.471 E-6	971.1	971.1	971.1	10	TA Calk
33.815-34.156	2.492 E-6	2.492 E-6	2.492 E-6	981.2	981.2	981.2	10	TA Calk
34.157-34.498	7.276 E-6	7.276 E-6	7.276 E-6	991.3	991.3	991.3	10	TA Calk
34.499-34.839	1.968 E-5	1.968 E-5	1.968 E-5	1001.4	1001.4	1001.4	10	TA Calk
34.841-35.182	3.697 E-6	3.697 E-6	3.697 E-6	1011.5	1011.5	1011.5	10	TA Calk
35.183-35.5								



35 CONTACT SHIFT SUPERVISOR FOR FOLLOWING DATA  
PRESENT MDCT FLOW 40,000 GPM.  
36 MAX MDCT FLOW WHICH CAN BE MADE AVAILABLE 40,000  
37 TIME AVAILABLE FOR RELEASE 280 MIN (200 to 1200 min).  
38 MDCT Flow to use for CALCULATIONS 38,000 GPM (must be 30,000 to 40,000)

39 MIN MDCT = FR-146 ALARM SETPOINT = (0.9) (MDCT Flow Frd 38,000)  
34,200

Gross  $\beta$  D.F.

40 Deleted

41 Deleted D.F. From (100) 468

42 REVISED CALCULATIONS FOR MPC/10:  
D.F. FROM (23) 371 = 37.1

D.F. FROM (34) 704 MAXIMUM = 704

D.F. FROM (26) 251

43 MAX. RR = (MIN MDCT 34,200) (36) = 48 = R.R. MAX. TO TO (41)  
(REQUIRED D.F. FROM (39) 704)

44 RR MAX. = 30 GPM (5.55 to 30 GPM) = FR-84 Alarm Setpoint

45 RR Actual = (0.9) (RR MAX) = 27 GPM (5 to 30 GPM)

46 IF RR Actual is based on MPC/10, Liquid Waste can be released at a rate greater than or equal to 5 GPM, but less than (42). Use this range of rates for (47).

BY 251 SPECIFIC

47 Estimated time of dump = (Est. Vol. to be dumped from (3) 7569 gal.) = 280 MIN  
(27 GPM-RR-Actual) (42)

48 Estimated Reading of RM-L6  
5574 CPM (From (32)) + 2000 CPM (Background) = 7574 CPM

49 Estimated Reading of RM-L7  
(7574 CPM (Est. Reading of RM-L6)) - 200 CPM (RM-L7) = 211 CPM  
(Required D.F. From (39)) 704

134  
130-11



Isotopes Analyzed (Excludes 1-3)	Specific Activity (From 19 to μCi/ml)	Sensitivity of RML-6 to Each Isotope (From Table 1621-1)	Monitor Response (CPM)
Mn-54	2.389 E-7	8.6 E7	21
Co-58	2.471 E-6	1.17 E8	289
Co-60	2.492 E-6	1.72 E8	429
Cs-134	7.276 E-6	1.99 E8	1448
I-131	1.59 E-7	1.06 E8	17
Ba-140	5.859 E-6	7.7 E7	451
La-140	1.156 E-5	7.7 E7	890
Nh-95	1.968 E-5	8.8 E7	1732
Ce-141	1.504 E-7	7.7 E7	12
Ce-144	3.697 E-6	7.7 E7	285

(32) Z = 5574  
Estimated Reading of RML-6  
above background

(31) RML-6 Setpoints

A. Background Limitations

- If either the estimated monitor response  $\geq 3600$  cpm, or  $\geq 3600$  cpm, go to (33) B.
- If RML-6 Bkg  $> 3600$  cpm, and  $3600$  cpm  $< Bkg < 21,000$  cpm, calculate "e" in A4.
- If Bkg  $> 27,000$  cpm, Decon RML-6 liner and return to (31) A.
- $$e = 3 \times \frac{(\text{Monitor Response } 5574) - 2 \times (\text{Bkg } 2000)}{(\text{Monitor Response } 5574)}$$
  $= 15,148$

NOTE: If  $e > 0.2$ , flush and/or decon RML-6 liner and return to (31) A. If  $e \leq 0.2$  go to (33) B.

B. High Alarm Setpoint

$$2 \times ((\text{Monitor Response } 5574) + (\text{Bkg } 2000)) = 15,148$$

C. Alert Setpoint

$$(\text{High Alarm } 15,148) = 7574$$

(32) Dilution Factor Based on RML-6

$$D.F. = \frac{(\text{RML-6 High Alarm } 15,148)}{21.5 \text{ cpm}} = 704$$

Sheet re-worked due to  
 Procedure change  
 LIQUID RELEASE PERMIT  
 HPP 1521

RELEASE NUMBER 11679-L (SHIFT SUPERVISOR)

DATE: 8-10-79 TIME: 0930 REQUESTOR: [Signature] DATE: 8-10-79

- WDL-T-11A TANK A
- WDL-T-11B TANK B
- WDL-T-12 LAUNDRY
- Other

TANK ISOLATED & "DO NOT OPERATE" Tagged  
 TANK LEVEL 11.4 ft. VOLUME 7330 gal.  
 SIGNED: [Signature]

(47) 15 gpm RR 15 (5-30 gpm) 487 min minimum Estimated time for RELEASE

(48) ESTIMATED CURIES TO BE DUMPED 1.25E3 x 40 = 0.0500 % OF QUARTERLY LIMIT  
 CURIES DUMPED TO DATE THIS QTR. [ ] x 40 = 1.33E2 % OF QUARTERLY LIMIT  
115-79-L LAST RELEASE # INCLUDED TOTAL 1.38E2 % OF QUARTERLY LIMIT

(49)  RELEASE RECOMMENDED BY Joe Dema RADIATION PROTECTION SUPERVISOR  
 RELEASE RECOMMENDED BY Dick Dubois SUP OF RAD PROT & CHEM UNIT SUPERINTENDENT  
 RELEASE APPROVED BY [Signature] SHIFT SUPERVISOR (GENERAL APPROVAL)

(50) RELEASE DATA:  
 RM-L6 Setpoint Hi Alarm 30,202 CPM: Alert 15,151 CPM: [ ] Initials [Signature]  
 FR-84 ALARM SET POINT AT 17 CPM: [ ] INITIALS [Signature]  
 WARNING SIGN ("CAUTION UNIT 1 MAKING LIQUID RELEASE") HUNG ON WDL-99 KEY SWITCH  
 IN UNIT II AUX. BLDG. INITIALS [Signature]  
 FR-146 ALARM SETPOINT AT 34,200 CPM: [ ] INITIALS [Signature]  
 WDL-V124 VALVE LOADED TO 15 GPM RELEASE RATE [ ] INITIALS [Signature]

(51) TIME RELEASE STOPPED 0940 8-13-79 Tank Level at Start of Release 11.4 ft. 7333.8  
 TIME RELEASE STARTED 0810 8-12-79 Tank Level at End of Release 1.5 ft. 930  
 Tank Volume Released 10.9 ft. 6423.8  
 MDCT EFFLUENT TOTALIZER AT STOP 84237.7 ccc  
 MDCT EFFLUENT TOTALIZER AT START 84177.6 ccc  
 TOTAL TIME OF RELEASE 1370 MINUTES 1370 TOTAL DILUTION FLOW 601 ccc

(52) FLOW AND RADIATION MONITORING RECORDER CHARTS MARKED:  
 RM-L6 Source Check Sat. Before Rel.  AT BEGINNING OF RELEASE   
 RM-L6 Alarm Returned to: Hi-Alarm = 3600 CPM  AT END OF RELEASE   
 INSTRUMENT READINGS: Alert Alarm = 1000 CPM  RM-L6 Flushed  Returned to:

	EXPECTED READING	READING AT START	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER RELEASE COMPLETE
FR-84	15 gpm	8	7	6	6	0
RM-L5	15,151 cpm	1.8 x 10 <sup>4</sup>	18,000	16,000	14,000	1.6 x 10 <sup>4</sup>
FR-146	44,000 gpm	42,000	44,000	44,000	46,100	41,000
RM-L7	308 cpm	300	250	300	300	220
		11.4	8.5	5.7	2.8	.3

(53) IF CHANGES IN FLOW FROM THE MDCT (OR CHANGES IN THE RELEASE RATE (V124/V125 position) DEVELOP DURING THE RELEASE, CALCULATION OF A NEW RATE AND SETPOINTS MUST BE MADE. THE NEW CALCULATIONS WILL BE COMPUTED ON PAGE 2 OF THIS FORM AND THE FOLLOWING TABLE WILL BE COMPLETED

	START TIME	STOP TIME	TOTAL TIME	*ACTUAL RELEASE RATE	FR-84 SET POINT	FR-146 SET POINT	APPROVAL SHIFT SUPV
ORIGINAL							
1st CHANGE							
2nd CHANGE							

\*RELEASE RATE CANNOT BE LESS THAN 5 GPM. MDCT CANNOT BE <5000 ccc

LIQUID RELEASE PERMIT

HFP 1621

RELEASE (4)

NUMBER

116-79-L

DATE 8-10-79 TIME 0731

REQUESTOR *[Signature]*

ISSUE DATE

WDT-11A TANK A  
WDT-11B TANK B  
WDT-12 LAUNDRY  
Other

TANK ISOLATED & "DO NOT OPERATE" Tagged  
TANK LEVEL 11.4 ft. VOLUME 7333 gal.  
SIGNED *[Signature]*

DATE 8-10-79  
TIME 0715

gpm RR MAX (5-30 gpm) 19 4.24 MIN (1.1 HR) minimum Estimated time for RELEASE

ESTIMATED CURIES TO BE DUMPED 1.35E3 x 40 = 0.0522 % OF QUARTERLY LIMIT  
CURIES DUMPED TO DATE THIS QTR. x 40 = 1.3382 % OF QUARTERLY LIMIT  
#115-79-L LAST RELEASE = INCLUDED TOTAL 1.3882 % OF QUARTERLY LIMIT

RELEASE RECOMMENDED BY *[Signature]* 8/11/79 2220 YAK  
RELEASE RECOMMENDED BY *[Signature]* 8/11/79 2140 YAK  
RELEASE APPROVED BY *[Signature]* SHIFT SUPERVISOR

RELEASE DATA:  
RM-L6 Setpoint Hi Alarm 30,302 cpm; Alert 15,151 cpm; Initials  
FR-84 ALARM SET POINT AT 19 gpm; Initials  
WARNING SIGN ("CAUTION UNIT 1 HEATING LIQUID RELEASE") HUNG ON WDL-99 KEY SWITCH  
IN UNIT 11 AUX. BLDG. Initials  
FR-148 ALARM SETPOINT AT 34,200 cpm; Initials  
VALVE V124 LOADED TO 17.1 GPM RELEASE RATE; Initials

TIME RELEASE STOPPED \_\_\_\_\_ Tank Level at Start of Release \_\_\_\_\_ ft.  
TIME RELEASE STARTED \_\_\_\_\_ Tank Level at End of Release \_\_\_\_\_ ft.  
TOTAL TIME OF RELEASE \_\_\_\_\_ MINUTES Tank Volume Released \_\_\_\_\_  
MDCT EFFLUENT TOTALIZER AT STOP \_\_\_\_\_  
MDCT EFFLUENT TOTALIZER AT START \_\_\_\_\_  
TOTAL DILUTION FLOW \_\_\_\_\_

FLOW AND RADIATION MONITORING RECORDER CHARTS MARKED:  
RM-L6 Source Check Sat. Before Rel.  AT BEGINNING OF RELEASE   
RM-L6 Alarm Returned to: Hi-Alarm = 3600 cpm  AT END OF RELEASE   
INSTRUMENT READINGS: Alert Alarm = 1800 cpm  RM-L6 Flushed

	EXPECTED READING	READING AT START	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER RELEASE COMP
FR-84	44,000 cpm						
RM-L6	15,151 cpm						
FR-148	17.1 gpm						
RM-L7	308 cpm						

IF CHANGES IN FLOW FROM THE MDCT ICR CHANGES IN THE RELEASE RATE (V124/V125 position) DEVELOP DURING THE RELEASE. CALCULATION OF A NEW RATE AND SETPOINTS MUST BE MADE. THE NEW CALCULATIONS WILL BE COMPUTED ON PAGE 2 OF THIS FORM AND THE FOLLOWING TABLE WILL BE COMPLETED

	START TIME	STOP TIME	TOTAL TIME	*ACTUAL RELEASE RATE	FR-84 SET POINT	FR-148 SET POINT	APPROVAL BY SHIFT SUPV.
ORIGINAL							
1st CHANGE							
2nd CHANGE							

\*RELEASE RATE CANNOT BE LESS THAN 5 GPM. MDCT CANNOT BE <5000 or >25000 cpm.

RELEASE DATA COMPLETED BY \_\_\_\_\_ INITIALS.

ALL DATA REQUIRED ON THIS FORM HAS BEEN COMPLETED.

SHIFT SUPERVISOR

*Run to Release Procedure*  
SPECIAL OPERATION CALCULATIONS

FOR UNEXPECTED CHANGES IN THE MDCT FLOW OR ACTUAL RELEASE RATE THE FOLLOWING CALCULATIONS MUST BE RE-COMPUTED BY THE SHIFT SUPERVISOR. THIS NEED ONLY BE DONE IF THE MDCT FLOW IS REDUCED.

1. MAXIMUM RELEASE RATE = (FR-84 SETPOINT)  
 $RR - MAX = \frac{NEW MDCT FLOW GPM \times (0.9)}{REQUIRED D.F.} = \boxed{\phantom{000}} GPM$
2. ACTUAL RELEASE RATE + (RR MAX)  $\times (0.9) = \boxed{\phantom{000}} GPM$
3. MINIMUM FLOW FROM MDCT (FR-146 SETPOINT) = NEW MDCT FLOW  $\times (0.9) = \boxed{\phantom{000}} GPM$

USE THIS AREA FOR CALCULATIONS:

25 CHEMISTRY PARAMETERS

26 Sample Obtained By: DZ Analysis Performed By: DZ  
 Date/Time: 8-10-79 @ 1337 Date/Time: 8-10-79 7-3

Dilution Factor Required Based on Boron (From Note 3)  $\boxed{\phantom{000}}$

	RESULT	LIMIT	
pH	6.20	4.5 - 9.5	(1)
Conductivity	5.5	<10 umho	(2)
Boron	217	PPM	(3)

1. Limit at tank to insure not exceeding limit of 6 - 9 pH at plant discharge
2. Must be <10 umho to consider water with a pH less than 6 or greater than 9. If conductivity is >10 umhos, release must be approved by Chemistry Supervisor or his designee with a written evaluation attached to release form.
3. 0.7 PPM at final discharge. DF based on Boron is  $\frac{Result (in PPM)}{0.7 PPM}$



WDL-T-11A  
 WDL-T-11B  
 WDL-T-12  
 OTHER

SAMPLE COLLECTED BY DZ  
 DATE 8-10-79 TIME 1337

DATE & TIME OF ANALYSIS  
 ALPHA \_\_\_\_\_  
 BETA \_\_\_\_\_  
 GAMMA 8-10-79 @ 1550

VOLUME IN TANK 1333 gal x 3705 2.77x10<sup>9</sup>  
 ACTUAL VOLUME RELEASED \_\_\_\_\_

RAD. ANAL. Perf. by: \_\_\_\_\_  
 APPROVED BY: \_\_\_\_\_

Composite Sample Collected By: \_\_\_\_\_

(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)	(17)	(18)	(19)	(20)	(21)	(22)	(23)
COUNT METHOD (Procedure Number)	VOLUME OF SAMPLE USED (ml)	SAMPLE COUNT TIME (MIN)	GROSS COUNTS	BKG COUNT TIME (min)	BKG COUNTS	NET SAMPLE COUNT RATE (cpm)	% ERROR ± 2σ	GAMMA ABUN. DANCE OR KEY	SPECIFIC ACTIVITY μCi/ml	MPC 100 μCi/ml	SPECIFIC ACTIVITY μCi/ml	ACT. TO BE RELEASED CURIES	ACTUAL RELEASED CURIES					
GROSS β								N.A.										
GROSS α								N.A.										
H-3								N.A.										
C-14								09-320										
C-13								1.00-335										
C-12								99-310										
C-11								1.00-133										
Zn-65								47-115										
Cs-134								90-605										
Cs-137								85-902										
I-131								82-304										
Ba-140								31-517										
La-140								00-1596										
Xe-133								37-121										
Xe-135								91-350										
AG-100M																		
LA-140																		
BA-140																		

FOR WDL-T-12; IF GROSS β SPECIFIC ACTIVITY > 1 × 10<sup>7</sup> μCi/g, LAUNDRY TAN. CANNOT BE DUMPED AND MUST BE PROCESSED THROUGH PAD WASTE SYSTEM

496  
 RECEIVED BY  
 OF  
 CURIES

ALARM SETPOINT FOR FLOW DATA: MEHLER  
 PRESENT FLOW: 44,000  
 FLOW WHICH CAN BE RELEASED: 44,000  
 FLOW AVAILABLE FOR RELEASE: 1200  
 FLOW TO USE FOR CALCULATIONS: 38,000

(36)  $MINIMUM FLOW = ALARM SETPOINT = (0.9) (FLOW FROM (35)) =$   
 $[34,200]$

(37) Deleted  
 (38) Deleted

(39) REVISED CALCULATIONS FOR MPC/10:  
 (D.F. FROM (33))  $\frac{496}{10} = [49.6]$

D.F. FROM (34)  $[1409]$

MAXIMUM =  $[1800]$

D.F. FROM (26)  $[310]$

DF FROM (100)  $[1800]$

(40)  $RR MAX = OVER FLOW [34,200] \times (35) =$

$(REQUIRED D.F. FROM (39) [1800]) = [19]$

(41)  $RR MAX = [19] \text{ GPM (5.55 to 30 GPM) = FR-34 Alarm Setpoint}$

(42)  $RR Actual = (0.9) (RR MAX) = [17.1] \text{ GPM (5 to 25 GPM)}$

(43) If RR Actual is based on MPC/10, Liquid Waste can be released at a rate greater than or equal to 5 GPM, but less than (42). Use this range of rates.

(44) Estimated time of dump =  $(\text{Est. Vol. to be dumped from (3) } [7333] \text{ gal}) /$   
 $( [17.1] \text{ GPM-RR-Actual} ) \times (42) = [429] \text{ min}$   
 $7.1 \text{ HR}$

(45) Estimated Reading of RX-L6  
 $[5151] \text{ GPM (From (32))} - [10,000] \text{ GPM (Background)} = [15,151]$

(46) Estimated Reading of RX-L7  
 $[15,151] \text{ GPM (Est. Reading of RX-L6)} - [300] \text{ GPM (RX-L7)} = [308]$

(47) Required D.F. From (39)  $[1800]$



(28) Isotopes Identified by Analysis (Exclude H-3)	(29) Specific Activity (From 19) $\mu\text{Ci/ml}$	(30) Sensitivity of RM-L6 to Each Isotope (From Table 1621-1)	(31) Monitor Response (CPM)
MN-54	$3.94E-7$	$8.8 \times 10^7$	35
CO-58	$3.70E-6$	$1.17 \times 10^8$	435
CO-60	$4.44E-6$	$1.72 \times 10^8$	764
AB-110M	$3.67E-6$	$7.7 \times 10^7$	283
CS-134	$9.11E-6$	$1.97 \times 10^8$	1813
CS-137	$1.79E-5$	$7.74 \times 10^7$	1385
LA-140	$3.55E-6$	$7.7 \times 10^7$	273
BA-140	$2.14E-6$	$7.7 \times 10^7$	165

(32)  $\Sigma = 5151$   
Estimated Reading of RM-L6 above background

(33) RM-L6 Setpoints

A. Background Limitations

- If either the estimated monitor response or Bkg < 3600 cpm, go to (33) B.
- If RML-6 Bkg > 3600 cpm, and  $3600 \text{ cpm} < \text{Bkg} < 27,000 \text{ cpm}$ , calculate "e" in A4.
- If Bkg > 27,000 cpm, Decon RML-6 liner and return to (33) A.
- $$e = 3 \times \frac{\sqrt{(\text{Monitor Response } 5151) + (2 \times (\text{Bkg } 10,000))}}{(\text{Monitor Response } 5151)} = |.0924|$$

NOTE: If  $e > 0.2$ , flush and/or decon RML-6 liner and return to (33) A. If  $e \leq 0.2$  go to (33) B.

B. High Alarm Setpoint

$$2 \times \{ (\text{Monitor Response } 5151) + (\text{Bkg } 10,000) \} = |30,302|$$

C. Alert Setpoint

$$\frac{(\text{High Alarm } 30,302)}{2} = |15,151|$$

(34) Dilution Factor Based on RML-6

$$\text{D.F.} = \frac{(\text{RML-6 High Alarm } 15,151)}{21.5 \text{ cpm}} = |1409|$$

all TC 79-122  
 Apr

LICUID RELEASE PERMIT  
MPP 1521

RELEASE NUMBER

117-79-C

(SHIFT SUPERVISOR)

79 TIME: 0240 REQUESTOR: Mehler DATE: 8-11-79  
TIME: 0240

WDT-11A TANK A  
WDT-11B TANK B  
WDT-12 LAUNDRY  
Other

TANK ISOLATED & "DO NOT OPERATE" Tagged  
TANK LEVEL 7.9 ft. VOLUME 5300 gal.  
SIGNED: *Mehler*

gpm RR (5-30 gpm) 5.0 minimum Estimated time for RELEASE

ESTIMATED CURIES TO BE DUMPED 2475 x 40 = .0090 % OF QUARTERLY LIMIT  
CURIES DUMPED TO DATE THIS QTR.          x 40 = .0352 % OF QUARTERLY LIMIT  
         LAST RELEASE # INCLUDED TOTAL .0373 % OF QUARTERLY LIMIT

49  RELEASE RECOMMENDED BY: *[Signature]* RADIATION PROTECTION SUP/Foreman  
 RELEASE RECOMMENDED BY: *[Signature]* SUP OF RAD PROT & CHEM/UNIT SUPERINTENDENT  
 RELEASE APPROVED BY: *[Signature]* SHIFT, SUPERVISOR (FINAL APPROVAL)

50 RELEASE DATA:  
RI-16 Setpoint HI Alarm 15000 CPM: Alert 7000 CPM:          Initials           
FR-84 ALARM SET POINT AT 27 CPM:          INITIALS           
WARNING SIGN ("CAUTION UNIT 1 MAKING LIQUID RELEASE") HUNG ON WDL-99 KEY SWITCH  
IN UNIT 11 AUX. BLDG.          INITIALS           
FR-145 ALARM SETPOINT AT 43000 CPM:          INITIALS           
WDL-V124 VALVE/WDL-V125 LOADED TO 27 GPM RELEASE RATE 5.0 INITIALS         

51 TIME RELEASE STOPPED 1205 TIME 8/14/79 DATE  
Tank Level at Start of Release 5300 ft. 7.7  
Tank Level at End of Release 970 ft. 2.5  
TIME RELEASE STARTED 2125 TIME 8/14/79 DATE  
Tank Volume Released 4370 ft. 7.4  
TOTAL TIME OF RELEASE 790 MINUTES  
MDCT EFFLUENT TOTALIZER AT STOP: 843677 cpm  
MDCT EFFLUENT TOTALIZER AT START: 843292 cpm  
TOTAL DILUTION FLOW: 387 cpm

52 FLOW AND RADIATION MONITORING RECORDER CHARTS MARKED:  
RI-16 Source Check Sat. Before Rel.   
RI-16 Alarm Returned to: HI Alarm = 3600 CPM  AT BEGINNING OF RELEASE   
Alert Alarm = 1000 CPM  AT END OF RELEASE   
INSTRUMENT READINGS: RI-16 Flushed  Returned to:         

EXPECTED READING	READING AT START	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER % COMPLETE	READING AFTER RELEASE COM:
FR-84 <del>7 gpm</del>	15 K	6.0	6	6	6
RI-16 7000 cpm	6100	9,000	7,000	10 <sup>4</sup>	10 <sup>4</sup>
FR-145 4000 cpm	43000	44000	42,000	44,000	44,000
RI-17 261 cpm	400	400	400	400	400

53 IF CHANGES IN FLOW FROM THE MDCT (OR CHANGES IN THE RELEASE RATE (V:24/V125 position) DEVELOP DURING THE RELEASE, CALCULATION OF A NEW RATE AND SETPOINTS MUST BE MADE. THE NEW CALCULATIONS WILL BE COMPUTED ON PAGE 2 OF THIS FORM AND THE FOLLOWING TABLE WILL BE COMPLETED

	START TIME	STOP TIME	TOTAL TIME	*ACTUAL RELEASE RATE	FR-84 SET POINT	FR-145 SET POINT	APPROVAL - SHIFT SUPV
ORIGINAL							
1st CHANGE							
2nd CHANGE							

\*RELEASE RATE CANNOT BE LESS THAN 5 GPM. MDCT CANNOT BE < 5000 gpm

55 RELEASE DATA COMPLETED BY: *[Signature]* INITIALS. *[Signature]* SHIFT SUPERVISOR  
ALL DATA REQUIRED ON THIS FORM HAS BEEN COMPLETED.

SPECIAL OPERATION CALCULATIONS

FOR UNEXPECTED CHANGES IN THE MDCT FLOW OR ACTUAL RELEASE RATE THE FOLLOWING CALCULATIONS MUST BE RE-COMPUTED BY THE SHIFT SUPERVISOR. THIS NEED ONLY BE DONE IF THE MDCT FLOW IS REDUCED.

1. MAXIMUM RELEASE RATE ~~NEW MDCT FLOW~~

$$(RR \text{ MAX}) = \frac{\text{NEW MDCT FLOW GPM} \times (0.9)}{\text{REQUIRED D.F.}} = \boxed{\phantom{000}} \text{ GPM } \textcircled{40}$$

2. The Actual Release Rate shall be between 5 GPM and  $[0.9 \times \textcircled{40}] = \boxed{\phantom{000}}$ ; FR 84 SET POINT =  $0.9 \times \textcircled{40}$   
FR 84 =  $\boxed{\phantom{000}}$

3. The lesser of:  $\left\{ \begin{array}{l} \text{New MDCT FLOW} \\ \geq 8000 \text{ GPM} \end{array} \right.$   
is new FR-146 SETPOINT  $\boxed{\phantom{000}}$  GPM

USE THIS AREA FOR CALCULATIONS:

25 CHEMISTRY PARAMETERS

26 Sample Obtained By: cdm Analysis Performed By: cdm  
Date/Time: 1700 8-11-79 Date/Time: 2200 8-11-79

Dilution Factor Required Based on Boron. (From Note 3)  $\boxed{128}$   $\textcircled{26}$

	RESULT	LIMIT	
pH	6.75	4.5 - 9.5	(1)
Conductivity	71	<10 µmho	(2)
Boron	90	PPM	(3)

- Limit at tank to insure not exceeding limit of 6 - 9 pH at plant discharge.
- Must be <10 µmho to consider water with a pH less than 6 or greater than 9. If conductivity is >10 µmhos, release must be approved by Chemistry Supervisor or his designee with a written evaluation attached to release form.
- 0.7 PPM at final discharge. DF based on Boron is  $\frac{\text{Result (in PPM)}}{0.7 \text{ PPM}}$





NAME OF  
SHIFT SUPERVISOR  
CONTACTED

*Acker*

- 35 CONTACT SHIFT SUPERVISOR FOR FOLLOWING DATA
- a) PRESENT MDCT FLOW 70000 gpm.
  - b) MAX MDCT FLOW WHICH CAN BE MADE AVAILABLE 7000 gpm.
  - c) TIME AVAILABLE FOR RELEASE 1200 min (200 to 1200 min)
  - d) MDCT Flow ~~for CALCULATIONS~~ 38000 gpm (must be >5000;  
<33000) 33d = FR-146 ALARM SETPOINT

36 Minimum ~~MDCT Flow~~ =  $(0.9 \times \text{MDCT Flow from } 35d) = \boxed{34200}$  (36)

- 37 Deleted
- 38 Deleted

39 REVISED CALCULATIONS FOR MPC/10:  
(D.F. FROM 23)  $\frac{127}{10} = \boxed{12.7}$

D.F. FROM 34  $\boxed{728}$

D.F. FROM 26  $\boxed{128}$

D.F. FROM 10  $\boxed{231.35}$

39 MAXIMUM =  $\boxed{738}$

40 MAX. RR =  $\left( \frac{\text{MIN MDCT } 34200}{\text{(REQUIRED D.F. FROM } 39) \frac{738}{FCV}} \right) = \boxed{76} = \text{R.R. MAX } 40$

41 FR-84 Alarm Setpoint =  $(0.9 \times 40) = \boxed{27}$  (41)

42 RR Actual is greater than 5GPM and less than  
41 As established by Shift Supervisor/Shift Foreman  
record as 42

43 Deleted

44 Estimated time of dump =  $\left( \frac{\text{Est. Vol. to be dumped from } 3 \text{ } 5300 \text{ gal}}{10 \left( \frac{FCV}{FCV} \right) \text{ GPM-RR-Actual } 42} \right) = \frac{530}{10} \text{ MI}$

45 Estimated Reading of RM-L6  
 $\frac{939}{939} \text{ CPM (From } 32) + \boxed{7000} \text{ CPM (Background)} = \boxed{7929} \text{ CPM}$

46 Estimated Reading of RM-L7  
 $\frac{7929}{7929} \text{ CPM (Est. Reading of RM-L6)} + \boxed{80} \text{ CPM (RM-L7)} = \boxed{261} \text{ CPM}$

(28) Isotopes identified by Analysis (Exclude H-3)	(29) Specific Activity (From 19) $\mu\text{Ci/ml}$	(30) Sensitivity of RM-L6 to Each Isotope (From Table 1621-1)	(31) Monitor Response (CPM)
CO-58	$1.04 \times 10^{-6}$	$1.17 \times 10^4$	122
CO-60	$5.01 \times 10^{-7}$	$1.72 \times 10^8$	86
NB-95	$6.17 \times 10^{-8}$	$3.8 \times 10^7$	5
CS-134	$3.00 \times 10^{-6}$	$1.99 \times 10^8$	597
CS-137	$7.01 \times 10^{-6}$	$7.74 \times 10^7$	54
I-131	$8.33 \times 10^{-8}$	$1.06 \times 10^8$	9
AG-110M	$7.24 \times 10^{-7}$	$7.7 \times 10^7$	56

(32)  $\bar{x} = 929$   
Estimated Reading of RM-L6 above background

(33) RM-L6 Setpoints

A. Background Limitations

1. If RM-L6 ESTIMATED READING  $> 3600$  cpm, and  $3600$  cpm  $<$  Background  $< 27,000$  cpm, calculate "e" in 3.3.A.4
2. If Background  $> 27,000$  cpm, Decontaminate <sup>the</sup> RM-L6 Lines and return to (33) A 1
3. If either the RM-L6 ESTIMATED READING or background  $< 3600$  go to (33) B



B. High Alarm Setpoint

$$2 \times \{ (\text{Monitor Response } \underline{929}) + (\text{Bkg } \underline{2000}) \} = \underline{15858}$$

C. Alert Setpoint

$$\frac{(\text{High Alarm } \underline{15858})}{2} = \underline{7929}$$

34. Dilution Factor Based on RML-6

$$\text{D.F.} = \frac{(\text{RML-6 High Alarm } \underline{15858})}{21.5 \text{ cpm}} = \underline{734}$$



UNITED STATES DISTRICT COURT  
FOR THE DISTRICT OF COLUMBIA

CITY OF LANCASTER,  
CITY OF LANCASTER AUTHORITY  
and ALBERT B. WOHLSEN, JR.,

Plaintiffs,

v.

UNITED STATES NUCLEAR  
REGULATORY COMMISSION,

Defendant.

Civil Action No. 79-1368

(Gasch, J.)

PLAINTIFFS' FIRST INTERROGATORIES  
TO DEFENDANT PENDING HEARING ON  
PLAINTIFFS' APPLICATION FOR PRE-  
LIMINARY INJUNCTION

Plaintiffs, CITY OF LANCASTER, CITY OF LANCASTER AUTHORITY and ALBERT B. WOHLSEN, JR., require that Defendant, UNITED STATES NUCLEAR REGULATORY COMMISSION, answer the following Interrogatories fully, in writing and under oath, in accordance with Rule 33 of the Federal Rules of Civil Procedure. These Interrogatories shall be deemed continuing so as to require supplementation by separate answer if defendant or its attorneys or anyone on behalf of defendant or its attorneys obtains further information between the time the answers hereto are served and the time of any hearing held on plaintiffs' Application for Preliminary Injunction. In answering the following interrogatories defendant is required to file full and complete answers based upon its personal knowledge as well as upon the personal knowledge of any of its agents, attorneys, employees or investigators.

By prior agreement of counsel for the parties in this action, answers to these Interrogatories will be served in less than thirty days and as soon as reasonably possible.

INTERROGATORY NO. 1

1. Has defendant permitted or approved the discharge of any water from Reactor No. 2 at the Three Mile Island ("TMI") nuclear generating plant referred to in plaintiffs' Complaint and Application herein since May 20, 1979?

INTERROGATORY NO. 2

2. If the answer to Interrogatory No. 1 is affirmative,

(a) State how much water (in gallons) was discharged and the origin within Reactor No.2 of such water;

(b) State whether any analysis was performed with respect to that water prior to its discharge, and if so, state in detail:

(i) the exact analysis performed, the person(s) who performed the analysis, the employer(s) of such person(s), and the amount (in gallons) of water analyzed; and

(ii) the complete findings resulting from the analysis, including the designation of all radioactive isotopes, and the extent of their radioactivities, which were found in the water; and

(c) State the basis for defendant having given its permission or approval for the discharge of that water.

INTERROGATORY NO. 3

3. Does defendant know of any discharge of water from Reactor No. 2 at TMI since May 20, 1979?

INTERROGATORY NO. 4

4. If the answer to Interrogatory No. 3 is in the affirmative,

- (a) State the amount of water discharged,
- (b) State whether defendant was requested to take any action concerning such discharge, and
- (c) If defendant received such a request, state what action defendant took, if any.

INTERROGATORY NO. 5

5. State whether there has been any construction or installation of water decontamination facilities, or any facilities related thereto, at TMI since May 20, 1979.

INTERROGATORY NO. 6

6. If the answer to Interrogatory No. 5 is in the affirmative,

- (a) Describe in detail the construction or installation activities involved,
- (b) State whether defendant has given approval for such construction or installation activities, and
- (c) If defendant has given such approval, state whether defendant has granted an amendment to the Metropolitan Edison Company's operating license and/or construction permit.

INTERROGATORY NO. 7

7. Has defendant permitted or approved, or does defendant intend to permit or approve, the discharge of any water from Reactor No. 2 at TMI prior to the disposition of Plaintiffs Application for a Preliminary Injunction filed herein on May 21, 1979

*No water from R-2 will be discharged until the NRC has issued for public comment an Environmental Assessment dealing with such discharges as required by the Commission Order issued May 25, 1979.*

INTERROGATORY NO. 8

8. If the answer to Interrogatory No. 7 is in the affirmative,

(a) State the amount of water (in gallons) which defendant has approved and/or intends to approve for discharge.

(b) State whether any analysis has been performed of the water to be discharged prior to permitting or approving such a discharge, and if so, state in detail:

(1) the exact analysis performed, the person(s) who performed the analysis, the employer(s) of such person(s), and the amount (in gallons) of water analyzed;

(2) The complete findings resulting from the analysis, including the designation of all radioactive isotopes, and the extent of their radioactivities, which were found in the water to be discharged; and

(c) State the basis for defendant having given or intending to give its permission or approval for the said discharge.

INTERROGATORY NO. 9

9. State whether defendant expects that there will be any construction or installation of water decontamination facilities, or any facilities related thereto, from and after the date of these Interrogatories and prior to the disposition of plaintiffs' Application for a Preliminary Injunction filed herein on May 21, 1979.

*Let's check w/ GPU/Mid-Ed on this.*



INTERROGATORY NO. 10

10. If the answer to Interrogatory No. 9 is in the affirmative, describe in detail the further construction or installation of water decontamination facilities contemplated; state whether defendant has given approval to the further contemplated construction or installation; and if such approval has been given, state whether defendant has granted to Metropolitan Edison Company an amendment to its operating license and/or construction permit.

Donald E. LeFever  
Christopher W. Mattson  
James A. Humphreys, III

Counsel for Plaintiffs  
City of Lancaster,  
City of Lancaster  
Authority and  
Albert B. Wohlson, Jr.

BARLEY, SNYDER, COOPER & BARBER  
115 East King Street  
Lancaster, Pennsylvania 17602  
(717) 299-5201

Washington, D.C. counsel  
for plaintiffs

ARENT, FOX, KINTNER, PLOTKIN  
& KAHN  
Federal Bar Building  
1815 H Street, N.W.  
Washington, D.C. 20006  
(202) 857-6000

May 24, 1979

By: \_\_\_\_\_  
Arthur E. Wilmarth, Jr.  
Reed L. von Maur

CERTIFICATE OF SERVICE

I, ARTHUR E. WILMARTH, JR., hereby certify that on this 24th day of May, 1979, I caused copies of Plaintiffs' First Set of Interrogatories to Defendant Pending Hearing on Plaintiffs' Application for Preliminary Injunction to be served by hand delivery upon William Cohen, Esquire, and Jose Uranga, Esquire, United States Department of Justice, 9th Street and Pennsylvania Avenue, N.W., Washington, D.C. 20530, counsel for Defendant.

ARTHUR E. WILMARTH, JR.

Counsel for Plaintiffs