

November 15, 1982

DMB 016

DISTRIBUTION

Docket File

Gray File  
EBlackwood  
HOrnstein

NRC PDR  
L PDR  
ORB#4 Rdg  
DEisenhut  
OELD  
AEOD

Docket No. 50-302

Mr. J. A. Hancock  
Vice President  
Nuclear Operations  
Florida Power Corporation  
ATTN: Manager, Nuclear Licensing  
P. O. Box 14042; M.A.C. H-2  
St. Petersburg, Florida 33733

EJordan  
ACRS-10  
JTaylor  
SMiner  
RIngram  
Tippolito

Dear Mr. Hancock:

By letter dated September 27, 1982 we sent you a Safety Evaluation (SE) concerning the electrical, instrumentation and control aspects of the Crystal River Nuclear Generating Plant, Unit 3 Auxiliary Feedwater System, TMI Action Plan Item II.E.1.2. Our SE was based on design information including design descriptions and logic diagrams which we thought to be sufficient at that time. However, in view of a recent finding that our understanding of the design may not accurately represent the final system to be installed, we request that you submit detailed electrical schematic diagrams showing the actual automatic initiation circuitry and emergency feedwater system pump and valve control circuits to be installed.

With this information we will reexamine your design to determine if our conclusions as stated in the SE still remain valid. Please contact your project manager if you have any questions.

The reporting and/or recording keeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P. L. 96-511.

Sincerely,

ORIGINAL SIGNED BY  
JOHN F. STOLZ\*

John F. Stoiz, Chief  
Operating Reactors Branch #4  
Division of Licensing

cc: See next page

8211220071 821115  
PDR ADOCK 05000302  
P PDR

OFFICE ▶	ORB#4:DL	C-ORB#4:DL					
SURNAME ▶	SMiner;cf	JStolz					
DATE ▶	11/15/82	11/15/82					

Crystal River Unit No. 3  
Florida Power Corporation

50-302

cc w/enclosure(s):  
Mr. S. A. Brandimore  
Florida Power Corporation  
Vice President and General Counsel  
P. O. Box 14042  
St. Petersburg, Florida 33733

Mr. Wilbur Langely, Chairman:  
Board of County Commissioners  
Citrus County  
Iverness, Florida 36250

Regional Radiation Representative  
EPA Region IV  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 220, 7910 Woodmont Avenue  
Bethesda, Maryland 20814

Mr. Tom Stetka, Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route #3, Box 717  
Crystal River, Florida 32629

Mr. T. C. Lutkehaus  
Nuclear Plant Manager  
Florida Power Corporation  
P. O. Box 219  
Crystal River, Florida 32629

Bureau of Intergovernmental Relations  
660 Apalachee Parkway  
Tallahassee, Florida 32304

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, Florida 32304

Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

November 15, 1982

Docket No. 50-302

Mr. J. A. Hancock  
Vice President  
Nuclear Operations  
Florida Power Corporation  
ATTN: Manager, Nuclear Licensing  
P. O. Box 14042; M.A.C. H-2  
St. Petersburg, Florida 33733

Dear Mr. Hancock:

By letter dated September 27, 1982 we sent you a Safety Evaluation (SE) concerning the electrical, instrumentation and control aspects of the Crystal River Nuclear Generating Plant, Unit 3 Auxiliary Feedwater System, TMI Action Plan Item II.E.1.2. Our SE was based on design information including design descriptions and logic diagrams which we thought to be sufficient at that time. However, in view of a recent finding that our understanding of the design may not accurately represent the final system to be installed, we request that you submit detailed electrical schematic diagrams showing the actual automatic initiation circuitry and emergency feedwater system pump and valve control circuits to be installed.

With this information we will reexamine your design to determine if our conclusions as stated in the SE still remain valid. Please contact your project manager if you have any questions.

The reporting and/or recording keeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P. L. 96-511.

Sincerely,

A handwritten signature in cursive script that reads "John F. Stolz".

John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

cc: See next page