

Detroit
Edison

Stanley G. Catola
Vice President
Nuclear Engineering and Services

Fermi 2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 586-4000

Reg Guide 1.16



February 15, 1991
NPC-91-0009

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Reference: Fermi 2
NRC Docket No. 50-341
NRC Operating License No. NPF-43

Subject: Monthly Operating Status Report for
January, 1991

Enclosed for your information and use is the Fermi 2 Monthly Operating Status Report for January, 1991. This report includes the Operating Data Report, Average Daily Unit Power Level, and the Summary of Unit Shutdowns and Power Reductions identified in NRC Regulatory Guide 1.16 and Fermi 2 Technical Specification 6.9.1.6.

If you have any questions, please contact Joseph Pendergast, Compliance Engineer, at (313) 586-1682.

Sincerely,

Enclosure

cc: A. B. Davis
J. R. Eckert
D. R. Hahn
R. W. DeFayette
W. G. Rogers
J. F. Stang

9102200009 910131
PDR ADOCK 05000341
R PDR

IE24
11

OPERATING DATA REPORT

DOCKET NO. 50-341

COMPLETED BY B. J. Stone

DATE February 15, 1991

TELEPHONE (313) 586-5148

OPERATING STATUS

1. UNIT NAME: Fermi 2 | Notes: (1) Calculated using |
2. REPORTING PERIOD: January, 1991 | MDC of 1093 for period prior to |
3. LICENSED THERMAL POWER (Mwt): 3293 | January 1, 1990. |
4. NAMEPLATE RATING (GROSS MWe): 1154 | |
5. DESIGN ELECT RATING (Net MWe): 1093 | |
6. MAX DEPENDABLE CAP (GROSS MWe): 1105 | |
7. MAX DEPENDABLE CAP (Net MWe): 1055 | |
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE
LAST REPORT, GIVE REASONS: _____
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (MWe Net): Approximately 800
10. REASONS FOR RESTRICTION, IF ANY: Administrative limit due to concerns
about main turbine blading.

	THIS MONTH	YR TO DATE	CUMULATIVE
11. HRS IN REPORTING PERIOD	<u>744</u>	<u>744</u>	<u>26,510</u>
12. HRS REACTOR WAS CRITICAL	<u>739.9</u>	<u>739.9</u>	<u>19,257.6</u>
13. REACTOR RESERVE SHUTDOWN HRS	<u>0</u>	<u>0</u>	<u>0</u>
14. HOURS GENERATOR ON-LINE	<u>716.8</u>	<u>716.8</u>	<u>18,275.4</u>
15. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
16. GROSS THERMAL ENERGY GEN (MWH)	<u>1,835,623</u>	<u>1,835,623</u>	<u>53,666,817</u>
17. GROSS ELECT ENERGY GEN (MWH)	<u>570,830</u>	<u>570,830</u>	<u>17,745,367</u>
18. NET ELECT ENERGY GEN (MWH)	<u>544,157</u>	<u>544,157</u>	<u>16,955,461</u>
19. UNIT SERVICE FACTOR	<u>96.3</u>	<u>96.3</u>	<u>68.9</u>
20. UNIT AVAILABILITY FACTOR	<u>96.3</u>	<u>96.3</u>	<u>68.9</u>
21. UNIT CAP FACTOR (USING MDC NET)	<u>69.3</u>	<u>69.3</u>	<u>59.4 (1)</u>
22. UNIT CAP FACTOR (USING DER NET)	<u>66.9</u>	<u>66.9</u>	<u>58.5</u>
23. UNIT FORCED OUTAGE RATE	<u>0</u>	<u>0</u>	<u>11.4</u>

24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, DURATION OF EACH)
A refueling outage is scheduled to begin March 29, 1991. It is presently estimated that the outage will last 75 days (breaker to breaker).
25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

	FORECAST	ACHIEVED
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-341
 UNIT FERMI 2
 DATE February 15, 1991
 COMPLETED BY E. Dawson
 TELEPHONE (313) 586-5027

Month January, 1991

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>133</u>
3	<u>467</u>
4	<u>761</u>
5	<u>760</u>
6	<u>745</u>
7	<u>783</u>
8	<u>781</u>
9	<u>777</u>
10	<u>783</u>
11	<u>772</u>
12	<u>780</u>
13	<u>779</u>
14	<u>774</u>
15	<u>801</u>
16	<u>799</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>800</u>
18	<u>800</u>
19	<u>794</u>
20	<u>801</u>
21	<u>803</u>
22	<u>792</u>
23	<u>796</u>
24	<u>804</u>
25	<u>802</u>
26	<u>800</u>
27	<u>803</u>
28	<u>799</u>
29	<u>803</u>
30	<u>804</u>
31	<u>800</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-341
 UNIT NAME Fermi 2

DATE February 15, 1991
 COMPLETED BY B. J. Stone
 TELEPHONE (313) 586-5148

REPORT MONTH January, 1991

NO.	DATE	TYPE (1)	DUR (HRS) (2)	REASON (2)	METHOD OF SHUTTING DOWN THE REACTOR (3)	LER NO.	SYS CODE (4)	COMP CODE (5)	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
90-011	11/25/90	S	27.2	B	1	-	TA	TRB	Due to change in turbine bearing vibration, power was reduced until a black & white condition was reached. Then control rods were inserted. Inspection of the South Low Pressure Turbine showed damage to both the shroud and the blades. Repairs were made. The reactor was re-started on 01/01/91. The generator was synchronized to the Grid at 0310 hrs. 01/02/91.

(1) F: FORCED
 S: SCHEDULED

(2) REASON:
 A - EQUIPMENT FAILURE (EXPLAIN)
 B - MAINTENANCE OR TEST
 C - REFUELING
 D - REGULATORY RESTRICTION
 E - OPERATOR TRAINING & LICENSE EXAMINATION
 F - ADMINISTRATIVE
 G - OPERATIONAL ERROR (EXPLAIN)
 H - OTHER (EXPLAIN)

(3) METHOD:
 1 - MANUAL
 2 - MANUAL SCRAM
 3 - AUTOMATIC SCRAM
 4 - INTINUED
 5 - REDUCED LOAD
 9 - OTHER

(4) EXHIBIT G - INSTRUCTIONS
 FOR PREPARATION OF DATA
 ENTRY SHEETS FOR LICENSEE
 EVENT REPORT (LER) FILE
 (NUREG-0161)

(5) EXHIBIT 1 - SAME SOURCE