

DISTRIBUTION:
Docket File
NRC PDR
L PDR

ORB#2 Rdg
Gray File
Deisenhut
SNorris
DClark
OELD
AEOD
IE-Harmon & Jordan
ACRS-10

NOV 15 1982

Docket Nos. 50-259
50-260
and 50-296

Mr. Hugh G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Dear Mr. Parris:

Subject: NUREG-0737, Items I.A.2.1.4 and II.B.4

Re: Browns Ferry Nuclear Plant, Units 1, 2 and 3

Reference is made to your letter of May 6, 1982 responding to our request for additional information on NUREG-0737, Items I.A.2.1.4 "Upgrading of RO and SRO Training" and II.B.4 "Training for Mitigating Core Damage". Our review of these items is complete. However, to find your training programs acceptable, we need to resolve the two items identified in the enclosure to this letter. A response to this request for additional information would be appreciated within 45 days of receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P. L. 96-511.

Sincerely,

ORIGINAL SIGNED BY

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosure:
Request for Additional
Information

cc w/enclosure:
See next page

8211230052 821115
PDR ADOCK 05000259
P PDR

OFFICE	ORB#2:DL	ORB#2:DL	C-ORB#2:DL				
SURNAME	SNorris	DClark, Cab	DVassallo				
DATE	11/15/82	11/15/82	11/15/82				

Mr. Hugh G. Parris

cc:

H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 33C
Knoxville, Tennessee 37902

Mr. Ron Rogers
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Charles R. Christopher
Chairman, Limestone County Commission
P. O. Box 188
Athens, Alabama 35611

Ira L. Myers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36104

Mr. H. N. Culver
249A HBD
400 Commerce Avenue
Tennessee Valley Authority
Knoxville, Tennessee 37902

James P. O'Reilly
Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

U. S. Environmental Protection
Agency
Region IV Office
Regional Radiation Representative
345 Courtland Street
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 311
Athens, Alabama 35611

Mr. John F. Cox
Tennessee Valley Authority
W9-D 207C
400 Commerce Avenue
Knoxville, Tennessee 37902

George Jones
Tennessee Valley Authority
P. O. Box 2000
Decatur, Alabama 35602

Mr. Oliver Havens
U.S. Nuclear Regulatory Commission
Reactor Training Center
Osborne Office Center, Suite 200
Chattanooga, Tennessee 37411

REQUEST FOR ADDITIONAL INFORMATION

NUREG-0737, ITEMS I.A.2.1.4 AND II.B.4

BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2 AND 3

DOCKET NOS. 50-259, 50-260 AND 50-296

1. Item II.B.4 of NUREG-0737 requires shift technical advisors and operating personnel from the plant manager through the operations chain to receive the training identified in Enclosure 3 to Denton's letter dated March 28, 1980. (Letter dated March 28, 1980 from Harold R. Denton, USNRC to "All Power Reactor Applicants and Licensees" concerning qualifications of reactor operators.) The TVA response to NRR dated May 6, 1982, does not include the plant superintendent and assistant plant superintendents in the personnel that receive this training. Describe the training program that is provided to the plant superintendent and assistant plant superintendents that covers the subject matter contained in Enclosure 3 to Denton's letter.
2. TVA correspondence to NRR dated May 6, 1982, stated in response to Questions 5 and 6 that 32 hours of retraining is provided in the operator requalification program and 16 hours of specific mitigating core damage training. Additionally, TVA stated that the total combined hours of training meet or exceed 80 contact hours. Please clarify this area of apparent conflict; i.e., 48 hours vice 80 hours. In addition, please identify how many hours of training are provided in each area in the initial operator training program.