

**Florida
Power**
CORPORATION

November 19, 1982
#3F-1182-18
File: 3-0-3-e

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUBJECT: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Technical Specification Change Request No. 53, Revision 1

Dear Mr. Denton:

Enclosed are three (3) originals and forty (40) copies of Technical Specification Change Request No. 53, Revision 1, requesting amendment to Appendix A of Operating License No. DPR-72. As part of this request, proposed replacement pages for Appendix A are enclosed.

Change Request No. 53, Rev. 1, is an application for a licensing amendment to allow a calibration error of up to 2% RATED THERMAL POWER in the out-of-core instrumentation, as discussed with members of your staff. Revision 1 is consistent with Revision 4 of the B&W Standard Technical Specifications (NUREG-0103). Change Request No. 53, submitted November 20, 1979, is superseded by Change Request No. 53, Rev. 1.

FPC considers Change Request No. 53, Rev. 1, to be a Class III Amendment per 10 CFR 170.22 as it involves a single safety issue. The licensing fee for Change Request 53, Rev. 1, was submitted with Change Request No. 53.


*A001
3/40*

8211230136 821119
PDR ADOCK 05000302
P PDR

Mr. Harold R. Denton, Director
#3F-1182-18
Page -2-

A signed copy of the Certificate of Service for Technical Specification Change Request No. 53, Revision 1, to the Chief Executive of Citrus County, Florida, is enclosed.

Very truly yours,



Dr. Patsy Y. Baynard
Assistant to Vice President
Nuclear Operations

PGH/mlg

Enclosures

cc: Mr. J. P. O'Reilly,
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
101 Marietta Street N.W., Suite 3100
Atlanta, Ga. 30303

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF)
) DOCKET NO. 50-302
FLORIDA POWER CORPORATION)


CERTIFICATE OF SERVICE

Patsy Y. Baynard deposes and says that the following has been served on the Chief Executive of Citrus County, Florida, by deposit in the United States mail, addressed as follows:

Chairman,
Board of County Commissioners
of Citrus County
Citrus County Courthouse
Inverness, FL 32650


One (1) copy of Technical Specification Change Request No. 53, Rev. 1, requesting amendment to Appendix A of Operating License No. DPR-72.

FLORIDA POWER CORPORATION



Patsy Y. Baynard
Assistant to Vice President
Nuclear Operations

SWORN TO AND SUBSCRIBED BEFORE ME THIS 19TH DAY OF NOVEMBER,
1982.




Notary Public

Notary Public, State of Florida at Large
My Commission Expires: May 29, 1984


(NOTARIAL SEAL)

STATE OF FLORIDA
COUNTY OF PINELLAS

PATSY Y. BAYNARD states that she is the Assistant to Vice President, Nuclear Operations, of Florida Power Corporation; that she is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of her knowledge, information, and belief.


PATSY Y. BAYNARD

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 19th day of November 1982.


Notary Public

Notary Public, State of Florida at Large,
My Commission Expires: May 29, 1984