

RECEIVED
NRC

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

1982 NOV 17 AM 10:55

JAMES D. SHIFFER
MANAGER

DEPARTMENT OF NUCLEAR PLANT OPERATIONS
NUCLEAR POWER GENERATION

REGION V I&E

November 16, 1982

Mr. R. H. Engelken, Regional Administrator
U.S. Nuclear Regulatory Commission, Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596-5368


Re: Docket No. 50-275, OL-DPR-76
Diablo Canyon Unit 1
Licensee Event Report 82-010/01T-0
Liquid Radwaste Effluent Discharge

Dear Mr. Engelken:

Pursuant to Section 6.9.1.12.b of the Technical Specifications, Appendix A to the Diablo Canyon Unit 1 Operating License, the enclosed Licensee Event Report is submitted concerning the partial discharge of the contents of a tank in the Liquid Radwaste System without having collected and analyzed a second independent sample as required by Action Statement 40 of Technical Specification 3.3.3.9 during periods when the Liquid Radwaste Effluent Line Radiation Monitor (RE-18) is inoperable.

This event has in no way affected public health and safety.

Sincerely,



JDS:vk

Enclosure

cc w/enc: Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director, Office of Management Information
and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Service List

8211230177 821116
PDR ADOCK 05000275
S PDR

IE-22
82-224