

CONNECTICUT YANKEE ATOMIC POWER COMPANY

HADDAM NECK PLANT

HADDAM, CONNECTICUT

MONTHLY OPERATING REPORT NO. 82-10

FOR THE MONTH OF

OCTOBER 1982

8211230189 821113
PDR ADOCK 05000213
R PDR

PLANT OPERATIONS

The following is a summary of plant operations for the month of October, 1982:

The unit operated at 100% power until October 24, when load was reduced to 400 Mwe to conduct a routine turbine valve test. The plant continued at 100% power throughout the remainder of the month.

SYSTEM OR COMPONENT	I&C Department Report for Oct. 1982 MALFUNCTION	EFFECT ON SAFE OPERATION	CORRECTIVE ACTION TAKEN TO PREVENT REPETITION	SPECIAL PRECAUTIONS TAKEN TO PROVIDE FOR REACTOR SAFETY DURING REPAIR
	CAUSE	RESULT		
Emergency Diesel Generator EG-2B Air start compressor switch	Switch reached end of life	Unable to start and stop air compressor within acceptable limits	None	Replaced switch
				Continuous monitoring of air supply tanks.

SYSTEM OR COMPONENT	Maintenance Report for Oct. 1982		EFFECT ON SAFE OPERATION	CORRECTIVE ACTION TAKEN TO PREVENT REPETITION	SPECIAL PRECAUTIONS TAKEN TO PROVIDE FOR REACTOR SAFETY DURING REPAIR
	MALFUNCTION				
	CAUSE	RESULT			
Emergency Diesel Generator EG-2A	Pin hole leak in service water flexible piping to heat exchan- er <u>Reason:</u> Age & corrosion	Small service water leak	None	Replaced pipe with stain- less steel flexible line.	Replaced flexible piping with temporary piping. Proved redundant diesel available
Emergency Diesel Generator EG-2B	Outboard heat exchanger tube leak <u>Reason:</u> Corrosion	Service water leak to engine coolant	None	Plugged leaking tube	Proved redundant diesel available
"B" Charging Pump	Pin hole in re- circulation by- pass isolation valve body. <u>Reason:</u> High fluid velo- city thru valve when valve is throttling for low flow	Reactor coolant leak to primary auxiliary build- ing atmosphere	None	Pad welded pin hole in valve body. Evaluating need for new valve design	N/A

AVERAGE DAILY UNIT POWER LEVEL

CORE XI

DOCKET NO. 50-213

Conn. Yankee
UNIT Haddam Neck

DATE November 13, 1982

COMPLETED BY A. Elms

TELEPHONE (203) 267-2556

MONTH: October 1982

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	570	17	574
2	571	18	574
3	571	19	574
4	571	20	573
5	571	21	574
6	570	22	575
7	570	23	576
8	569	24	546
9	569	25	575
10	572	26	576
11	5	27	576
12	573	28	577
13	573	29	576
14	573	30	577
15	574	31	576
16	574		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Complete the nearest whole megawatt.

CONNECTICUT YANKEE
 REACTOR COOLANT DATA
 MONTH: OCTOBER 1982

REACTOR COOLANT ANALYSIS	MINIMUM	AVERAGE	MAXIMUM
PH @ 25 DEGREES C	: 6.30E+00	: 6.58E+00	: 6.80E+00
CONDUCTIVITY (UMHOS/CM)	: 4.35E+00	: 6.03E+00	: 7.10E+00
CHLORIDES (PPM)	: <5.00E-02	: <5.00E-02	: <5.00E-02
DISSOLVED OXYGEN (PPB)	: <5.00E+00	: <5.00E+00	: <5.00E+00
BORON (PPM)	: 1.84E+02	: 2.30E+02	: 2.76E+02
LITHIUM (PPM)	: 3.70E-01	: 5.47E-01	: 7.60E-01
TOTAL GAMMA ACT. (UC/ML)	: 1.12E+00	: 1.43E+00	: 2.29E+00
IODINE-131 ACT. (UC/ML)	: 7.98E-03	: 8.91E-03	: 1.10E-02
I-131/I-133 RATIO	: 7.34E-01	: 8.50E-01	: 1.01E+00
CRUD (MG/LITER)	: <1.00E-02	: <1.00E-02	: <1.00E-02
TRITIUM (UC/ML)	: 5.43E-01	: 1.08E+00	: 1.50E+00
HYDROGEN (CC/KG)	: 1.81E+01	: 2.05E+01	: 2.42E+01

AERATED LIQUID WASTE PROCESSED(GALLONS): 1.96E+05
 WASTE LIQUID PROCESSED THROUGH BORON RECOVERY(GALLONS): 4.48E+04
 AVERAGE PRIMARY LEAK RATE(GALLONS PER MINUTE): 4.01E-01
 PRIMARY TO SECONDARY LEAK RATE(GALLONS PER MINUTE): 0.00E+00

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH October 1982

DOCKET NO. 50-213
 UNIT NAME Corn, Yankee
 DATE Nov. 13, 1982
 COMPLETED BY A. Elms
 TELEPHONE (203) 267-2556

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
									No shutdowns or power reductions in the month of October 1982.

- 1 F Forced
 S Scheduled
- 2 Reason:
 A-Equipment Failure(Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training
 F-Administrative
 G-Operational Error(Explain)
- H-Other(Explain)

- 3 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram.
 4-Other(Explain)
- 4 Exhibit G-Instructions for Preparation of Data Entry Sheets for Licensee Event Report(LER) File (NUREG-0161)

5 Exhibit 1 Same Source

REFUELING INFORMATION REQUEST

1. Name of facility

Connecticut Yankee Atomic Power Company

2. Scheduled date for next refueling shutdown.

January 22, 1983

3. Scheduled date for restart following refueling.

Approximately six to eight weeks.

4. (a) Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

No technical specification changes are anticipated at this time.

(b) If answer is yes, what, in general, will these be?

N/A

(c) If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Ref. 10 CFR Section 50.59)?

(d) If no such review has taken place, when is it scheduled?

N/A

5. Scheduled date(s) for submitting proposed licensing action and supporting information.

There are no scheduled dates because of (4) above.

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

None.

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool.

(a) 157 (b) 441

8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.

1168

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.

1994 to 1995