LICENSEE EVENT REPORT
CONTROL BLOCK: [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 M A Y K R 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 CAT 58
CON'T O 1 SOURCE L 6 0 5 0 0 0 0 2 9 7 1 0 1 2 8 2 8 1 1 1 1 1 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 During Mode 6, the pressurizer code safety valve surveillance test showe
ol3 d that SV-181 lifted at 2569 psig and SV-182 lifted at 2576. The require
0 4 d set pressures are 2485 psig and 2560 psig respectively (T.S.3.4.3). Th
e Main Coolant System safety limit pressure of 2735 psig would not have
old been exceeded as a result of this condition. A similar occurence was rep
orted as LER 81-15. There was no adverse effect on the health and safety
ols of the public.
SYSTEM CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBC
The cause of this event is attributed to setpoint drift. The valves are
[1] 2 inch Mod. 1719 WA. The lift pressure setpoint of each valve was adjust]
[1] ed to specification. No further corrective action is deemed necessary at
1]3 this time.
1 4 L 7 8 9
FACILITY STATUS SPOWER OTHER STATUS (30) METHOD OF DISCOVERY DESCRIPTION (32) 1 5 H 28 0 0 0 0 29 NA B 31 Notification from Test Laboratory 7 8 9 10 10 12 13 13 44 45 46
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36) NA PERSONNEL EXPOSURES AMOUNT OF ACTIVITY (35) NA 44 45
1 7 NUMBER 0 37 Z 38 OESCRIPTION (39) 7 8 9 PERSONNEL INJURIES 13 80
1 8 0 0 0 0 40 NA NA NA
LOSS OF OR DAMAGE TO PACILITY 43 TYPE DESCRIPTION NA NA NA
PUBLICITY SSUED DESCRIPTION 45 NA S PDR NRC USE ONLY SSUED DESCRIPTION 45 NA S PDR NRC USE ONLY SSUED DESCRIPTION 45 NA S PDR NRC USE ONLY SSUED DESCRIPTION 45 NR
NAME OF PREPARER Donald A. Rice PHONE (413) 625-6140