



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

November 5, 1982


Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-039/03L-0
ER 100450 FILE 841-23
PLA- 1385

Docket No 50-387
License No NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-039/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.c, in that the bypass valves around the containment atmosphere particulate monitors were inadvertently left open.


H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

cc: A. Schwencer
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655