

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Title: Region IV and V Event Reporting Workshop
Docket No. Volume II

LOCATION: Arlington, Texas

DATE: Friday, November 9, 1990 PAGES: 144 - 242

9102210063 901109
PDR MISC
9102210063 PDR

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

*RF02
0/11*

200013

1 U. S. NUCLEAR REGULATORY COMMISSION

2 - - - - - x

3 REGION IV AND V EVENT : VOLUME II

4 REPORTING WORKSHOP :

5 - - - - - x

Champions I Ballroom
Sheraton CentrePark Hotel
Arlington, Texas
Friday, November 9, 1990

6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

The above-entitled matter commenced at 9:00 a.m.

NRC SPEAKERS AND PANEL MEMBERS:

- JOHNS JAUDON, Deputy Director, DRS, Region IV
- PAT GWYNN, Deputy Director, DRP, Region IV
- JACK CROOKS, Trends and Patterns Anal. Branch, AEOD/HQ
- EDWARD JORDAN, Director, AEOD/HQ and Chairman, CRGR
- BOBBY FAULKENBERRY, Deputy Regional Administrator Region V
- MARK WILLIAMS, Chief, Trends and Patterns Anal. Br., AEOD/HQ
- ERIC WEISS, Incident Response Branch, AEOD/HQ
- STU RICHARDS, Chief, Reactor Projects Branch, Region V
- AL CHAFFEE, Chief, Events Assessment Branch, NRR/HQ
- NANCY ERVIN, Safeguards Branch, NRR/HQ
- JOAN HIGDON, International Safeguards Branch, NMSS/HQ

C O N T E N T S

		PAGE
1		
2		
3	Current Rulemaking/Guidance Revision	
4	Jack Crooks	147
5	Discussion on 50.73 Reporting	155
6	Safeguards Events (10 CFR 73.71)	
7	Nancy Ervin	207
8	Joan Higdon	223
9	Discussion on 73.71 Reporting	228
10	Summary Discussion	231
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		

P R O C E E D I N G S

9:00 a.m.

1
2
3 MR. WILLIAMS: If you'll take your seats, we will
4 begin. Last night they disassembled the room, so if you had
5 anything left in the room, it's not here today.

6 They took the name tags for the panel, among other
7 things, so we'll have to identify ourselves in advance of
8 the questions. Standard procedure. You will do the same.
9 We have a new reporter today.

10 Today we'll cover two areas. Jack Crooks will
11 begin on 50.73. Jack really is going to cover the outlying
12 areas and reporting requirements that drew our attention and
13 he'll talk about some of the generic results of what's
14 coming into the NRC in terms of LERs.

15 Then we'll have a panel discussion and then move
16 along to the safeguards events discussion after a break, and
17 a panel discussion on that.

18 With luck, if we meet all our goals, we'll be able
19 to finish each panel discussion and we might be able to
20 leave about 11:30 today.

21 Does anyone have any questions, burning questions
22 that they'd like to bring up before we start today's
23 session?

24 [No response.]

25 MR. WILLIAMS: Okay. With that, I'll introduce

1 Jack Crooks.

2 STATEMENT OF

3 JACK CROOKS

4 MR. CROOKS: Good morning. Can you hear all right
5 in the back.

6 [Affirmative responses.]

7 MR. CROOKS: What I'll be doing is providing you
8 with some background information that hopefully will aid in
9 our discussion. Then what I'm doing is, I will be covering
10 some of the areas the staff is considering making changes
11 in.

12 We said the other day we don't use numbers. In
13 this case I'm going to use numbers to try to give you an
14 idea of what's been reported under each of the reporting
15 criteria. It also gives you a flavor of what the results
16 would be of our proposed minor rule changes.

17 Some of this information, if you're interested in
18 more detail is also covered in the AEOD Annual Report for
19 1989, which is NUREG-1272, Volume 4, No. 1. This
20 information comes from that source.

21 The information that I am presenting, again, gives
22 kind of a broad perspective of what's come in under the
23 various reporting criteria.

24 It does not convey anything regarding significance
25 of events. That's been discussed before. We're looking at

1 that on an individual event basis and also on an aggregated
2 event basis.

3 So the pie charts and tables merely represent
4 percentages of what's coming in under each reporting
5 criteria.

6 If we could move on to the next slide.

7 I'll be covering, then, the basic nature of what's
8 coming in through each category. I'll get into the ESF
9 actuations specifically, and also tech spec violation areas
10 specifically.

11 May I have the next slide?

12 The points that I want to make on this second
13 slide, you'll see that the technical specifications area and
14 the ESF reporting area are bringing in about 80 percent of
15 the information that's coming in on LERs.

16 Reports addressing the items that impede the
17 fulfillment of a safety function are about ten percent of
18 what's being reported.

19 Reports addressing plants being degraded or in an
20 unanalyzed condition are nine percent.

21 Reports addressing common mode failure related
22 events are about three percent.

23 Internal and external threats combined are less
24 than one percent.

25 We haven't received any reports that have come in

1 under the criteria of airborne releases or liquid releases.

2 In total, in 1989 there were about 2375 LERs.

3 Go on to the next slide.

4 This pie chart gives you an idea of the various
5 systems that have reported under ESF actuation reporting.
6 The percentages here represent the percent of the number of
7 actuations, as opposed to the number of LERs received.

8 If you look, you'll see that reactor protection
9 system actuations accounted for 23 percent; HVAC systems, 28
10 percent; and the RWCU, 8 percent.

11 Now, some other things that we've looked at over
12 the years has been when are these things occurring. About
13 half of the events have occurred during operations. About
14 another third occurred during testing and the remainder were
15 identified during maintenance.

16 The trend over the years has been that there are
17 fewer actually occurring during operations.

18 The RWCU and the HVAC areas, as we mentioned
19 earlier, are two particular areas that we were looking at or
20 making minor rule changes to reduce reporting in this area.

21 Go to the next slide, please.

22 Here I present information on numbers of LERs
23 involving ESF actuations that were not associated with RPS
24 actuations. We had a total of like 609. There were like
25 1350-some actuations or system isolations reported in those

1 LERs.

2 That shows that the number of LERs that involved a
3 single system ESF -- In other words, it would be an LER
4 that was addressing just a reactor water cleanup system
5 isolation or a control room vent system isolation or some
6 other single system.

7 With better than two-thirds of the total LERs in
8 these categories, of this about three-quarters of that were
9 unneeded. By "unneeded," we define that as actuations where
10 the measured parameter was not exceeded. Therefore it
11 didn't reach its setpoint band and didn't actuate the ESF.

12 These would be the ones that were caused by
13 personnel error, some caused by loss of power supply, some
14 other problem other than the system measured parameter being
15 exceeded.

16 Then I just further broke this down into the HVAC
17 systems and the RWCU, again just to give you an idea what
18 the impact would be from a change in the reporting
19 requirements in this area.

20 Go to the next slide, please.

21 We further broke down the LERs involving single
22 ESF actuations for HVAC. In this area you can see that
23 those specifically involving the control room were about 77
24 and about 66 of those were unneeded.

25 The thrust of the last two slides is that if we go

1 through with the minor rule changes, probably the impact
2 will be to reduce reporting in the range of 100 to 150 LERs.

3 Go to the next slide, please.

4 This slide merely breaks down in general terms the
5 content of the LERs or the criteria that the LERs have been
6 coming in under on the technical specification violations.

7 Three-quarters of these involve exceeding the
8 action statements in LCOs or exceeding some limiting
9 condition for operation, such as range of temperature
10 change, things in that area.

11 The remaining quarter came under variances from
12 surveillance tests, failures to perform the tests on time or
13 items that were related to surveillance tests.

14 Go to the next slide, please.

15 People have been interested in what staff
16 initiatives have taken place over the years regarding LER
17 reporting because we do view it and have viewed it as kind
18 of a living type thing where we're looking at what's coming
19 in and trying to see, well, okay, what improvements can we
20 make.

21 The initial things have been discussed. They were
22 the issuance of the NUREG-1022, which I'm sure all of you
23 are aware of and have been using for guidance. This, plus
24 the original Federal Register notices that were associated
25 with the rulemaking are really the bases for making many of

1 the interpretations in the rule.

2 The next document that was issued was NUREG-1022,
3 Supplement 1 and, again as was mentioned, there were
4 workshops held in late '83.

5 This captured specific answers to specific
6 questions that were asked at those workshops, so that there
7 was a particular focus on questions that were raised by the
8 industry and by licensees at that time.

9 Then there was another document, NUREG-1022,
10 Supplement 2, which was issued in 1985, that provided the
11 results of the review of a sampling of LERs after the first
12 year that the new rule was in place.

13 I don't know how many of you were familiar with
14 that. I know some people have used it. It provided
15 guidance primarily on the content of the LERs.

16 It was an effort that occurred before, what Mark
17 had talked about, where between '86 and '87 we were looking
18 at a larger sample of LERs to see how the quality of the
19 content of the LERs was stacking up against the reporting
20 requirements.

21 So those were the initial efforts. There was an
22 effort in '87 also where the staff gave consideration --
23 There was a mention that -- In creating the rule we found
24 that there was a lot of train level information that was
25 needed for probabilistic risk assessment purposes, and also

1 some other efforts that were trying to focus on risk
2 significant system and component concerns.

3 So the staff had developed a proposed rule at that
4 time that would have brought in basically a monthly
5 reporting on train level unavailability.

6 In that reporting we would have been asking for
7 system, sub-system, component involved, duration of train
8 unavailability for each event, and this would have included
9 unavailability for all causes: Preventive maintenance,
10 corrective maintenance, equipment failure, personnel error,
11 et cetera, as well as the corrective actions that were being
12 taken to improve on train unavailability.

13 The thrust of this is, there still were studies
14 going on related to what was the equivalent system
15 unavailability, because at times the combined train
16 unavailabilities appeared to be exceeding what anyone had
17 expected.

18 At the same time that we had the train level
19 reporting under consideration, we also had looked at
20 reducing the current reporting under the rule in the
21 engineered safety features actuation area.

22 What we have looked at here was a reduction in the
23 reporting such that when the systems were not required to be
24 operable, we could --individual event reporting of unneeded
25 actuations would be reduced.

1 We did try to make some provisions for if there
2 was a high frequency of this type occurrence, that there
3 would be a periodic reporting, be it monthly or quarterly.

4 We didn't fully develop that but it would have
5 probably been send an LER in once a quarter that addressed
6 in content all of the information that we needed for these
7 ESF actuations.

8 This proposal, for a number of reasons, did not
9 make the proposed rule stage in mid-1980.

10 Go to the next slide, please.

11 The current initiatives that we have under way
12 where, again, mentioned several times, we're considering
13 deleting the event reporting requirements for unneeded
14 reactor water cleanup system isolations or control room
15 emergency vent system actuations isolations.

16 We may make some provision, again, where there's a
17 high frequency of these things, and there would be some type
18 of reporting in that area, again be it quarterly -- We're
19 just not sure what the number is or anything, but we felt
20 there may be some value to that.

21 The other thing that we're doing is we are working
22 on preparation of either Supplement 3 to NUREG-1022 or a
23 revision to 1022 that will take into consideration all the
24 issues and the concerns and the questions that had been
25 raised at the four workshops that were just held across the

1 country.

2 From a longer-term standpoint, we also are
3 initiating an effort to look and see that the reporting
4 requirements will be meeting our longer-term needs.

5 In other words, over the last five or six years
6 we've still had the need for operational information for
7 monitoring plant status and feeding back the lessons learned
8 from experience.

9 There also are some other needs that are coming in
10 because of plant aging, life extension, and some of the
11 information ... we just at this time don't have some of that
12 information.

13 So we're looking to see, okay, are we capturing
14 the information that we need. This would be a longer-term
15 rulemaking process.

16 The minor rule changes Mr. Jordan mentioned
17 yesterday, we're talking in terms of months. We also feel
18 that the guidance would be a parallel effort, so that the
19 supplement or revision to the NUREG would come out at the
20 same time as the minor rule change.

21 That concludes what I have to say at this time.
22 So we can go into discussion.

23 DISCUSSION ON 50.73 REPORTING

24 MR. JORDAN: Jack, I think I'd like to raise an
25 issue you mentioned, the needs of the future with regards to

1 reporting.

2 We discussed in the previous workshop on
3 backfitting the benefits of PRAs on a plant-specific basis.

4 I think there is a need in the future for industry
5 and NRC to have information that would lead to an
6 understanding of how well safety systems are performing in a
7 PRA sense.

8 So I think that's a possibility that certainly I
9 will be looking at for future direction of reporting.

10 The NPRDS system does not provide data that can be
11 transcribed or transposed into reliability of systems. We
12 tried that and since you don't have the numbers of starts or
13 the duration of unavailability, so many assumptions are
14 necessary that the value of the information is very poor.

15 So just as maybe a discussion piece, that's an
16 item that I have a long-term interest in. Maybe others on
17 the panel would like to make comments about the overall
18 process.

19 MR. WILLIAMS: We can talk a little bit about...
20 This is Mark Williams.

21 Some of the staff concerns in the past have been
22 the way that rulemaking activity would impact a plant's
23 operations.

24 In other words, when we were considering train
25 unavailability, we wanted train level data, which was

1 something we had given up in the rulemaking we have now.

2 We thought it had to be approached very
3 cautiously. One of the problems that we had was that it
4 would tend to drive preventative maintenance programs in a
5 certain way, because once you tested a train or a system and
6 you had to log as down time all the down time since the last
7 surveillance test, or half of that interval, which is kind
8 of standard practice, that might drive frequencies of
9 testing in an adverse way, making it infrequent.

10 Plus, the other impacts of changing the
11 requirements for reporting or trying to track reliability of
12 systems.

13 We didn't want to have any effect on plant
14 operations that we really couldn't predict well in advance.
15 So we didn't want to do things that we didn't understand
16 very well.

17 So when we do change the requirements and we do
18 propose changes, one of the things that we try to look at is
19 what impact will it have on the way that the plants are
20 operated, assuming that changes are made to have the minimum
21 lock on availability of systems and the like.

22 So we do look at things like that.

23 Anybody have any comments in that area?

24 Unavailability of train is kind of one of the things the
25 staff keeps going back to time and time again for risk

1 assessment purposes and indicators.

2 MR. REEVES: Don Reeves, Nebraska Public Power.

3 You mentioned, Jack, in the near term, the
4 elimination of certain selected ESFs, being the reactor
5 water cleanup and the control room HVAC.

6 Are there any other ESF actuations that were
7 considered? I think you mentioned that there were some
8 other considerations, but were discarded for various
9 reasons?

10 MR. CROOKS: Jack Crooks, AEOD.

11 We did look at other areas and we still are
12 looking at some of the other areas. What we looked at
13 previously was whether or not to do away with or to back off
14 on the system actuations when the system wasn't needed.

15 In Supplement 1 we've said if the system is
16 removed from service, that you -- We provided guidance that
17 you didn't need to report ESF actuations when the system was
18 removed from service.

19 That's still something that we are looking at.
20 The problem is we have found that there are a number of
21 reports that came in under those conditions that did
22 identify things that were of interest.

23 So what we're doing is, ideally we all like to
24 have a fine line. What we're trying to do is narrow the
25 band that exists for interpretation of the guidance.

1 MR. WILLIAMS: There had been an earlier
2 rulemaking -- Mark Williams -- where we had considered
3 eliminating the reporting of the ESF actuations when the
4 system wasn't required to be operable, the reporting of ESF
5 actuations when the actuation was part of a preplanned
6 sequence.

7 What we mean by that, if it's written in the test
8 procedure.

9 And then the elimination of the reporting when the
10 ESF was an unneeded actuation. An unneeded actuation was
11 when a measured parameter did not reach the setpoint band
12 for that parameter.

13 In other words, it was not a valid signal, but
14 we're defining that very closely, because if it was a valid
15 parameter or exceeded the setpoint, it may have been not
16 general radiation area but a local source or something that
17 would get a valid signal. But that would have eliminated a
18 lot of reports.

19 That had some sweeping aspects to it. When you
20 get into some of the very high important systems, like scram
21 breakers and some of the other components, that had some
22 down sides to it.

23 But we did consider those kinds of generic
24 changes.

25 MR. REEVES: We still have in the rule preplanned

1 actuation requirements, but no requirement to report them.

2 MR. CROOKS: Right.

3 MR. REEVES: Let me tell you, something that
4 occurs at Cooper Station on a regular basis is Groups 2, 3
5 and 6 isolations on a scram from power and it turns out
6 pretty much from any power level, full power or during
7 normal shutdown.

8 We currently have no specific statement in our
9 shutdown procedure to alert the operator, if you will, that
10 these group isolations can be expected.

11 It's my intention to go ahead and put those kinds
12 of statements in these particular shutdown procedures.

13 It would then seem to follow in my mind that such
14 isolations would not be reportable in the future.

15 Would you comment on that?

16 MR. CROOKS: If I understand you correctly, you're
17 talking about following the scram?

18 MR. REEVES: Yes.

19 MR. CROOKS: Is it following the scram, the manual
20 shutdown? You are manually shutting down and you reach a
21 level --

22 MR. REEVES: We'll shut down to about 20 percent
23 thermal power and disrupt the unit, instead of inserting the
24 throw rods, which is our normal method of shutting down
25 plant.

1 In those cases we expect anywhere from -- and
2 history has shown we'll get about a 30 to 33-inch shrink in
3 reactor vessel water level. Boom, it's down and it
4 recovers.

5 MR. CROOKS: Right. I think that's consistent
6 with the guidance that's in the statements of consideration
7 explaining that ESF actuations that were part of a
8 preplanned shutdown procedure did not need to be reported.

9 In other words, if we're saying don't report the
10 reactor trip under those conditions, then if there's an
11 associated group isolation, it seems reasonable to me and
12 it's my opinion at this point that those would not need to
13 be reported.

14 MR. REEVES: There's at least one utility that I'm
15 aware of where an individual utility has been given
16 direction by its management to look at system requirements
17 with the plant in shutdown condition and evaluate the
18 feasibility of taking the systems out of service such that
19 if during maintenance or surveillance testing -- not
20 surveillance testing, but most maintenance testing, a
21 spurious actuation that has previously caused the systems to
22 be actuated and resulted in their writing an LER could be
23 avoided.

24 In other words, to look at taking systems out of
25 service and making them unavailable, the sole purpose being

1 to reduce reporting requirement.

2 MR. JORDAN: This is Jordan.

3 That would bother me, because I think you are
4 affecting safety in that context. If the reporting
5 requirements are driving people to do things like that, then
6 there's a problem with the requirements or the way they're
7 being perceived.

8 So the reduction of availability takes away some
9 margins that would bother me a great deal.

10 MR. REEVES: I guess I'm driving back now towards
11 the reporting of the ESF actuations when systems are not
12 needed, which is the case here.

13 I wonder if further consideration can be given to
14 a plant in the shutdown mode and a reduction in the
15 reporting requirements or elimination of reporting
16 requirements for those systems that are not required to be
17 operable in the tech specs.

18 MR. WILLIAMS: This is Mark Williams.

19 What has come up in the past is the significance
20 of certain components in certain systems. That might be
21 okay for some and not okay for others that are very highly
22 significant components or systems.

23 That's what happened last time, because that was
24 exactly our view. You know, we had thought that we should
25 look at eliminating the reporting of ESF actuations when the

1 systems weren't required to be operable.

2 At that time that was part of a packet of stuff
3 that we were moving along. Ultimately, we decided not to do
4 it. There were a number of different things that came up
5 during the process.

6 But we have looked at that. We have considered
7 it. It's an area that's fertile but it's hard to take on
8 generically for all the components and all the systems, all
9 ESFs.

10 MR. REEVES: Is there any discussion of that in
11 any kind of an AEOD document that will be available to the
12 industry for industry review?

13 MR. WILLIAMS: I don't think so.

14 MR. JAUDON: Let me pose a question to you. Johns
15 Jaudon.

16 Assuming that you did not have to report systems
17 that were not needed and they were down and one actuates or
18 the actuation is not proper, you don't get the response you
19 expected.

20 Would you consider that to be reportable? For
21 instance, you had an HVAC actuation, which is sometimes
22 meaningless, and yet the dampers don't operate properly?

23 MR. REEVES: It would depend upon the circumstance
24 under the present rulemaking.

25 MR. JAUDON: I was really asking about the

1 significance, how you viewed the significance of the event.

2 MR. REEVES: Well, we can take the case, for
3 example, of a diesel generator. If we have a diesel
4 generator that fails to start or if we have a diesel
5 generator that fails during surveillance testing, doesn't
6 perform properly during surveillance testing, we don't
7 always, do not automatically report that, if it's only one
8 and if it's not generic.

9 Now, if it's potentially something that's going to
10 affect both diesel generators, an engineering situation,
11 then we would report that.

12 So like I said, it would depend upon the situation
13 at the time.

14 MR. JAUDON: Thank you.

15 MR. JORDAN: We've got some more discussion back
16 here, so let's hear from them and then try to get questions.

17 MR. CHERNOTT: Harold Chernott, Wolf Creek.

18 To kind of switch gears, a question tying together
19 both workshops here. The additional guidance being
20 represented as possibly a revision in NUREG-1022 or another
21 supplement, will that go to CRGR for a review prior to its
22 issuance?

23 MR. JORDAN: Most certainly.

24 MR. CHERNOTT: So it will get a full backfit
25 review prior to issuance?

1 MR. JORDAN: You bet.

2 MR. CHERNOTT: Thank you.

3 MR. GULDEMOND: Mr. Crooks, Bill Guldemon,
4 Comanche Peak.

5 You indicated a significant percentage of the LERs
6 that you're receiving are for tech spec LCO violations
7 and/or surveillance violations.

8 What's being done with this information as part of
9 the tech spec improvement program to examine whether or not
10 these violations are avoidable or that the requirements of
11 the tech specs are perhaps overly restrictive?

12 MR. CROOKS: People in the tech spec groups have
13 that information available and they have looked at it.

14 In fact, there will be an impact from the tech
15 spec group program that more than likely will reduce some of
16 the reporting because they will be changing some of the LCO
17 time requirements.

18 Some of the surveillance testing will also be
19 moving out of the tech specs into supplemental documents.
20 So there clearly will be an impact from the tech spec group
21 program.

22 MR. WILLIAMS: We had done an earlier study of
23 that. For example, we had done a NUREG on all the tech spec
24 violations for three or four years.

25 It turned out that we had done a prioritization of

1 those, high, medium and low, and there was an awful lot of
2 fire protection in there, as you would guess.

3 That was one of the things that went into the pie
4 a couple of years ago, or a few years ago, or three years
5 ago, as the tech spec improvement people were working on it.

6 We had been working with them. We turned out a
7 report. They used that report in their program.

8 There will be an impact from the tech spec
9 improvements on the reporting for tech spec violations.

10 We've also got further guidance coming for the
11 staff in terms of what's a missed surveillance, when that
12 constitutes a tech spec violation and be reportable, and so
13 on.

14 So within the staff, those activities are
15 coordinated, historically.

16 MR. WALKER: A comment, for what it's worth.
17 Roger Walker, TU Electric Company.

18 I've been around a long time and I know and I
19 think you people know a lot of those actions taken were just
20 kind of conservative values, seven days for a pump or thirty
21 days for a pump, and so on.

22 Giving it back to the tech spec improvement
23 program, it should help the industry.

24 I'm up here to ask a different question.
25 Unfortunately, I have to direct you back to the area that

1 you were discussing.

2 Another utility yesterday asked me to ask a
3 question with respect to the guidance put out on ESF
4 actuation to Region II specifically, but I think it's widely
5 distributed in your July 12th memo.

6 It's a two-part question, so I'll bring it out
7 just to get it on the transcript.

8 "In that memorandum providing guidance you stated
9 that if for any reason ESF components are caused to operate,
10 except expected responses from testing, then an ESF
11 actuation did occur and that the quantity of circuitry
12 subject to the signal or the reasons for the actuation are
13 immaterial.

14 "Individual contacts, relays and other components
15 in an ESF logic circuit can be considered ESF components.

16 "Did you mean by that that licensees should report
17 the operation of an individual contact without completion of
18 the minimum ESF actuation logic, such as a half scram?"

19 I think I know the answer to this, Mark, but I'll
20 let you answer it.

21 MR. WILLIAMS: Yes, a half scram is not a
22 reportable thing. In multi-train systems, we have guidance
23 on the street. So I think the answer to your question is
24 no.

25 MR. WALKER: I gather what your intent was, I

1 think, that the system got off for some reason and didn't
2 perform.

3 Let me ask a second part of the question, since
4 your answer was no.

5 It's more statement from the utility. "Certain
6 ESF components, such as contacts, relays, pumps and valves,
7 are shared between the normal functions of a plant and the
8 ESF functions.

9 "As an example, an ESF signal may initiate control
10 room and primary containment isolation and close some
11 ventilation dampers.

12 "However the same dampers may also be designed to
13 close upon a non-safety-related signal in order to control
14 ventilation for normal operation."

15 I hate reading.

16 "In this example, the non-safety-related signal,
17 not the ESF signal, causes the ventilation dampers to close
18 and no ESF actuations occur, such as control room and
19 primary containment isolation.

20 "Based on your above response..." which was no
21 "...you would not expect the licensee to report the
22 actuation of components if they actuate as designed due to
23 non-safety-related signals and were not the result of a
24 completion of the minimum ESF actuation signal?"

25 I think the answer is yes?

1 MR. WILLIAMS: Under all except some conditions,
2 Some dual function components might be tested in a non-
3 safety mode.

4 What we always focus on and the guidance we've got
5 out is that it's the impact on a safety mode of operation
6 that's important.

7 So if it's a non-safety signal when you're really
8 testing that component for all its functions and it didn't
9 work, then it would still be relevant to the safety mode.

10 For dual function components, if you didn't want
11 to inject and you were testing it in some other mode.

12 MR. HORIN: Just to follow up on that, Roger and I
13 had the same questions. This is Bill Horin from Winston &
14 Strawn.

15 Given your answers there, I guess just to confirm,
16 there is guidance in the supplementary information provided
17 with 50.72 that says with respect to this criteria that,
18 "Actuation of multi-channel ESF actuator systems is defined
19 as actuation of enough channels to complete the minimum
20 actuation logic. Therefore, single channel actuations,
21 whether caused by failures or otherwise, are not reportable
22 if they do not complete the minimum actuation logic."

23 My question on that would be, does that guidance
24 continue to be applicable and valid?

25 MR. WILLIAMS: I think for multi-channel systems,

1 for the answer to the question he was answering.

2 I think we just had a situation where somebody
3 used the same guidance where they had multi-train systems or
4 multi-channel systems and they were trying to use the same
5 guidance in a system configuration.

6 So yeah I would think that would still be
7 applicable for the question you addressed.

8 Jack, did you have a comment?

9 MR. CROOKS: Yes. I think the multi-channel
10 actuations came about -- As Roger had mentioned, they
11 really wrote this in to cover the half scram situation, and
12 also other systems where you require at least two different
13 conditions to be satisfied.

14 If one condition was satisfied and you didn't have
15 the second condition, then you didn't really actuate the
16 engineered safety feature.

17 Is that clear?

18 MR. HORIN: That's clearer to me. I don't know if
19 anybody else has any further questions.

20 MR. CROOKS: That's consistent with this
21 paragraph. Your question came up in Region III.

22 They basically said this paragraph sounded
23 somewhat convoluted because we were using actuation to
24 define actuation.

25 The paragraph itself in the Statement of

1 Consideration probably needed a little bit added to it that
2 would have tied it to this.

3 They really, I think, were specifically thinking
4 in terms of the two out of four RPS actuation, situations
5 like that.

6 MR. HORIN: I think the utility's concern was that
7 that guidance could have been applied if read --

8 MR. CROOKS: Differently.

9 MR. HORIN: If read strictly to, in effect,
10 contradict the guidance that was in the supplementary
11 information.

12 From what I gather, you're saying that no, that
13 guidance in the supplementary information is still valid.

14 MR. JORDAN: Yes.

15 MR. WILLIAMS: We had gone over that response
16 before it ever went out in two offices and we had both
17 concluded consistent with what the earlier guidance was. At
18 least in our view it was.

19 MR. FEIST: Chuck Feist, Comanche Peak.

20 Let me give you a scenario. Let's say we've got a
21 two out of four ESF actuation logic and one channel is out
22 and set to trip. Another channel just fails, doesn't get a
23 true signal, and throws you in an actuation.

24 So one is out and the other has just randomly
25 failed and you get an actuation. Is that included or not?

1 MR. WILLIAMS: Yeah, I would say that's
2 reportable.

3 MR. FEIST: That is reportable?

4 MR. WILLIAMS: In bypassing, you had an actuation
5 come in on the other one.

6 MR. FEIST: I'm confused.

7 MR. WASHINGTON: Steve Washington from Washington
8 Public Power.

9 I'd like maybe a little bit of clarification on
10 the definition of preplanned. I think our definition has
11 been that it must be -- you must know that an actual
12 actuation is going to occur.

13 Yet some testing and maintenance could be taking
14 place which has a high probability of it occurring, say an
15 isolation of an air system. You don't know what the leak
16 off that air system is going to be.

17 Can you write that into your test procedure and
18 say that's a planned actuation?

19 MR. WILLIAMS: This is one of these situations
20 where we really rely on your judgment. Anything that's part
21 of the preplanned sequence, that's written into a procedure,
22 that says check for an actuation of this ESF logic, whatever
23 it is, that's something that's not reportable.

24 Then if it's expected as part of shut down, or
25 whatever it is, and it's written into the procedure, that's

1 not reportable.

2 We have to rely on your engineering judgment to do
3 that. I think, really, we just rely on that in terms of
4 what's going to be reportable and what's not reportable, and
5 you're the engineer on the job, so you're going to make that
6 decision and we are going to get to second guess it.

7 MR. GULDEMOND: Bill Guldemon, Comanche Peak.

8 I think I'm confused. I don't know if I'm wrong
9 in this regard. I guess I've got three questions that I'd
10 like you to answer again, and I'll beg your indulgence in
11 this regard.

12 One is, is the actuation of an ESF component from
13 a non-ESF source, closure reactor water cleanup isolation
14 valves in response to an ion change or high temperature. Is
15 that viewed as a valid ESF actuation under 50.72?

16 Two, the condition that Chuck Feist described just
17 a moment ago where he had failure of a single train. Again,
18 the other train was in a trip condition. Is that considered
19 a valid ESF actuation if you have not gotten to a process
20 parameter setpoint that would cause it.

21 And number three, if you receive a valid ESF
22 actuation signal but the component does not change state,
23 the component, the valve, the pump, whatever it might be,
24 because it was already in a safeguards position, is that
25 reportable?

1 Just to give an example, containment isolation
2 valve already closed when containment isolation signal
3 received. The valve doesn't change state because it's
4 already in a safeguards position.

5 MR. WEISS: I'm not sure that I remember the
6 details of each question, but on the first one where you had
7 reactor water cleanup isolation and its closing due to a
8 process parameter saying that the ionization beds had to
9 be protected from high temperature, that's not an engineered
10 safety features actuation signal.

11 It would be my judgment that that would not be a
12 reportable ESF item.

13 Let's see. The last one was, you had....

14 MR. WILLIAMS: The second was one train was --I
15 think the answers, if I remember, is no, yes, yes.

16 MR. WEISS: That's what I remembered, too.

17 MR. GULDEMOND: The question was, if you have one
18 channel in trip, and you receive a failure in the second.
19 In other words, you do not receive a valid initiating signal
20 from the process parameter, yet an actuation occurs.

21 MR. WEISS: Yes. The answer to that is yes. Let
22 me give you a dramatic example.

23 An MSIB goes closed because you've got one channel
24 in trip and you get a spike somewhere at a sensing logic
25 because somebody is out doing a surveillance.

1 Can you imagine us not being interested in that?

2 No, we'd definitely be interested in that.

3 So the answer to that question is yes.

4 And the third one?

5 MR. GULDEMOND: The third one was if you have a
6 valid actuation signal but the component that is to be
7 actuated is already in the safeguards position.

8 A closed containment isolation valve receives a
9 containment isolation signal. Is that considered a valid
10 PSF actuation?

11 In other words, how far does the actuation have to
12 be processed and action occur before specifically --

13 MR. WEISS: If you get a scram signal and all
14 routes are involved, that's typically been reported in the
15 past. You get an MSIB closure signal and MSIBs are already
16 closed, those are typically reported.

17 My personal view on that is that that's required
18 by the regulations as they now stand, yet it's fertile
19 ground for an amendment to the regulations.

20 MR. REEVES: Don Reeves, Cooper Station.

21 I want to clarify again ESF actuations, reporting
22 of ESF actuations for a non-ESF segment.

23 I think that the guidance that we had previously
24 received at the utility and the guidance that I thought
25 existed in the letter that went back to Region II, was that

1 any ESF component that is actuated -- The situation that
2 causes an ESF component to actuate is reportable.

3 MR. WEISS: That's right.

4 MR. REEVES: Is my reading of that incorrect?

5 MR. WEISS: He had a dual function. He had a
6 different case.

7 You see, this is one of the dangers of providing
8 specific answers to specific questions. We provide a
9 specific answer to a specific question under a specific set
10 of circumstances, and then somehow that's drawn out more
11 broadly.

12 That can be done with almost every answer we've
13 given today. We told you that if you have a preplanned
14 sequence, it's not reported.

15 That does not mean that you can go out and write
16 in whenever a LOCA occurs, anticipate that you're going to
17 get low pressure coolant injection, and therefore say that
18 the LOCA is not reportable because it was a preplanned
19 sequence. When we have a LOCA, we have a low pressure
20 coolant injection.

21 You can make overly broad the specific
22 interpretations that we provide and I'm very uncomfortable
23 in workshops when people give me a very brief description of
24 a specific example that's on the borderline, and then I'm
25 asked to provide a broad answer for it. It's very difficult

1 to do.

2 It's much better if what happens back in the
3 office occurs. That is, we sit and we discuss the thing for
4 20 or 30 minutes. We get all the details on the table. We
5 have applied all the criteria. We see whether any other
6 criteria apply, and then we provide a specific answer.

7 It happened in the last workshop that when we got
8 into the discussion, in Region III, about what was the
9 purpose of the reporting, that an attorney, I believe it
10 was, got up and asked me why I was asking them to think in
11 cosmological terms, on the one hand, all kind of vague and
12 nebulous, and then I'd get very specific on the other.

13 It seemed contradictory to him and the point of it
14 was, that if you kept in mind what we're trying to
15 accomplish, it will help you understand our specific
16 interpretations.

17 For example, we just gave an answer to Mr.
18 Guldemon about when you had one channel in trip and you had
19 a spurious signal, whether that was reportable, and we said
20 yes.

21 My specific response was, could you imagine NRC
22 not being interested in an MSI² going close to power because
23 you had one channel on trip and another channel was made up
24 spuriously.

25 There is a good example of how, if you think about

1 what the NRC is driving at, you'll get the answer to your
2 question.

3 So on reactor water cleanup, can you imagine
4 anybody in the NRC being interested in the fact that the
5 resin beds are protected from high temperature? No.

6 But if, on the other hand, you have an ESF
7 actuation, for whatever reason, a guy sweeping the control
8 room happens to catch a lever with his sleeve and all rods
9 go in or all MSIBs close.

10 Yes, even though that was not a preplanned
11 sequence, even though that is a spurious thing, we would be
12 interested in that.

13 On the other hand, you know as well as we do that
14 there are many things that just don't constitute big safety
15 problems, spikes at various times, and we're thinking about
16 how to eliminate those sorts of things from the regulation,
17 without throwing out the baby with the bath water, without
18 throwing out what you and I know as engineers are safety
19 significant items.

20 MR. REEVES: The reason I brought the question up,
21 and I don't mean to be facetious in my response, is that
22 this was the first instance in discussing ESF actuations
23 that I've heard that a non-ESF signal may not be reported.

24 As I say, in previous guidance to us as a utility
25 and what I thought was the guidance provided in that letter

1 going back to Region II was that actuation of an ESF
2 component is reportable.

3 MR. WEISS: That's only for the dual function
4 component.

5 MR. REEVES: That was not understood in that
6 letter.

7 MR. WEISS: No, it wasn't addressed in that
8 letter.

9 MR. REEVES: No, it was not.

10 MR. WEISS: But the thesis, the thing that
11 prompted that letter, the thesis was that you did not have
12 to report -- The utility contended that you did not have to
13 report engineered safety features actuations in those
14 circumstances where the complete logic sensor and component
15 did not function, and we just can't live with that.

16 Can you imagine, for example, you having a reactor
17 scram called for, picked up by the sensor, the logic picking
18 up, and the trip breakers failing to open.

19 Can you imagine NRC not being interested in an
20 ATWS? I mean, it just doesn't make sense. If you keep in
21 mind what we're after, you're going to get the specific
22 answer to your question.

23 So in general, we are interested in engineered
24 safety features actuations, regardless of where they occur,
25 and there are some exceptions. And one of the exceptions is

1 where it's totally trivial from a safety point of view.

2 If you have a dual safety function in a reactor
3 water cleanup isolation valve going closed, and if it's for
4 a non-safety purpose, we're not all that interested in it,
5 which is not to say that if in the process you discover a
6 generic problem associated with pipe cracking or a valve not
7 closing against pressure, we would be very interested in
8 that.

9 Suppose, for example, that that valve goes closed
10 to protect the resin beds and it fails to go closed because,
11 you discover, there's a design problem with the valve, a
12 maintenance problem. We would be very interested in it
13 because it would have direct implications for safety.

14 When that valve was called to go closed for a
15 safety reason, it would fail to go closed, and we would want
16 to know about that ahead of time.

17 We would want to inform all the other plants so
18 that they could have proper LOCA mitigations if they get a
19 rupture in that system.

20 MR. JORDAN: This is Jordan.

21 I want to comment on the value of the workshop in
22 collecting these kinds of instances that remain fuzzy. Even
23 after we've given our best shot, they remain fuzzy and there
24 is a need for us to sweep the correspondence that's been
25 provided to utilities into a revised guidance document.

1 But we're going to try to keep it as simple and
2 practical as possible, because if you get a guidance
3 document that's a foot thick, you're going to be worse off
4 than you were before.

5 So I want to try to keep with the philosophy and
6 one of the philosophical things I like is, is it of value to
7 you to know about with respect to another utility.

8 Maybe you learn something from another utility, if
9 that information comes to you through the NRC and input
10 process of reviewing LERs and extracting lessons from them.

11 To me, that's the bottom line. Do you think it
12 might be of value to others, component level failure or a
13 system level failure?

14 The whole thing is about feedback of operational
15 information in the context we're talking about here. It's a
16 long way from emergency response type events.

17 We're really talking about longer-term reviews and
18 extracting lessons and then feeding them back.

19 MR. HORIN: Let me just ask a brief question.
20 Chuck then has some more specific questions.

21 Getting back to this guidance memo, I think
22 perhaps where the confusion is arising is that there is a
23 very broad statement that is reportedly quoting the Region
24 II position, and then the statement is made that OEAB agrees
25 with this position.

1 I think what the problem that people are facing is
2 that if you read that broad statement and try to apply it to
3 some of the other circumstances beyond what was involved
4 here, you get into confusion.

5 I think what I heard you mention a second ago, and
6 I just want to confirm it is that really this memorandum was
7 focusing on a particular circumstance that utility was
8 facing and the very narrow position that that utility had
9 taken, and wasn't intended to try to apply to all other
10 issues that may arise in this area.

11 MR. JORDAN: You're right on. Exactly.

12 MR. WILLIAMS: Incidentally, Chuck, they had taken
13 a specific position on what constitutes the actuation of an
14 ESF.

15 You need all three elements of the ESF in order to
16 have a valid ESF actuation, and the staff very, very quickly
17 came to a consensus that the staff has agreed with that
18 generically as a position.

19 On the other hand, case-specific things that we've
20 talked about here still exist in the present regulatory
21 guidance, but our answer was the position put forward by
22 Georgia Power in that letter.

23 MR. HORIN: So licensees shouldn't try to read
24 this in other areas, such as what we've been talking about
25 today, and instead should still deal with those on a case-

1 by-case basis consistent with the guidance that's out there.

2 MR. WILLIAMS: You just have to take what value
3 that provides for that case.

4 MR. FEIST: Chuck Feist, Comanche Peak.

5 On this dual function question, see if I can
6 understand. The feedwater steam mitigation line looks and
7 acts a lot like feedwater isolation valve.

8 So what you would say is if we had a feedwater
9 actuation with a non-safety logic that actuated the
10 feedwater isolation valve and everything worked normally,
11 that wouldn't be reportable, but if the feedwater isolation
12 valve didn't close, that is something that is.

13 Is that understanding the way you interpret that?

14 MR. WILLIAMS: My first answer to the question is
15 that it would be reportable, but I'll have to sit down and
16 think about it. Maybe it's not, and rather than give you a
17 quick answer to that, I would have to look at it carefully.

18 MR. CHAFFEE: Wouldn't that be part of your
19 feedwater isolation --

20 MR. FEIST: I can't hear you.

21 MR. CHAFFEE: Can you hear me now?

22 It seems to me that the reportability of that
23 would probably depend if the feedwater isolation is starving
24 your generators and causing a trip, clearly I would think I
25 would want to know about that.

1 It depends. You have to take into context what it
2 does to the plant.

3 MR. FEIST: Well, the actuation doesn't starve the
4 steam generator. The first water -- the upper nozzle or the
5 main nozzle --

6 MR. CHAFFEE: I can't hear you.

7 MR. FEIST: It doesn't -- Starving the steam
8 generator doesn't cause -- It starts off feedwater pumps
9 and diverts feedwater into a different nozzle.

10 This kind of thing only happens during startups
11 and shutdowns.

12 MR. CHAFFEE: So it would only happen at the time
13 of shutdown?

14 MR. FEIST: You could be at low power. You could
15 be in mode two.

16 MR. CHAFFEE: I guess I don't understand quite
17 what you're saying. You have to take the event in total and
18 look at what particular --

19 MR. FEIST: If the non-safety signal works
20 normally as it's designed and all the equipment works
21 normally, that would not be reportable?

22 MR. JORDAN: I don't believe it would be
23 reportable. So I agree with you.

24 MR. FEIST: But if something, one of the ESF
25 components didn't work, then that would kick it in.

1 MR. JORDAN: Yes.

2 MR. FEIST: That's what I was driving at.

3 MR. JORDAN: Right.

4 MR. FEIST: Thank you.

5 MR. JOHNSON: My name is Alan Johnson and I'm with
6 Arizona Public Service.

7 I want to change the subject a little bit.

8 I think, at least on my part, I really more
9 understand your July 12th memo now and feel more comfortable
10 with it, because it really could be interpreted rather
11 broadly.

12 I want to change it. Earlier you mentioned that
13 you were looking at -- This for Jack Crooks. You were
14 looking at eliminating reporting of control room
15 ventilation.

16 Are you considering expanding that for generic
17 ventilation? In our case we have a fuel building
18 ventilation, which is the exact same thing, that we would
19 like to see taken out of the rule also in a similar fashion.

20 MR. CROOKS: We started into that area. I'm not
21 sure right -- We haven't come up with the final words.

22 Right now the focus is on the control room
23 emergency vent systems.

24 MR. JOHNSON: Then the other question I have is,
25 as mentioned in the last workshop at King of Prussia, and I

1 haven't heard anything back about it, but the question on
2 previous similar events.

3 There's a requirement in there to basically
4 analyze previous similar events, why they occurred. Are you
5 looking at limiting the time frame we have to go back?

6 Some of us are getting into a situation on an
7 event that happened six years ago and explain why the
8 corrective action for that event didn't prevent this one.
9 It serves no purpose.

10 MR. CROOKS: This came up in Region III also. I
11 think in Region III we indicated that you have a history and
12 what would be expected would be to go back a reasonable time
13 to see if a previous occurrence was related.

14 People are saying you sometimes have a 20-year
15 history. We didn't expect you to go back. If there had
16 been 30 previous occurrences, presumably somewhere in there
17 things were changing.

18 So what you do would be to go back and take the
19 part of that history that would apply to the event that
20 you're reporting.

21 I don't know whether that -- We haven't drawn a
22 line. Something that is on the record we certainly can look
23 at with the new guidance.

24 MR. JORDAN: What you're really saying is, use
25 judgment at this point. There isn't a statute of

1 limitations that we've expressed one way or the other.

2 So it is an area of discretion on your part. And
3 let me warn you. If we take away your discretion, the
4 regulation and the requirements become larger and more
5 voluminous.

6 I think in most cases you're better to have your
7 discretion and to apply it. You may get second guessed but
8 it's certainly not going to be an issue regarding
9 enforcement.

10 How far back you go is based on your own
11 conscience and certainly with respect to system
12 modifications.

13 Where a system no longer has a problem that it had
14 ten years ago, the statute of limitations has run out on
15 that one. You don't have to go back that far.

16 So I would urge you to keep the discretion. If
17 there's a real problem, then we'll try to provide more
18 guidance, but the guidance I would provide right now, even
19 within the revision of 1022, is the utility should use
20 judgment on how far back to go.

21 I would like to hear argument from you as to
22 whether you would prefer having more specific guidance.

23 VOICE: No.

24 MR. JORDAN: Okay.

25 MR. REEVES: Eric, I want to respond directly to

1 you on your comment that you would be interested in a valve
2 situation, the situation being an ESF component is given an
3 actuation signal from a non-ESF segment and fails to close
4 or fails to actuate.

5 You would not be interested in the former; i.e.,
6 the fact that an actuation signal was given from a non-ESF
7 component -- or a non-ESF segment.

8 But you would be interested in the situation that
9 the component did not function as it was intended to
10 function.

11 I guess my comment is, we would report that, if it
12 met the criteria of the rule. It just would not be an
13 automatic report.

14 For example, if it was an isolation valve that
15 failed to go closed and it was the second isolation valve on
16 the line and whatever caused this one valve not going closed
17 would not affect the second one, we'd not report it.

18 If it was a pump that failed to start, we'd not
19 report it if we had a redundant pump on the system.

20 MR. WEISS: Single random component failures are
21 not reportable under the rule.

22 MR. REEVES: That's just the criteria we'd be
23 applying.

24 MR. WEISS: The rule, however, says that if you
25 have something generic, it says in the Statements of

1 Consideration -- Remember my presentation yesterday.

2 MR. REEVES: Right.

3 MR. WEISS: The Commission emphasized that if you
4 have something of generic significance, the licensees are
5 encouraged to report those things.

6 So the point I was trying to make, and maybe it
7 didn't come across too clearly, that if you find that a
8 failure of a component was due to a generic cause --

9 MR. REEVES: That word didn't apply here, talking
10 about generic cause.

11 MR. WEISS: Why is that?

12 MR. REEVES: Well, as opposed to a single random
13 event.

14 MR. WEISS: A single random event is not
15 reportable. Something that has generic safety significance
16 that would be of interest to other plants so that they could
17 prevent accidents from happening would be reportable.

18 So for example, you find out that a reactor water
19 cleanup system isolation valve that was supposed to close
20 and protect the resin beds for a non-safety reason, well, it
21 failed to close because of a generic reason, because there
22 was a design defect, a manufacturing defect, or for whatever
23 reason, that's important for another plant.

24 They may have a loss-of-coolant accident that
25 occurs in their reactor water cleanup system and the

1 isolation valve between the cleanup system and the RCS fails
2 to function for the same reason, because they have the same
3 defect in that valve.

4 You can imagine that we would have expected you to
5 have told us about your discovery.

6 MR. REEVES: We would agree and I don't think
7 anyone in this room would have disagreed with reporting that
8 situation.

9 I have one other comment that seems to be a very
10 common thread that folks are making. Frankly, I think most
11 of us in this room like the free and open exchange of
12 information with the NRC and with AEOD and being able to
13 report these things that are going on, in some cases
14 regardless of safety measures.

15 The reality is that we, in cases where we choose
16 not to report, we are under the threat of enforcement, or
17 feel to be under the threat of enforcement.

18 When we're in that position, we're going to try
19 to -- I think I can speak for a number of people. We try
20 to adhere to the rule as closely as we can so we meet the
21 requirements of the rule.

22 That hinders the open exchange. I don't know what
23 can be done to get beyond that kind of philosophy.

24 MR. GWYNN: I'd like to comment. Pay Gwynn from
25 Region IV.

1 If you feel under the threat of enforcement
2 because of a specific item that you haven't reported, then
3 I'd suggest that you discuss that with the NRC and we will
4 help you to make sure that you have made the correct
5 judgment.

6 I think if you look at the enforcement statistics
7 for the Agency with respect to taking enforcement action for
8 failure to report, that you'll find that that's not a very
9 large number of violations in the recent history of this
10 Agency.

11 MR. REEVES: Unfortunately, Nebraska Public Power
12 District was subject to enforcement action at one time, so
13 we are very conscious of that type situation.

14 MR. GULDEMOND: Bill Guldemond, Comanche Peak.

15 During backfitting discussions and some of the
16 discussions yesterday I think there was a consensus reached
17 that we need to maintain an open forum with regard to a
18 variety of issues, reporting being one.

19 There was some discussion yesterday about how to
20 go about getting questions on reportability answered when we
21 have a specific situation that's unclear.

22 The conversations were saying, talk to residents,
23 talk to the region, talk to the AEOD.

24 My question is, what is your preferred method for
25 receiving questions and processing those questions? Is the

1 preferred method to start with the resident or to go to the
2 region or AEOD?

3 What is your preferred method of communicating?

4 MR. JORDAN: The preferred method is with the
5 resident of the region with an NRR. AEOD in this process
6 doesn't have a real regulatory role.

7 We would be advisory. I'll open something that
8 we've discussed internally with NRR, is establishing a panel
9 that would combine advice that would include a general
10 counsel representative, an AEG representative, an NRR
11 representative and a regional person.

12 That would then try to keep 1022 alive and current
13 by extending the guidance that's in it, after we revise it,
14 and serve as an advisory panel to the rest of the Agency.

15 It wouldn't be for utilities to contact directly,
16 but where there's a controversy, it would go to that kind of
17 a panel.

18 So that's something that we're thinking about more
19 than just a fine idea, but not yet a reality. I think it
20 would help you that there would always be a group of people
21 with some corporate memory that would be able to then give
22 advice.

23 But clearly, contact is with the region and NRR,
24 if enforcement.

25 MR. GWYNN: I'd like to add to that. Typically

1 what you'll find is that the resident inspector will act as
2 a conduit with the region and we will look at the matter to
3 see if in fact the Agency has substantial experience in that
4 area.

5 If we can, we'll answer the question based on the
6 Agency's experience, and if we can't, we will get NRR
7 involved in the conversation directly and get whatever help
8 we need from headquarters.

9 MR. JORDAN: I'll admit to one thing. Whenever
10 there is an egregious event, in my view, that the Agency
11 really needed to know about promptly, and I find out about
12 it through some sideways means a week after it happened and
13 the Agency wasn't informed, then I go to the region and say,
14 "Why didn't we get this report?"

15 The region will go back to the utility with that
16 and we do it with correspondence. So I'm not putting
17 anything in an enforcement type reaction.

18 But those are for what I would say egregious cases
19 that are one or two a year.

20 In most cases -- I would say in all cases where
21 there's judgment, where these are in fuzzy regions, those
22 are talked about. They are a matter for discussion.

23 MR. HANCE: Doug Hance, Gulf States Utilities,
24 River Bend.

25 I'd like to change the subject a little bit. This

1 is the issue of type of discovery.

2 We were engaged in a predicted maintenance
3 activity some time ago and identified a condition as a
4 result of this activity.

5 Later on we tore the component down and went into
6 an outage. We found there was nothing wrong with it.

7 If that situation had gone the other way and we
8 had found that the valve was inoperable, how would you apply
9 time of discovery in situations like that?

10 MR. WILLIAMS: The same way that the tech spec
11 people do. Pretty much exactly the same way.

12 Make your operability judgment on a component.
13 Now, if you're going to tear it down, once you've arrived at
14 the engineering judgment that the component probably would
15 not have performed its function.

16 But then, again, if you have a vibration or
17 whatever it is and it's enough to make the call initially,
18 then that would be the time of discovery. It's when the
19 judgment was made.

20 MR. HANCE: It's a matter of engineering judgment
21 as to when the component would be declared inoperable?

22 MR. JORDAN: Yeah, your judgment.

23 MR. WILLIAMS: That's right.

24 Mr. GULDEMOND: Bill Guldemond, Comanche Peak
25 again.

1 Rather than ask a question, I'd like to offer an
2 observation with regard to the impacts of some of the
3 reporting. That observation being that it has not been
4 uncommon in our experience when a more significant event
5 occurs and is reported by one of the mechanisms available
6 for us to receive multiple points of contact from the NRC,
7 from the resident inspector, the region, the NRR project
8 manager and occasionally other offices.

9 It would be beneficial to us, and I think to you,
10 if there were some way to channel those communications
11 through a smaller group of people, not only because from our
12 personal perspective it would be less of an impact on our
13 resources, but on your perspective we think it would aid the
14 correct flow of information so that we didn't get
15 inconsistencies.

16 I offer that only as an observation for your
17 consideration.

18 MR. FAULKENBERRY: I would like to address this
19 just a little bit and I'll ask Stu and maybe some other
20 people to address it.

21 We have had problems in the past with regard to
22 this and it shouldn't happen. We shouldn't bug you people
23 with telephone calls and we shouldn't have half a dozen
24 different people calling you and asking the same questions.

25 It's a problem. It's a very difficult problem to

1 resolve. I think we have made some progress in that area.

2 What we will encourage, of course, is to do your
3 one-hour reporting and report through the headquarters duty
4 officer, et cetera, and inform the resident inspector.

5 What we at the region will try to do -- It won't
6 always happen but we certainly are conscious of it and we
7 really try to do it very hard -- is to work through our
8 resident inspector and try to get the information from him.

9 So that is the point of contact. He is trying to
10 ferret out the information and get it back to us.

11 Sometimes we have a problem. Sometimes either our
12 resident inspector is gone or for some reason we can't work
13 through that mechanism and then you will find some people
14 from the region office calling the control room, calling
15 people at the site trying to get the information that way.

16 I guess the best way I can answer your question is
17 we're very conscious of it. We don't want to overburden and
18 overload the system, your system.

19 But the other side of it is that we are pressured
20 to get information. We're pressured to understand the
21 situation and what's going on.

22 We'll work through the resident to the extent we
23 can, but if that breaks down, sometimes you're going to find
24 we have to call.

25 Stu, do you have anything to add to that?

1 MR. RICHARDS: Yeah. I would like to add that,
2 when it isn't working that way, we need to hear about it.
3 We don't always know if you're getting calls from other
4 sources besides the resident inspector.

5 For the not-so-barn-burning events we try to work
6 through the resident. When it's something that's a larger
7 issue, what we try to do would be to give the licensee some
8 period of time to get their facts together and then get all
9 the interested parties on one large conference call, go
10 through the information, get a feel for where the utility
11 stands and then agree on some other time in the next day or
12 so to get back to you again.

13 That's worked pretty well, but if you are being
14 flooded with calls, we'd like to hear about it. In this age
15 of regulatory impact, we've been, particularly in the last
16 year, very sensitive, trying to not do exactly what you're
17 describing.

18 MR. GULDEMOND: Is there anything we can do to
19 facilitate that process by perhaps identifying points of
20 contact for various types of events or events that would aid
21 you in the acquisition of information in situations where
22 you feel a need for timely information.

23 MR. RICHARDS: One of the things that has worked
24 for some of our utilities is when they recognize that it's
25 an event or an occurrence of significance to the NRC, right

1 up front they'll say, "This happened and we'd like to set up
2 a conference call with you in four hours, six hours,
3 whatever period of time, to tell you where we stand."

4 Then the region will take the lead in contacting
5 NRR and any other interested parties and basically arrange
6 our end of the conference call.

7 If you get any calls in the meantime on your end,
8 if you'll just say, "Hey, six hours from now we're getting
9 together. Join us."

10 So instead of having a lot of people out there
11 with these individual communications going on, trying to
12 defer everybody to one call has worked well.

13 If the licensee will recognize that and take the
14 lead, all the better.

15 MR. GWYNN: Before we go on -- Pat Gwynn, Region
16 IV.

17 I would like to indicate that Region IV uses a
18 similar process to Region V. If in fact our process is not
19 working, then regional management needs to get that feedback
20 so that we can get the situation under control.

21 MR. CHAFFEE: I'd like to add one thing. Can you
22 hear me? This is Al Chaffee.

23 In the Events Assessment Branch, we usually try
24 the same type. When we get a 50.72 in, we typically will
25 wait until we get the region's daily report later that day,

1 which hopefully will give us additional information and help
2 minimize the need for us to make additional communications.

3 So NRR also is trying to find ways to minimize the
4 amount of communications going on on a particular thing.

5 MR. RICHARDS: One other thing I'd like to add.
6 Within the Agency it's become common practice now for the
7 points of contact that talk to the utility to be one, the
8 project manager in NRR, typically communication with your
9 licensee organization and then through the region and the
10 resident on the operations side.

11 So if you've got a pretty good relationship with
12 your PM and you're getting calls from other parties, I'd
13 just refer them to the PM, particularly if you've already
14 talked to the PM about the issue.

15 You can just say, "We're talking to the PM about
16 it and we prefer to work through him."

17 MR. REEVES: I wanted to get back to the concept
18 of ask the resident. I don't want you to take my comments
19 as being negative to the resident inspectors, to their
20 capabilities or to their efforts to try and do their job
21 well.

22 But one of the things that we discovered when we
23 got together on this LER committee from a variety of
24 utilities was the variety of interpretations that had been
25 provided to the utilities by either the region or the

1 resident inspectors.

2 I guess my comment is to come up with a consistent
3 interpretation of the rule or consistent reporting in
4 accordance with the guidance, experience has shown that
5 asking the resident, each individual resident at various
6 points in time over the several years the rule has been in
7 existence has resulted in a variety of interpretations and a
8 variety of reporting philosophies for the utilities.

9 So asking the residents is not the answer. That
10 should not be. That has been our first stop and I think the
11 experience has shown that we've got an inconsistent
12 application of the rule and inconsistent application of the
13 guidance for reporting.

14 That doesn't mean that the utility -- We
15 ourselves obviously look at the rules and look at the
16 guidance and come up with our own assessment as to the
17 condition and whether or not it is reportable.

18 We are that way. We're just as fallible as the
19 inspectors.

20 To get consistency, we're going to need to go to a
21 central organization.

22 MR. FAULKENBERRY: Let me try to answer that.
23 Bobby Faulkenberry.

24 Of course, I have to go back to the beginning.
25 You people certainly have the responsibility to make a

1 judgment and follow the regulations, what have you.

2 I think there will always be inconsistencies
3 between various people interpreting the same thing, in
4 effect, as the resident inspector is concerned.

5 However, I feel that once you people take a cut at
6 it and try to make a determination of whether it's
7 reportable or not, if it's down in the gray area, I would
8 still encourage you to go to the resident inspector, if
9 nothing more to inform him, because we in the regional
10 office, we want information.

11 But to communicate and inform him and to get his
12 opinion on it, and the way the system works is that if the
13 resident inspector, if it's in the gray area and he's not
14 too sure, he'll call the regional office and he'll talk to
15 his management and get more people involved in it and there
16 will be several people that will come to a collective
17 agreement on it.

18 So my feeling in that is if that system works,
19 even though that there are maybe some differences in
20 interpretation from, say, one region to the other, one
21 resident inspector to the other, it's going to be down in
22 such a gray area that it's not going to be significant.

23 It's not going to have any health and safety
24 operational significance. It's not going to be important
25 from that respect.

1 MR. REEVES: I don't think any of us have any
2 problems with interpreting the rule when the situation is
3 black and white and you don't either.

4 The problem is in determining whether or not a
5 report is required for the situations that are in a gray
6 area.

7 So all we're talking about here is guidance to try
8 and clarify the gray area, somehow try to make the gray area
9 go away.

10 As I'm saying, we've got six years of experience
11 that says that doesn't work. There are individuals out
12 there in industry and in the NRC and we each have our own
13 interpretations.

14 To me, if it's AEOD and their efforts to provide
15 research from these operating events, they are the guys that
16 would like to have or need to have the information and to
17 me, the clearinghouse for any of those questions ought to go
18 right back to those folks.

19 What do you really want to have? Is this
20 important enough for a utility to go ahead and write an LER?

21 MR. WILLIAMS: The staff does call all the staff
22 together. In other words, the regions have contacted NRR,
23 NRR has contacted AEOD and the regions have contacted AEOD.
24 None of this stuff is really done in a vacuum.

25 MR. REEVES: Well, then, if it's not done in a

1 vacuum, there should be no inconsistency across the country.
2 It's obvious there is.

3 MR. WILLIAMS: You're just going to have to live
4 with the inconsistency, because inconsistencies occur over
5 time and I can give you examples of different guidance that
6 occur over a period of months a reportable event is
7 developing, and things like that.

8 So again, the first contact would be resident, the
9 region, and the regions get NRR, AEOD, and the staff works
10 pretty well among the staff.

11 It's just a matter of flushing the issue up.

12 MR. JORDAN: Let me ask a question. How many of
13 these from your utility would you think would occur during a
14 year? How many instances would you need more guidance than
15 you presently have?

16 MR. REEVES: Oh I'd say the number would range.
17 This year there probably, I don't think, that much. What
18 we've had so far has been rare.

19 MR. JORDAN: One or two?

20 MR. REEVES: In past years, three or four maybe.
21 We're not talking about an enormous number.

22 MR. JORDAN: Because what I was thinking in
23 reaction was that I think the focus really should still
24 remain with the resident, but if the resident makes his
25 initial determination and sends it up the line to get it

1 verified as being consistent with the policy, maybe that
2 will help solve what problem.

3 MR. GWYNN: The rest of it really should act as a
4 conduit to get the information to the regional office.

5 Unless it's very clear in NUREG-1022 and its
6 supplements and your people just haven't read that
7 information, I wouldn't anticipate that the resident
8 inspector would be making judgments outside the guidance
9 that he's been given.

10 He would act as a conduit and provide that
11 information to the region so that we could then use a wider
12 base of experience in making those judgments.

13 That's what I expect would happen

14 MR. REEVES: Okay. Well, I can't speak firsthand
15 for conversations that go on between the guys calling the
16 shots for the utilities and resident inspectors at other
17 plants. I haven't been there.

18 But I guess I can tell you what I've picked up
19 from my peers at this conference, and that is that there is
20 a pretty wide inconsistency.

21 If in fact all these things were funneled up to a
22 central clearinghouse, the inconsistencies that I hear about
23 wouldn't exist.

24 Not to say that we'd be in a perfect world.
25 Obviously, we're not going to be there.

1 The other question I had is, I don't how many
2 resident inspectors there are here, but I'd be concerned if
3 I was a resident inspector and the utility came to me and
4 asked me my interpretation of reportability and non-
5 reportability.

6 I'd be concerned as the resident inspector of
7 being asked to call the reportability shots for a utility.

8 Consequently, as a resident inspector, I would
9 back off and I'd say, "You fellows make the decision. We'll
10 follow up."

11 I would be happy to try and provide as much
12 guidance as I could to the utility and if the guidance was
13 not clear in a particular area, I'd try to funnel that up
14 and get some kind of a judgment from folks within the NRC,
15 rather than the resident.

16 I don't think you folks want the resident in the
17 position of calling the shots on reportability. I think
18 it's a --

19 MR. JORDAN: No. Let's do clarify that.

20 When the resident is called upon by the utility,
21 he's giving his view of what the guidance says.

22 The utility makes the decision on whether or not
23 to make the report. He's not going to be taking that
24 responsibility.

25 What you do is discuss it with the inspector and

1 he agrees or disagrees and then you do what you choose, but
2 he's not making that decision.

3 MR. LINVILLE: Jim Linville. I'm currently from
4 NRR but formerly with Region I.

5 I guess that this problem with communications and
6 getting these issues up through the proper chain, I'd
7 encourage you to be open and direct with the resident.

8 If you're concerned on a particular issue about
9 inconsistency in interpretation, tell him your concern about
10 that and suggest that a conference call be arranged to
11 discuss it.

12 MR. REEVES: I wouldn't have any hesitancy at all.
13 From my knowledge of people on the LER committee, I don't
14 know a one of them that would be hesitant about talking to
15 the resident.

16 So it's not as if we're re-inventing the wheel
17 here. As I said, there is a problem. We have a lack of
18 consistency.

19 It is apparent. It's got to be apparent to these
20 folks up here.

21 MR. LINVILLE: I think you're going to have that
22 same problem if you're talking to two different people. So
23 to get a number of people involved in the discussions is
24 probably even tougher to try to get consistency.

25 MR. WALKER I'm Roger Walker, TU Electric.

1 The way we generally handle it, because I agree
2 with him somewhat. I don't think that I want to have my
3 resident inspector called upon to take an independent
4 interpretation.

5 What I usually do is go to my resident, if I'm in
6 a gray area, and I say, "This is my interpretation of this.
7 I can see how you could interpret it some other way, but if
8 you disagree with me, let me know. If you want to talk it
9 over with your section chief, let me know."

10 That usually solves the problem.

11 MR. WILLIAMS: Let's break. Why don't we be back
12 at a quarter of, on time. Thank you very much.

13 [Recess, 10:35 a.m. to 10:50 a.m.]

14 MR. WILLIAMS: We are running a little bit late.
15 We're going to try to pick up some time. So without delay,
16 we'll let Nancy begin.

17 STATEMENT OF

18 NANCY ERVIN

19 MS. ERVIN: I'm going to discuss our regulation
20 that deals with reporting the safeguards events.

21 For the benefit of those who are not in
22 safeguards, I'll give a brief description and history of the
23 regulation.

24 Then I'll be discussing some activities that we
25 have ongoing to revise our guidance on reporting of these

1 events.

2 The revision is in an effort to eliminate
3 unnecessary reporting and to better clarify reporting
4 requirements.

5 10 CFR 73.71 requires licensees to report
6 significant safeguards events to the NRC Operations Center
7 within one hour after discovery of each event.

8 Although this rule covers fuel facilities and
9 transportation of S&M, also some non-power reactors, I'm
10 going to limit my discussion to the power reactors because
11 of the audience today.

12 These events include acts or attempts to do
13 significant physical damage to a power reactor, including
14 the interruption of normal operations through tampering.

15 Significant events can also include safeguards
16 system failures, if the failure is not compensated and if it
17 could allow undetected or unauthorized access into a
18 protected or vital area.

19 The rule also requires licensees to report certain
20 less significant safeguards events in a log for quarterly
21 transmittal to the NRC.

22 These events include safeguards systems failures
23 that are compensated and that do not immediately endanger
24 the health and safety of the public.

25 The next viewgraph, please.

1 73.71 was originally published in 1973. A major
2 revision to the rule was published June 9, 1987, and
3 effective October 8, 1987.

4 The purpose of the revision was to clarify
5 reporting requirements, eliminate unnecessary reporting and
6 to improve NRC's data analysis system.

7 Reg Guide 5.62 entitled, "Reporting of Safeguards
8 Events," was revised in November of '87 to clarify the rule
9 revisions.

10 NUREG-1304, same title, was published in February
11 of '88 to address questions that were discussed at a
12 September 14, 1987, workshop on the revised rule.

13 Next viewgraph. please.

14 Prompt notification of safeguards events is very
15 important. We analyze these events for their immediate
16 impact on the safe operation of the plants and the health
17 and safety of the public.

18 Some of the events may warrant NRC oversight,
19 which can include activation of the NRC Information
20 Assessment Team or the NRC Response Center.

21 In some cases we may also need to notify other
22 agencies, such as the Federal Bureau of Investigation if
23 sabotage is involved, or the Bureau of Alcohol, Tobacco and
24 Firearms if explosives are involved.

25 If the event affects other licensees or agencies,

1 we may issue an immediate generic communication. More long-
2 term feedback would be rule or guidance revision as
3 appropriate.

4 An example of that is a generic letter that we've
5 recently developed to reduce unnecessary prompt reporting,
6 and I'll be discussing this a little bit later.

7 Next viewgraph, please.

8 The loggable or less significant events that we
9 receive each quarter are reviewed to determine if generic
10 safeguards system effectiveness problems exist or are
11 developing.

12 Our formal long-term analysis is conducted by NMSS
13 and results are forwarded to the licensees. Ms. Higdon will
14 be discussing this analysis system shortly.

15 We issue generic communications and initiate rule
16 or guidance revisions when necessary, based on a review of
17 these events.

18 A recent example of a generic communication is
19 Information Notice 90-13, entitled, "Importance of Review
20 and Analysis of Safeguards Event Logs."

21 This Information Notice was issued to remind
22 licensees of the benefits of meaningful reviews and analysis
23 of the event logs and reports required by 72.71. Also, of
24 initiating prompt, effective corrective measures to prevent
25 recurrence of the identified problems.

1 It was generated because of concern that some
2 licensees were not analyzing safeguards system problems and
3 the problems were continuing to recur with no apparent
4 measures taken to correct them long term or to get to the
5 root of the problem.

6 Next viewgraph, please.

7 About a year ago we initiated a revision to Reg
8 Guide 5.62 and NUREG-1304. The purpose was to incorporate
9 lessons learned from two years' experience with
10 implementation of the revised 73.71 rule.

11 The revision is also based on our evaluation of
12 the safety significance of all events reported and the
13 immediate actions taken by the licensees and the NRC.

14 The proposed revision incorporates the appropriate
15 parts of NUREG-1304 into Reg Guide 5.62, and it will result
16 in additional reduced reporting, primarily in the area of
17 the one-hour reports. Also, the fitness for duty events.

18 It will provide further clarification of the
19 reporting requirements and will address improvements
20 necessary for the event log analysis program.

21 We intend to issue the revised Reg Guide for
22 public comment within three months after our generic letter
23 gets published.

24 We also, with respect to the generic letter, which
25 will reduce prompt reports that are coming in that are

1 unnecessary right now to the Operations Center, it
2 represents a revision to our current policy and it's
3 responsive to the concerns that were raised in the Impact
4 Survey.

5 We're hoping that that will be published within
6 the next couple of months. It's in CRGR now for review for
7 backfit considerations.

8 We intend the generic letter to be guidance only.
9 When it's published, no written response will be required
10 and any actions that you take will be strictly voluntary.

11 The generic letter may be modified in the final
12 revision to Reg Guide 5.62, but that wouldn't be for about
13 another year, because of the lengthy regulatory process
14 involved in revising Reg Guides.

15 The policy changes that I'm going to discuss with
16 you that are in the generic letter will not be effective
17 until the generic letter is published. Until that time you
18 should continue to follow the current published guidance.

19 I don't have any viewgraphs on the generic letter
20 and you won't find anything in your packet, because it's
21 pre-decisional.

22 But what I'm going to do is, I'm going to read you
23 the specific events that we have been getting into the
24 Operations Center as one-hour reports.

25 Some of them do represent a revision to our

1 previous position with regard to one-hour reporting. Others
2 are already discussed in our guidance but the guidance
3 wasn't clear enough so there is still some confusion and
4 these events were coming into the Center as one-hour
5 reports.

6 So when I read the examples to you, you're going
7 to find some of them that actually already are described in
8 the current guidance.

9 Before I talk about the specific events that are
10 listed in the generic letter, I'll go over some of the more
11 generic policy in the letter.

12 Our current published guidance suggest that a
13 licensee report system failures within one hour if the event
14 is not properly compensated within ten minutes of discovery.

15 This is by a licensee employee, contractor or
16 vendor, or within the time that's prescribed in your
17 approved security plan. This is already stated in Reg Guide
18 5.62.

19 The generic letter allows you to log the event,
20 even if it takes you more than ten minutes to compensate for
21 it, provided all other aspects of proper compensation as
22 described in Reg Guide 5.62 and the NUREG-1304 are met.

23 This logging is allowed if extenuating
24 circumstances prevent the compensation within ten minutes of
25 discovery, also provided that there was no malevolent

1 intent, nothing adverse resulted from the delay, and that
2 the licensee takes appropriate measures to ensure a more
3 timely response or other necessary action in the future.

4 An example of this type of event would be if an
5 individual fails to notify security promptly of a safeguards
6 event, and this is typically what delays the ten-minute time
7 frame of compensating for the event.

8 A vendor or someone that's new to the facility
9 might discover something and then not realize that they were
10 supposed to have called security.

11 In cases where you do have more than a ten-minute
12 time frame on compensating, we'd like you to note the cause
13 of the delay in your log entry.

14 Another policy change deals with fitness-for-duty
15 events. Significant fitness-for-duty events are now
16 reportable under 10 CFR 26.73, not under 73.71.

17 Fitness-for-duty performance data must be
18 submitted under the provisions of 26.71 (delta).

19 In those rare cases where an event with safeguards
20 significance is caused by a fitness-for-duty event, the
21 fitness-for-duty aspect should be reported to the NRC in
22 accordance with Part 26 and the safeguards aspects in
23 accordance with 73.71.

24 When a telephonic report is required by both
25 rules, you can make one telephone call, if you'd like,

1 instead of making two, as long as it's made within the one
2 hour which is required by 73.71.

3 That is your choice. You don't have to. If you
4 want to make the one-hour safeguards report and then make
5 your 24-hour report for the fitness-for-duty, you can do it
6 that way.

7 Now I'll discuss the events that are listed in the
8 generic letter that can be logged instead of being reported
9 to the NRC within one hour of discovery.

10 These events have actually been coming into the
11 Center now for three years. We started analyzing these
12 events about a year ago and we had two years of experience
13 then.

14 So you've got about three years of analyzing the
15 impact and what licensees and what the NRC does with the
16 event when we make the decision to allow them to be logged.

17 These events can be logged if they're properly
18 compensated in accordance with the guidance provided in Reg
19 Guide 5.62 and NUREG-1304 and the areas of the generic
20 letter that we just discussed.

21 When there are factors that could change the
22 reportability of the safeguards events, specific factors --
23 I'll discuss those with that example as we go through.

24 The first one is a design flaw or vulnerability in
25 a protected or vital area, safeguards area, if the flaws

1 existed for more than ten minutes.

2 Previously, if a degradation had existed for more
3 than ten minutes, it was a one-hour report. Now you can log
4 it, as long as you don't find anything adverse when you do
5 your inspection of the event.

6 The next example is a failed compensatory measure
7 such as an inattentive or sleeping security guard or
8 equipment that fails after being successfully established as
9 an effective compensatory measure for a degraded security
10 system.

11 If security personnel are ineffective because of
12 alcohol or drugs, the security degradation is reportable
13 under 73.71 and the licensee should include the positive
14 results of the four cause tests in the data submitted under
15 26.71(d).

16 The next example is discovery of contraband inside
17 the protected area that is not a significant threat.

18 For example, such a condition could be the
19 discovery of a few bullets or a weapon that was
20 inadvertently left unattended or unsecured by the security
21 force.

22 If contraband is found in a vehicle in a parking
23 lot outside of the protected area, you don't have to report
24 the event within one hour. You also don't have to log it.

25 This is because the contraband was outside of the

1 PA and, again, this is provided that there is no attempt
2 being made to bring it in, that nothing adverse is
3 discovered as you get into the event more.

4 The next example is compromise, including loss or
5 theft, of safeguards information that could not
6 significantly assist an individual in gaining unauthorized
7 or undetected access into a facility or in the area of
8 radiological sabotage or theft of S&M.

9 The next example is loss of all AC power supply to
10 security systems or loss of all computer systems, provided
11 adequate security measures, compensatory measures, can be
12 maintained until the systems are restored.

13 If a power loss or a computer failure could not
14 enable undetected or unauthorized access, again, you don't
15 have to log it and you don't have to call it in within one
16 hour.

17 An example of this would be a computer failure
18 would not require reporting if it's negated by an automatic
19 switchover to a functioning backup computer without a time
20 delay.

21 Also, momentary loss of lighting caused by a power
22 interruption would not require reporting, if the loss could
23 not have allowed undetected or unauthorized access.

24 Even in the beginning with our guidance, just like
25 on the 50.72/50.73 side, we've allowed a lot of licensee

1 judgment.

2 When you report an event to the Op Center within
3 one hour, we expect that to be a significant event,
4 something that could endanger the health and safety of the
5 public or adversely affect the immediate safe operation of a
6 plant.

7 If you determine that this couldn't happen, then
8 these are the types of events that we would like to see you
9 logging instead of calling in to the Center.

10 The last group of examples of loggable events deal
11 with partial fail res of an otherwise satisfactory access
12 authorization or access control program.

13 The first example is a vendor who's been cleared
14 and authorized to receive a badge permitting unescorted
15 access to protected and vital areas, who inadvertently
16 enters the protected area through a vehicle gate without
17 being searched, without being issued a badge.

18 The licensee discovers the event, searches the
19 individual, issues a badge and takes corrective actions to
20 prevent recurrence.

21 If you do that, you can log it. You don't have to
22 call in.

23 If search equipment fails and the licensee does
24 not detect the failure, thereby allowing unsearched
25 individuals to enter the protected area, they can log the

1 event, as long as nothing adverse is discovered.

2 That would mean that you didn't know the equipment
3 went down, so chances were that the folks coming through
4 didn't know the equipment was down, either. If you can pull
5 them back and search them, you do that.

6 But in your final evaluation and your judgment,
7 nothing adverse happened from the event, you can log it.

8 If you discover that the search equipment fails
9 before anyone goes through unsearched and you immediately
10 use other equipment that's available with the same
11 capability, that would be like your hand-held or walk-
12 through searching devices. If you have one train up and you
13 find out that it's out of service before anyone goes
14 through, you send them through a different train.

15 That does not require a report. It does not
16 require a log entry. No reporting on that one.

17 The next example is an individual who's required
18 to have an escort for a particular area, who inadvertently
19 becomes separated from his or her escort, but the escort or
20 another person who's authorized unescorted access recognizes
21 the situation and corrects it.

22 If the individual separates from his or her escort
23 to use a restroom which has had limited means of egress and
24 the escort remains nearby and has full view of the egress
25 area, no report or log entry is required.

1 We have gotten these and you don't have to report
2 it and you don't have to log it.

3 If an employee of a licensee or contractor enters
4 a vital area improperly without realizing that the card
5 reader is processing a preceding employee's card, or if the
6 employee walks in behind another employee without using his
7 key card, tailgating, or using the key card improperly, puts
8 the key card in, doesn't notice the red light and goes in
9 behind the other person, the event can be logged, even if
10 the employee was not authorized access to any vital area, if
11 the improper entry was inadvertent and was without
12 malevolent intent.

13 If an individual enters a vital area to which he
14 or she is authorized unescorted access by inadvertently
15 using an access control medium, key card or badge, intended
16 for another individual who's also authorized access to the
17 area, again, this kind of event can be logged.

18 If an individual authorized only protected area
19 access, is incorrectly issued a badge granting vital area
20 access, the event can be logged whether the individual does
21 or doesn't enter VAs, again depending on no malevolent
22 intent and nothing adverse discovered with the event.

23 If an individual is issued an incorrect badge but
24 he or she cannot reasonably use it. An example of this
25 could be in your path area, if you have a system where you

1 hand of badges but then they also have to have a pin that
2 they have to put into the key pad in order to get through
3 the turnstile to go into the protected area.

4 In a case like that, where it's not reasonable
5 that the individual even could have used the badge to get in
6 or to do anything, if that's discovered and it's corrected,
7 you don't have to log it. You don't have to call it in.

8 The next example is improper control, to include
9 loss or offsite removal of access control media, including
10 picture badges, keys, key cards or access computer codes,
11 that could be used to gain unauthorized or undetected
12 access.

13 These can be logged as long as they're properly
14 compensated, which includes preventing successful use of the
15 medium and initiation of measures to determine if the medium
16 was used during the period that it was lost or off site.

17 If the licensee determines that it was used during
18 this period, the event should be reported within one hour
19 from when you discover that it was used.

20 If you determine that the medium could not have
21 been used to gain unauthorized access or undetected access,
22 you don't have to report it. You don't have to log it.

23 Situations of this type of event could include the
24 following. If the authorized individual only momentarily
25 takes the badge outside of the PA, immediately discovers

1 that they've done it, and brings the badge right back in
2 before any compromise could have occurred.

3 If a badge or a key card is only momentarily
4 misplaced and the event is discovered and corrected before
5 anyone could reasonably use the device for entry, or if the
6 badge was automatically deleted from the system when taken
7 off site, a new badge with a different access code is issued
8 to the individual upon re-entry and the previous access code
9 is not used in another badge, these events would not require
10 any reporting.

11 The next-to-last example is card reader failure
12 that causes vital area doors to unlock in the open position
13 or to lock in the closed position but with no functioning
14 door alarm.

15 If the card reader causes the vital area door to
16 lock in the closed position and the alarm functions, no
17 report, no log entry is required.

18 The last example of a loggable event is incomplete
19 pre-employment screening records. This includes
20 falsification of a minor nature or inadequate
21 administration, control, and evaluation of psychological
22 tests.

23 Unescorted access of the individual should be
24 canceled or suspended until the identified anomaly is
25 resolved.

1 If the licensee determines that the unescorted
2 access would have been denied based on the developed
3 information that was missing, then a one-hour report would
4 be required within one hour of discovering the adverse
5 information.

6 Now Joan Higdon will address the NMSS analysis
7 system.

8 STATEMENT OF

9 JOAN HIGDON

10 MS. HIGDON: Good morning. I'm Joan Higdon from
11 the Division of Safeguards and Transportation and manager of
12 the Safeguards Event Logs Analysis Program.

13 I'd like to take a few minutes to give you brief
14 background information on our program. Our division has
15 responsibility of conducting and implementing the logs
16 program.

17 Activities associated with this effort are the
18 review and analysis of reported events in the quarterly logs
19 and feedback to the NRC and the licensee of analysis
20 findings and statistical data.

21 The goal of this program is to serve both
22 audiences and the logs is one mechanism to be used for
23 improving safeguards system performance.

24 Emerging from this program are a number of cases
25 where the event logs and feedback data were the bases for

1 root cause analysis that resulted in improved equipment
2 operation or reduced human error.

3 We have specific examples of those a little bit
4 later.

5 Additional staff resources have been dedicated to
6 this program at this time, which will enable our staff to
7 perform a technical analysis of the event data, with the
8 results provided to industry as a companion to the quarterly
9 report.

10 Each quarter a review and analysis is performed
11 for each quarterly log submittal. Reported events are
12 categorized based on the root cause of each event.

13 We are focusing on the specific component that
14 failed, type of human error or environmental factors that
15 impact on the functioning of the system.

16 The results of this review is distributed to each
17 reporting licensee and their facility and appropriate NRC
18 headquarters and regional staff in a quarterly feedback
19 report.

20 Licensee corporate staff are being added to our
21 mailing list on an as-requested basis. If anyone here is
22 not on our mailing list and wish to be added, please see me
23 after the briefing.

24 The quarterly report presents statistical data for
25 events reported from each facility with regional and

1 industry averages.

2 These numbers, whether event totals or averages,
3 are to be used as a frame of reference for the licensee and
4 NRC staff.

5 These numbers are not to be interpreted as
6 standards of performance or the norm for any facility, event
7 category or quarter.

8 These numbers should be evaluated, along with an
9 understanding of a facility's design, equipment, population
10 and other circumstances that affect reporting for each
11 quarter.

12 Although numbers are useful in doing trend
13 analysis, they can vary substantially from facility to
14 facility, as a result of site-specific characteristics and
15 other factors.

16 Therefore, emphasis is placed on identifying and
17 evaluating the root cause of unusual trends of reported
18 events.

19 There is much value in this analysis program for
20 maintaining effective safeguards. The use of the event logs
21 and feedback reports are designed to be a positive approach
22 for improving system performance.

23 The trending of events from quarter to quarter
24 will focus inspection resources to specific areas that merit
25 closer examination.

1 Emphases are placed on what the number is
2 comprised of and not just the number.

3 NRC feedback to industry will give the licensees
4 an opportunity to evaluate written performance and security
5 procedures and to take self-correcting action in areas that
6 are in need of improvement.

7 The licensees are using the logs and feedback
8 reports as a tool in evaluating their facility's operation.

9 Where new equipment has been installed or modified
10 or a new security procedure implemented, the quarterly
11 trending will afford the licensee an opportunity to chart
12 its progress.

13 By comparing their facility's data against
14 industry, this comparison serves as a point of reference in
15 this evaluation.

16 The event data should be reviewed in conjunction
17 with the previous quarter's data. We are not focusing on
18 statistics for just one quarter, but the trend of reporting
19 of events from quarter to quarter for each facility.

20 There are cases where the event logs and feedback
21 reports highlighted a need for certain changes at a
22 facility.

23 Many licensees are performing a root cause
24 analysis based on event logs and quarterly feedback reports.

25 The analysis findings have resulted in

1 modifications to certain equipment or security procedures,
2 which improved equipment reliability or reduced human error.

3 The findings are provided to industry, since it
4 may have application at other facilities.

5 We want the feedback report to be used as a medium
6 for the exchange of information regarding analysis findings
7 and lessons learned that can have a positive effect on the
8 security program.

9 Some specific examples of these are where in one
10 particular facility they had the installation of heavy-duty
11 springs on a security doors.

12 The springs are designed to facilitate the door
13 closing, especially when the door is adversely affected by
14 air pressure.

15 Another case where a strobe light was installed
16 over a security door and it is designed to turn on while an
17 individual is exiting the door and to turn off only after
18 the door has been shut and the bolt actually in place.







19 There have been some findings and statistics where
20 these have reduced human error.

21 Additional staff resources have been dedicated to
22 this program and the data is now undergoing a technical
23 review.

24 These findings will be issued, along with your
25 quarterly report, focused on specific topics, such as

1

IMAGE EVALUATION TEST TARGET (MT-3)



1 certain equipment performance, environmental influence, and
2 on security procedures that are successful in reducing human
3 error.

4 In addition, work has begun to normalize the data,
5 grouping like facilities together based on size, population
6 and similar environmental conditions.

7 Over time, the quarterly report will be revamped
8 to present the data in a manner which reflects site specific
9 characteristics and other factors that impact on that
10 reporting.

11 Our staff is sensitive to industry's concerns and
12 needs with regard to this program.

13 We appreciated the opportunity to receive your
14 input at the Orlando meeting. Based on this information,
15 we've made a number of changes in the program, and we're
16 working towards making it a very successful and positive one
17 for both NRC and industry.

18 Thank you.

19 MR. WILLIAMS: Questions?

20 DISCUSSION ON 73.71 REPORTING

21 MR. GULDEMOND: Bill Guldemond, Comanche Peak.

22 To what extent is the analysis of data that's
23 received as part of the event log and reports utilized as an
24 input directly into the SAPP process on a plant-by-plant
25 basis?

1 MR. FAULKENBERRY: Stu, do you want to pick that
2 up?

3 MR. RICHARDS: I'm not responsible for the
4 safeguards area but I have sat on just about every SAPP
5 board in Region V in the last year or two, and I can tell
6 you that the SAPP boards are very cautious about not
7 applying raw data straight, reaching conclusions.

8 That's not to say that there wouldn't be some kind
9 of a mention of how many loggable events were received. I
10 think there's some discussion of the number of safeguards
11 events, but the board tries to consider the significance.

12 Frequently we have a lot of discussion about what
13 it means. So it may not necessarily come through in the
14 written product, but I can assure you that we try very hard
15 to stay away from just using numbers and stick to
16 significance in reaching some kind of conclusion on
17 performance.

18 MR. GULDEMOND: So the process is consistent with
19 the utilization of performance indicator data relative to
20 SAPP?

21 MR. RICHARDS: I think so. In the SAPP process
22 we're not supposed to apply numbers to reach a conclusion.
23 It's significance of events and how it relates to overall
24 performance.

25 But I think we'd be wrong not to consider that

1 information as part of the process.

2 MR. GULDEMOND: Thank you.

3 MS. BRITT: Kathleen Britt, Comanche Peak.

4 Could you clarify the circumstances which would
5 lead us to be responsible for a fitness-for-duty report as
6 well as a 73.71 report and how this could come about without
7 specifically conflicting with 26.73, and also considering
8 that 26.73 report is a 24-hour report, whereas the 73.71
9 report is a one-hour report?

10 MS. ERVIN: An example might be where you have a
11 guard that's posted as a compensatory measure for a degraded
12 safeguards barrier, and the guard is under the influence of
13 drugs or alcohol and can't perform and then something
14 adverse happens as a result of that.

15 The one-hour report for the safeguards would be
16 73.71. If there was something adverse that happened on the
17 safety side, it might fall under the 24-hour reporting.

18 Your fitness-for-duty would be a for-cause test.
19 If the event involved like a control room operator and a
20 security type event was also involved with it, then you
21 might have your 24-hour report that would be a call in for a
22 fitness-for-duty.

23 And you could take care of both of them by the
24 one-hour report, if you chose to. It would be unusual.

25 That's why we said in those rare cases, because

1 it's not that it won't ever happen.

2 It was a question that was -- Loren Busches is
3 the fitness-for-duty expert in NRR, and it was a question
4 that had come up with licensees several times.

5 So we wanted it in the generic letter.

6 MS. BRITT: Doesn't 26.73 specifically say that
7 you only make reports under that rather than --

8 MS. ERVIN: I can't hear you.

9 MS. BRITT: Does 26.73 not specifically say that
10 you make reports under Part 26 rather than 73.71?

11 MS. ERVIN: This is for the reports that are
12 reportable strictly under 26. If you have a joint report,
13 Loren said the 26 would be called in with that data and then
14 the 73.71 under 73.71.

15 It's really more like two separate events. We're
16 just saying if you want to save making two calls, you can
17 call under the one-hour 73.71 report.

18 MR. WILLIAMS: If there's no other questions,
19 maybe we can reconstitute the LER panel and have a wrap-up
20 question or if Ed has some closing comments on that, we can
21 move to that.

22 SUMMARY DISCUSSION

23 MR. WILLIAMS: I guess the first thing is we would
24 like to hear some closing comments from you, anything that
25 you think is worth mentioning.

1 One of the things that occurs to me throughout
2 these workshops is that we seem to be focusing on the fringe
3 areas of reporting more than we are on what might be
4 fundamental problems or fundamental areas of concern.

5 There's a few reasons for that that I can see, but
6 do any of you have an idea of a major area, a fundamental
7 question that you have on reporting that's not one of these
8 definitional areas or fringe areas, that we didn't cover
9 during the workshop that you think really needs to be
10 addressed?

11 MR. BRANCH: Steve Branch.

12 It's not really a fundamental question. It's more
13 of a procedural question under 50.9.

14 50.9 states that, "Reports should be made to the
15 Regional Administrator." Is the intent there that the
16 Regional Administrator be personally notified or is it
17 possible to notify the deputy administrator or a section
18 chief or resident?

19 MR. FAULKENBERRY: That's used in kind of a broad
20 sense. When you say notify the regional administrator, that
21 means notify someone in the regional office, generally a
22 management official of the regional office.

23 MR. BRANCH: That would not include, then, the
24 resident inspector?

25 MR. FAULKENBERRY: I guess it could.

1 Okay. Ed answered the question, no, it should be
2 the regional office.

3 MR. BRANCH: I'm sorry?

4 MR. FAULKENBERRY: No. It should be someone in
5 the regional office specifically.

6 MR. BRANCH: Thank you. And also, one further
7 followup. Should the 50.9 notification exclusively
8 reference 50.9?

9 MR. WILLIAMS: I think that's appropriate.

10 MR. JORDAN: Yeah. What we want to try to protect
11 you and us from is a passing comment about the problem and
12 then a month later the comment, "We reported that on August
13 21st. Don't you remember? We wrote it down in the..."
14 That won't work.

15 So it's important to say, "This is a report in
16 response to the requirements of 50.9," blah, blah, and even
17 subparagraphs, if appropriate, so that we are sensitized and
18 you know exactly what you are reporting.

19 MR. BRANCH: Thank you.

20 MR. WILLIAMS: The other thing that seems to be
21 coming up and last year it came up on one plant in the east
22 is that there's a potential use -- Some people are trying
23 to use 50.9 rather than 72.73.

24 If it's reportable pursuant to the discussions
25 we've had over the last day here, then 72.73 is the right

1 means to do it.

2 50.9 does not have all the content requirements
3 that 73(d) does and the like, so we really prefer and we'll
4 ask for 73 reports and 72.

5 Any other wrap-up questions or statements? Don?

6 [Laughter]

7 MR. REEVES: Let me just go on record as stating
8 that I think the LER committee would appreciate working very
9 closely with the NRC in trying to come up with improved
10 guidance for LERs.

11 We have talked about that several times during
12 this workshop.

13 MR. WILLIAMS: For my own part, I'm not really
14 sure about the charter of that committee. Cindy originally
15 explained this is an LER/JCO committee.

16 MR. REEVES: That's correct.

17 MR. WILLIAMS: That was initiated by Georgia
18 Power, I think. She had to leave. She was working in that
19 area for Georgia Power, I think.

20 MR. REEVES: Well, she apparently is in the
21 licensing group at Georgia Power and she is involved in
22 preparing LERs and JCOs.

23 MR. WILLIAMS: Is there a term that this committee
24 will exist for?

25 MR. REEVES: It was created under the auspices of

1 the prime reps of BWR Auxiliary Group and was funded for
2 this this year and there apparently either been or will
3 be a funding request submitted for next year, which my
4 understanding is will be within regional groups.

5 MR. WILLIAMS: Well, maybe you could advise us of
6 the membership in a letter.

7 MR. REEVES: Sure.

8 MR. JORDAN: We've got that.

9 MR. WILLIAMS: We've got all that? Okay.

10 MR. CHERNOTT: If I could interrupt a second.

11 Harold Chernott, Wolf Creek.

12 One thing to note here is that group has not
13 received endorsement of all the other owners groups yet. As
14 such, it represents a subset of the total industry at this
15 point.

16 MR. JORDAN: I'd like to make a comment about
17 that. When the NRC does seek comments on a particular
18 policy or rule change, we do it publicly. So when we send
19 something out, it will go to all utilities and to UCS and
20 anybody else and everybody else.

21 So it would be an open communication. The
22 Advisory Committee Act prevents us from working with only
23 one group.

24 So we appreciate the offer and I'm sure that we
25 will take you up on it. But we also provide it universally.

1 MR. REEVES: I agree and I will say that the
2 participation -- An invitation has been extended to all the
3 owners groups to support that function, to participate in
4 the function.

5 At this stage, with no request for any
6 supplementary funding, whatever costs are involved is
7 underwritten to this date by the BWR Group.

8 Participation of all utilities has been encouraged
9 and requested.

10 MR. JORDAN: From my personal viewpoint I think
11 that committee has done some very useful work and I
12 appreciate your initiative.

13 MR. WILLIAMS: Thank you, Don.

14 Maybe the panel has closing comments. Johns,
15 would you like to bat?

16 MR. JAUDON: [Shakes head]

17 MR. GWYNN: I have no comments.

18 MR. WILLIAMS: Jack.

19 MR. CROOKS: I just wanted to extend again a thank
20 you for the comments that are on the record.

21 We will take them and our plans are to go over all
22 the workshops, as I mentioned before, pull out the key
23 issues and then develop new guidance and possibly a slight
24 rule change.

25 MR. WILLIAMS: Ed.

1 MR. JORDAN: I, too, want to thank the
2 participants, the host region, Region IV, for putting
3 together the facilities, and the court reporter for taking
4 down this material, and indicate that the record will be
5 available through the Public Document Room, and then make a
6 couple of comments.

7 I think the first one will be that generally, the
8 NRC is satisfied with the level of reporting in terms of the
9 events that are reported. We're getting about the right
10 set.

11 Failures to report are generally isolated and the
12 NRC handles them on a case-by-case basis. We have
13 inconsistencies we'd like to improve.

14 We want to leave room for judgment and I think
15 this workshop has sort of reinforced that.

16 There certainly is a need to adjust the reporting
17 requirements and the guidance, and I'll go a step further
18 than Jack Crooks did and say we will issue revised guidance
19 and we will promulgate a minor rule change in order to make
20 those clarifications.

21 I think the safeguards and security area is to be
22 commended for having gotten theirs to the point of very near
23 issuance and I think that will help you as well as helping
24 the Commission.

25 We do expect this change in minor rulemaking and

1 guidance to eliminate many of the non-usable reports, non-
2 usable to you and to us.

3 Certainly, you've helped identify the areas that
4 need revision.

5 I want to remind once again, the industry
6 shouldn't arbitrarily change, based on discussions of
7 guidance we've had here or owners group guidance or others,
8 the existing reporting requirements until it in fact has
9 been sent out.

10 So please take under advisement the proposed
11 changes are not yet amendable.

12 I would reinforce my statement about important
13 stuff. I think that's the essence of what all of us want,
14 is that people that are developing reports have a philosophy
15 of why the report is being issued.

16 It's to provide for the industry the material that
17 may benefit them and prevent them from having to learn about
18 a problem independently.

19 We really want to have a collective learning
20 process and reduce the numbers of events and errors. I
21 think that's fundamental.

22 So if you have that bottom line as a basis for
23 making a determination, I think that helps a lot.

24 The value of closer communications is just evident
25 from our discussions. The NRC, I think, has not done as

1 good a job as we should in having these kinds of discussions
2 with you and getting down to cases.

3 I told the backfitting workshop, and I would say
4 it again here, that the next workshop we have in this regard
5 we will make it up in terms of case studies.

6 We will provide some marginal event scenarios and
7 then break up into groups and classify them and find out why
8 we have problems with our determinations.

9 So I think that will be a beneficial way of
10 treating it.

11 The one question that was raised that was unique
12 in my previous involvement, and that was whether the NRC
13 industry may be missing important information related to
14 defects identified in dedication of commercial grade
15 components.

16 This is an identification process the utilities
17 have and there is certainly a great deal more of that going
18 on based on vendors no longer providing quality grade
19 equipment.

20 So I certainly have a question in my mind as to
21 whether that change in the present mode of reporting is
22 missing some important generic information.

23 So we'll be working with you utilities to try to
24 understand whether there's a problem there that we need to
25 do something about.

1 Okay. I think I've covered everything. I would
2 say that there is an attempt on our part to make those
3 revisions both to the guidance and the rule and send it out
4 and we'll be interacting with you on a public basis.

5 Thank you.

6 MR. FAULKENBERRY: I think from the region's
7 perspective, I would encourage you to go back and think in
8 terms of the intent of the rule to communicate the
9 information that is of concern to us, from both a generic
10 and specific standpoint.

11 Certainly, we in the regions are probably looking
12 at reporting information from a little bit different
13 perspective than headquarters, but we've got a concern to
14 understand and know what's going on and to stay on top of
15 it.

16 I would hope that when we get down in these gray
17 areas you've expressed concerns about, really what should be
18 reported and what shouldn't at some low levels, that if you
19 apply that criteria: Does it have safety significance; is
20 it something that the NRC needs to know with regard to
21 evaluating condition of the powerplant and the operational
22 safety of the powerplant; or do other utilities need to know
23 this information from the standpoint of preventing possible
24 problems or getting out of possible problems.

25 I would think that would cover most of the things

1 that are of concern to us.

2 I would also hope, too, that if you apply that
3 criteria way down into the fuzz and into this gray area and
4 it has no safety significance, that we in regions from an
5 enforcement standpoint wouldn't get too hung up with regard
6 to trying to catch you on some very, very gray area.

7 So that's the message I would put across, is to
8 try to apply the criteria of the importance and safety
9 significance.

10 MR. WILLIAMS: The thought that came to my mind
11 during all these workshops is the root cause analysis that's
12 demanded by the LER process.

13 It seems to me that the questions on LER reporting
14 that are not in the fringe areas, the ones that really do
15 have potential for enforcement followup, given an event may
16 arise, precursor events that were found and not reported,
17 whatever the case is, these problems arose from inadequate
18 root cause analysis.

19 The root cause analysis that's demanded by you in
20 your day-to-day work is really a key to understanding the
21 events and understanding the goal of the whole mission of
22 LER reporting.

23 LER reporting is a followup activity to feed back
24 information to others.

25 The root cause analysis that you require will go

1 ahead and satisfy a lot of the questions that have been
2 raised throughout the workshops, all four workshops.

3 So I just place the emphasis on the root cause
4 analysis. Then once that is thoroughly done, it seems much
5 easier to make a determination and the evaluations of
6 significance, and a lot of these fringe areas will fade away
7 given a thorough understanding of the events.

8 So I think that's where we really need to focus
9 and then the reporting would follow that.

10 Eric, do you have any comments?

11 MR. WEISS: No, thank you.

12 MR. WILLIAMS: Al?

13 MR. CHAFFEE: No.

14 MR. WILLIAMS: Thank you very much.

15 [At 11:45 a.m., the workshop in the above-
16 entitled matter was closed.]

17 - - -

18

19

20

21

22

23

24

25


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

NAME OF PROCEEDING: REGION IV AND V EVENT REPORTING
WORKSHOP, Volume II
PLACE OF PROCEEDINGS: Arlington, Texas
DATE: November 9, 1990

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



GAY E. DENTON

Official Reporter

Ann Riley & Associates, Ltd.

(4)


LICENSEE EVENT REPORTING WORKSHOP

SESSION #2

"RULEMAKING/GUIDANCE REVISION"



1989 LER DISTRIBUTION REPORTING CRITERIA



1989 ESF LERs (WITHOUT RPS)


. TOTAL LERs: 609 [1358 ACTUATIONS/ISOLATIONS]

	<u>TOTAL</u>	<u>UNNEEDED*</u>
. LERs WITH SINGLE ESF	432	325
HVAC SYSTEMS:	158	132
RWCU SYSTEM:	48	34

* MEASURED PARAMETER DID NOT REACH SETPOINT BAND.



1989 TECHNICAL SPECIFICATION LERs VIOLATIONS



I & C Systems - 43% of LCOs and 42% of Surveillances



CURRENT STAFF INITIATIVES

NEAR-TERM

- ELIMINATION OF SELECTED ESFs
- UNNEEDED¹ RWCU ISOLATION OR CONTROL ROOM HVAC ACTUATIONS
- ISSUANCE OF ADDITIONAL GUIDANCE (NUREG 1022 SUPP.3)

LONG-TERM

- SYSTEMATIC RE-EVALUATION OF REQUIREMENTS
- PROBABLE RULE CHANGE

¹ Unneeded actuations are those that are spurious or occur when the measured actuating parameter(x) did not reach the set-point(s) band.



REPORTING OF SAFEGUARDS EVENTS 10 CFR 73.71

Summary of Regulatory Base

- Significant Events
 - Prompt Reporting/1 Hour
 - NRC Operations Center
- Less Significant Events
 - Record in Log/24 Hours
 - Log to NRC Quarterly

HISTORY

Originally Published 1973

- Major Revision on June 9, 1987 to:
 - Clarify Reporting Requirements
 - Eliminate Unnecessary Reporting
 - Improve NRC's Data Analysis System

RG 5.62, "Reporting of Safeguards Events"

- Revised November 1987
 - Clarified Rule Revisions

NUREG-1304, "Reporting of Safeguards Events"

- Published February 1988
 - Documented Questions Discussed at September 14, 1987, Workshop

1-HOUR REPORTS

Purpose

- Prompt Notification
 - Significant Events
- Safe Operation of Plant(s)
- Health and Safety of Public
 - May Warrant NRC Oversight

NRC Use of Information

- Immediate Analysis
- Notification to Other Agencies

NRC Feedback

- Oversight if Appropriate
- Immediate Generic Communication if Appropriate
- Rule/Guidance Revision as Appropriate

LOGGABLE EVENTS

Purpose

- Notification Quarterly
 - Less Significant Events
- Safeguards System Effectiveness

NRC Use of Information

- Long-Term Analysis

Feedback

- Analyses to Licensees
- Generic Communication as Appropriate
- Rule/Guidance Revision as Appropriate
- IN-90-13, "Importance of Review and Analysis of Safeguards Event Logs"

ON-GOING ACTIVITIES

Revision to RG 5.62

- NUREG-1304
- Incorporate Lessons Learned/
2 Year's Experience

Generic Letter

- Policy Revision
- Eliminate Unnecessary Reporting

Responsive to Impact Survey

- Impact Survey Considered in Revision
to RG 5.62 and Generic Letter

6

Safeguards Event Log Analysis Program

10 CFR 73.71
Reporting of Safeguards Events

Office of Nuclear Material Safety and Safeguards
Division of Safeguards and Transportation
Joan Higdon (301) 492-0477

Safeguards Event Log Analysis Program

- Analysis of Reported Events
- Use of Event Data by NRC/Licensees
- Program Results
- New Initiatives

Analysis of Reported Events

- Categorization of safeguards events
 - Specific failed component
 - Type of human error
 - Influences by environment
- Quarterly Feedback Report to NRC and licensees
 - Statistical data for hardware system/human error events
 - Results of licensee self-assessment
 - Identifies factors impacting licensee reporting

NRC Use of Event Data

- Identify indicators of possible system/program weaknesses
- Provide feedback to licensees for maintaining effective safeguards system performance
- Provide input for NRC inspection planning

Industry Use of Event Data

- Perform self-assessment of a facility's security equipment and procedures
- Compare facility data against industry

Program Results

Event logs and feedback data bases for root cause analysis performed by licensee and NRC which resulted in:

- Improved equipment reliability
 - Card Readers
 - Computers
 - Perimeter detection system

- Reduced human error
 - Lost badges
 - Badges taken off site
 - Badges incorrectly issued
 - Unsecured door events

New Initiatives

Analysis to determine correlations between event data and facility design, equipment and special circumstances

- Normalization of data
- Root cause analysis