

Attachment 3

Engineered Safeguards
Busses Voltage Calculations

8211230288 821119
PDR ADDCK 05000302
P PDR



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS		CISID	04-5011-113	PAGE	2
REV.	0	1	2	3		OF	40
MICROFILMED						PAGES	
ORIGINATOR	P. C. Johnson						
DATE	7/8/82						

Purpose: To compare Engineered Safeguards Bus Voltages with those measured by Florida Power Corporation.

Sources of Information: These are identified at the appropriate part of the calculations.

Computer Calculation: Not applicable

Assumptions: These are identified at the appropriate part of the calculations.

Indetification of End Results: The comparison of calculated and measured voltages is shown in the Table at the end of the calculations.

The actual one line diagram used (except for impedance values) is given on page 37 of Calculations 11/20/79 in "Adequacy of Station Electric Distribution Voltages - Crystal River 3".

4.16 KV LOADS

Rated KVA taken from "Crystal River Unit 3 - Auxiliary Loading pages 3 and 4.

Number of motors running taken from those in "Adequacy of Station Electric Distribution voltages" pages 4, 5 of Calculations 10/21/80. KVA calculated from latest current information shown on the motor data sheets.

Power factors were also taken from motor data sheets; the power factor of the Auxiliary Building Exhaust Fans, since they were running at just over 50% load was estimated from the full load power factor.

As the impedance of an induction motor will vary as the voltage applied to the terminals, the terminal voltage was estimated at .99 of 4.16 KV (base voltage) from preliminary calcuations.



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS

CISID 04-5011-113

PAGE 3

OF

REV. 0 1 2 3

MICROFILMED

PAGES 40

ORIGINATOR *J.C. Wilson*

DATE 7/8/82

The impedance of an induction motor when running is given by

$$Z_{base} = Z_{rated} \times \left(\frac{\text{Actual Terminal Voltage}}{\text{Base Voltage}} \right)^2$$

In calculating the impedance from rated KVA, in terms of the base MVA, motor KVA has been multiplied by $\left(\frac{\text{Base Voltage}}{\text{Actual Terminal Voltage}} \right)^2$, since impedance is proportioned to the inverse of the KVA.

Motor impedance is then $\frac{\text{Base MVA}}{\text{Motor MVA}}$

Base MVA has been taken throughout as 100.

Unit Bus 3A	KVA		pf	KW	KVAR	Converted to Motor 4.16KV Base			
	Rated	Running				Volts	MW	MVAR	MVA
1. CW Pump 3A	1700	1700	.822	1397	968	.99			
2. CW Pump 3C	1700	1700	.822	1397	968	.99			
3. Sec. Service Closed Cycle Pp. 3A	317	317	.875	277	153	.99			
4. Feedwater Boster Pp.	2110	2110	.91	1920	875	.99			
5. Condensate Pp. 3A	1750	1750	.9	1575	763	.99			
6. Normal Nuc. Serv. Sea Water Pp. 3	328	328	.843	277	176	.99			
7. Aux. Bldg. Exh.	180	100	.85	85	53	.99			
8.				6928	3956		7.069	4.036	8.14

Unit Bus 3B

9. CW Pump 3B	1700	1700	.822	1397	968	.99			
10. CW Pump 3D	1700	1700	.822	1397	968	.99			
11. Sec Service Closed Cycle Pp. 3B	317	317	.875	277	153	.99			



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT **ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS**

CISID
04-5011-113

PAGE
4
OF
40
PAGES

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>R. W. Brown</i>			
DATE	7/8/82			

Unit Bus 3B	KVA		pf	KW	KVAR	Converted to Motor 4.16KV Base			
	Rated	Running				Volts	MW	MVAR	MVA
12. Feedwater Booster	2110	2100	.91	1920	875	.99			
13. Condensate Pp. 3B	1750	1750	.9	1575	763	.99			
14. Norm. Nuc. Serv. CCC Pp. 3	227	227	.843	277	176	.99			
15. Aux. Bldg. Exh.	180	100	.85	85	53	.99			
16. Fan 3B				6851	3888		6.99	3.967	8.0372

	Z	∅	R + jX
Unit Bus 3A	12.285	29.72°	10.669 + j 6.0904
Unit Bus 3B	12.442	29.58°	10.82 + j 6.142

ES Bus 3A	KVA		pf	KW	KVAR	Converted to Motor 4.16KV Base			
	Rated	Running				Volts	MW	MVAR	MVA
Make UP Pump 3A	588	588	.926	545	222	.99			
Reactor Bldg. Spray Pump 3A	215	215	.925	199	82	.99			
Decay Heat Pump	339	339	.921	312	132	.99			
Emerg. N. S. Sea Water Pump 3A	643	643	.87	559	317	.99			
Emerg. N. S. CCC Pump 3A	620	620	.89	552	283	.99			
Decay Heat Serv. Sea Water Pp.	285	285	.827	236	160	.99			
				2403	1196		2.452	1.22	2.7387



Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS			CISID	04-5011-113	PAGE	5
REV.	0	1	2	3	OF			
MICROFILMED					PAGES			
ORIGINATOR	TC Wilson							
DATE	7/8/82							

	Z	Ø	R + jX
ES Bus 3A	36.513	26.45	32.691 + j 16.264
ES Bus 3B	36.513	26.45	32.691 + j 16.264

6.9 KV LOADS

Only the Reactor Coolant Pumps.

Volts = 6.6 KV FLC = 685 amp. 1250 rmp. synchronous

KVA Input = $\sqrt{3} \times 6.6 \times 685 = 7830$

hp = 9000

kW Output = $9000 \times .746 = 6714$

$$\text{pf} \times \text{efficiency} = \frac{6714}{7830} = .8575$$

Efficiency must be less than unity, so that pf must be greater than .8575.

Examine 4 KV Motors

hp	rpm	efficiency	pf	
2000	1200	.946	.9	
1750	257	.934	.822	low speed, not fair comparison
400	1800	.938	.921	
800	1800	.936	.89	
2500	1800	.948	.91	
700	1800	.951	.926	
700	900	.933	.87	
700	1200	.933	.89	

Lowest efficiency = .933 If we use this, pf would be $\frac{.8575}{.933} = .919$ Highest pf in above table = .926, but this is at 1800 rpm.



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS

CISID
04-5011-113

PAGE
6

REV.	0	1	2	3	OF 40
MICROFILMED					PAGES
ORIGINATOR	<i>J. Wilson</i>				
DATE	7/8/82				

Suggest use .9 pf for reactor coolant pump motor.

Running Load = 4 x 7020 KVA = 28.08 MVA at 6.6KV.

Impedance at rated volts on 100 MVA base = $\frac{100}{28.08} = 3.56125$ pu.

Preliminary calculations showed that volts at motor terminals was approximately 1.033 pu of base voltage, 6.9 KV

Impedance at 6.9 KV = $3.56125 \times 1.033^2 = 3.8007 \epsilon j 25.84$
= 3.42021 + j 1.65634

480 V LOADS

Loads directly connected to the 480 V Switchgear Buses are taken from "Adequacy of Station Electric Distribution Voltages" - Calculations 10/21/80 pp. 5 thru 7. Pf taken from motor data sheets. Motor KVA Loads are based on 460 volts. See "Crystal River 3 - Auxiliary Loading."

Loads on Motor Control Centers are taken from "Adequacy of Station Electric Distribution Voltage" - Calculations 11/20/79. For the ES Buses the case is Load at End of Block Loading Sequence Including Manually Applied Loads. The loads have been calculated on 480 volts so the motor loads must first be expressed in terms of the 460 volt rating - See "Crystal River 3 - Auxiliary Loading". From examination of motor data sheets it was apparent that an average pf of 0.85 would be a suitable value.

Non motor loads were expressed at 480 volts, so as these are constant impedance loads there is no need to convert to a rated 460 volts.

In order to simulate cable impedances to loads, the load impedances were increased by 2%.

Motor Terminal voltages on the Unit Buses were estimated to be 94% of base voltage and 93% of base voltage on ES Buses. These figures were obtained from preliminary calculations.



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS		CISID	04-5011-113	PAGE	7
REV.	0	1	2	3		OF	40
MICROFILMED						PAGES	
ORIGINATOR		<i>R. J. ...</i>					
DATE		7/8/82					

480 V LOADS CONNECTED DIRECTLY TO SWITCHGEAR BUSES

	KVA 460. V		pf	Running		KVA 480 V
	Connected	Running		KW	KVAR	
Condr. Vac. Pump 3A	137	137	. 92	126	54	
Station Service Air Compressor 3A	91	50	.905	45	21	
React Bldg. Ind. Cooler Pump 3A	73	50	.835	42	28	
Cond. Injection Pump 3A	134	50	.915	46	20	
				<u>259</u>	<u>123</u>	
<u>Resistive</u>						<u>315</u>
<u>480V React Aux Bus 3A</u>						
Inst. Air Compressor 3A		50	.905	<u>45</u>	<u>21</u>	
<u>Resistive</u>						<u>345</u>
<u>480V Intake Bus 3A</u>						
Screen Wash Pump		70	. 85	<u>60</u>	<u>37</u>	
<u>480V Heating Bus 3</u>						
Heaters						<u>827</u>
<u>480V Turbine Bus 3B</u>						
Motors - As Bus 3A				<u>259</u>	<u>123</u>	
Heaters						<u>195</u>
<u>480V Reactor Aux. Bus 3B</u>						
Motors - As Bus 3A		50	.905	<u>45</u>	<u>21</u>	
Heaters						<u>20</u>



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS		CISID	04-5011-113	PAGE	8	
REV.	0	1	2	3		OF	40	
MICROFILMED							PAGES	
ORIGINATOR <i>J. Wilson</i>								
DATE 7/8/82								

	KVA 460. V		pf	Running		KVA 480 V
	Connected	Running		kW	KVAR	
<u>480V Intake Bus 3B</u>						
Screen Wash Pump 3B		70	. 85	60		37
Screen Wash Pump 3C		70	. 85	<u>60</u>		<u>37</u>
				<u>120</u>		<u>74</u>
<u>480V ES Bus 3A</u>						
Decay Heat CCC Pump 3A		96	. 86	83		49
Cont. Comp. Wat.		213	. 9	<u>192</u>		<u>93</u>
Chiller 3A				<u>275</u>		<u>142</u>
<u>480V ES Bus 3B</u>						
As Bus 3A				<u>275</u>		<u>142</u>
<u>480V Plant Aux. Bus 3</u>						
Resistive						<u>733</u>



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

4.16KV UNIT BUS 3A 480V LOAD IMPEDANCES

	KVA 480V	KW 460V	KVAR	Motor Volts	Converted to		MVA	Z	Ø	i.02Z	R + j x	
					480V KW	Base KVAR						
<u>Heating Transformer</u>												
Resistive	827						.827	120.92	0	123.34	123.34+j0	
<u>Machine Shop MCC</u>												
Motors	102.3	83.4	51.75	.94	94.39	58.57						
Heaters	177				177	58.57						
					271.39	58.57	.27764	360.18	12.18	367.38	359.11+j77.5	
<u>Turbine Aux xfr. 3A</u>												
<u>Turbine Bus 3A</u>												
Motors		259	123	.94	293	139						
Heaters	315				315							
					608	139	.62369	160.34	12.88	163.54	159.43+j36.45	
<u>Turbine MCC 3A</u>												
Motors	288	235	146	.94	266	165						
Heaters	219				219							
					485	165	.5123	195.2	18.79	199.1	188.49+j64.13	
<u>Water Treat MCC 3A</u>												
Motors	205.4	167	104	.94	189	118						
Heaters	50				50							
					239	118	.26654	375.17	26.28	382.68	343.13+j169.43	

SUBJECT ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS	REV.	0	CISID 04-5011-113	PAGE 9
	MICROFILMED			
	ORIGINATOR	C. H. Brown		
	DATE	7/8/82		
		1		
		2		
		3		
			PAGES	40



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

4.16KV UNIT BUS 3A 480V LOAD IMPEDANCES (Cont'd)

	KVA 480V	KW 460V	KVAR	Motor Volts	Converted to		MVA	Z	Ø	1.02Z	R + j x	
					480V KW	Base KVAR						
Vent MCC 3A												
Motors	284	231	143	.94	261	162						
Heaters	125				12.5							
					<u>273.5</u>	<u>162</u>	.31788	314.59	30.64	320.88	276.08+j163.53	
Reactor Aux. xfr 3A												
Reator Bus 3A												
Motors		45	21	.94	51	24						
Heaters	345				345							
					<u>396</u>	<u>24</u>	.39673	252.06	3.47	257.1	256.63+j15.56	
Reactor MCC 3A1												
Motors	52.2	43	26	.94	49	29						
Heaters	124.3				124.3							
					<u>173.3</u>	<u>29</u>	.17571	569.12	9.5	500.5	493.64+j82.61	
Press. Heater MCC 3A	726				726		.726	137.74	0	140.5	140.5+j0	

SUBJECT	ENGINEERED SAFEGUARDS	CISID	04-5011-113	PAGE	10
REV.	0	1	2	3	OF
MICROFILMED					
ORIGINATOR	7/8/82				PAGES
DATE					40

4.16KV UNIT BUS 3A 480V LOAD IMPEDANCES (Cont'd)

	KVA 480V	KW 460V	KVAR 460V	Motor Volts	Converted to		MVA	Z	θ	1.02Z	R +
					480V KW	Base KVAR					
Reactor MCC 3A2											
Motors	92.6	75	47	.94	85	53					
Heaters	114.4				114.4						
					199.4	53	.20632	484.68	14.8F	494.37	477.79+j126.95
<u>Intake xfr. 3A</u>											
Intake Bus 3A											
Motors		60	37	.94	68	42	.07992	1251.17	31.7	1276.2	1085.81+j670.61
Heaters											
Intake MCC 3A											
Motors	54.2	44	28	.94	50	32					
Heaters	60				60						
					110	32	.11456	872.9	16.22	890.36	854.92+j248.7



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

ENGINEERED SAFEGUARDS
USES VOLTAGE CALCULATIONS
DATE 7/8/82
FILMED
INATOR
CISID 04-5011-113
PAGE 11 OF 40 PAGES 40



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

4.16KV UNIT BUS 3B 480V LOAD IMPEDANCES (Cont'd)

	KVA 480V	KW 460V	KVAR 460V	Motor Volts	Converted to		MVA	Z	Ø	1.0ZZ	R + j x	
					480V KW	Base KVAR						
Vent MCC 3B												
Motors	299	243	151	.94	275	171						
Resistive	21				21							
					296	171	.34184	292.53	30.02	298.39	258.36+j149.29	
Reactor Aux. xfr 3B												
Reactor Bus 3B												
Motors		45	21-	.94	51	24						
Resistive	20				20							
					71	24	.07495	1334.28	18.68	1360.97	1289.28+j435.89	
Reactor MCC 3B1												
Motors	42.3	35	21	.94	40	24						
Resistive	57				57							
					97	24	.09992	1000.75	13.9	1020.77	990.88+j245.22	

SUBJECT	ENGINEERED SAFEGUARDS	CISID	PAGE
BUSES VOLTAGE CALCULATIONS		04-5011-113	13
REV.	0		OF
MICROFILMED	1		40
ORIGINAL	2		PAGES
DATE	7/8/82		



Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION

4.16KV UNIT BUS 3B 480V LOAD IMPEDANCES (Cont'd)

Converted to

	KVA	KW	KVAR	Motor	480V	Base					
	480V	460V	Volts		KW	KVAR	MVA	Z	θ	1.02Z	R + j x
Reactor MCC 3B2											
Motors	83.5	68	42	.94	77	48					
Resistive	147				147						
					<u>224</u>	<u>48</u>	<u>.22909</u>	<u>436.52</u>	<u>12.09</u>	<u>445.25</u>	435.37+j93.26
Press Heater 3B	847				<u>847</u>		<u>847</u>	<u>118.06</u>	<u>0</u>	<u>120.43</u>	120.63+j0
Intake xfr 3B											
Intake Bus 3B											
Motors		120	74	.94	<u>136</u>	<u>84</u>	<u>.15985</u>	<u>625.59</u>	<u>317</u>	<u>638.1</u>	542.9+j335.3
WTMCC 3C											
Motors	134	109	68	.94	<u>123</u>	<u>77</u>	<u>.14511</u>	<u>689.11</u>	<u>32.05</u>	<u>702.9</u>	595.77+j373

SUBJECT	ENGINEERED SAFEGUARDS	CISID	PAGE
BUSES VOLTAGE CALCULATIONS		04-5011-113	14
REV.	0		OF
MICROFILMED			40
ORIGINATOR	<i>R. D. Brown</i>		PAGES
DATE	7/8/82		

4.16KV UNIT BUS 3A 480V LOAD IMPEDANCES

	KVA 480V	KW 460V	KVAR	Motor Volts	Converted to		MVA	Z	Ø	1.02Z	R + j x	
					480V KW	Base KVAR						
<u>ES Aux xfr 3A</u>												
ES Bus 3A												
Motors		275	142	.93	318	164	.3578	279.49	27.28	285.08	253.37+j130.66	
<u>ES MCC 3A1</u>												
Motors	97.1	80	49	.93	92	57						
Resistive	213				213							
					305	57	.31028	322.29	10.59	328.73	323.13+j60.41	
<u>ES MCC 3A2</u>												
Motors	240.1	196	122	.93	227	141						
Resistive	88				88							
					315	141	.34512	289.76	24.11	295.55	269.77+j120.73	
<u>ES MCC 3AB</u>												
Motors	119.4	98	60	.93	113	69						
Resistive	39				39							
					152	69	.16693	599.06	24.42	611.04	556.38+j252.62	



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

DATE 7/8/82	ORIGINATOR <i>R. W. Brown</i>	MICROFILMED	REV. 0	SUBJECT ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS	CISID 04-5011-113	PAGE 15
			1			OF 40
			2			PAGES
			3			



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

4.16KV UNIT BUS 3B 480V LOAD IMPEDANCES

	KVA 480V	KW 460V	KVAR	Motor Volts	Converted to		MVA	Z	θ	1.02Z	R + j x	
					480V KW	Base KVAR						
<u>ES Aux xfr 3B</u>												
Motors		275	142	.93	318	163	.3578	279.49	27.28	285.08	253.37+j130.66	
<u>ES MCC 3B1</u>												
Motors	260.9	213	132	.93	246	153						
Resistive	96				96							
					342	153	.37466	266.91	24.1	272.25	248.52+j111.16	
<u>ES MCC 3B2</u>												
Motors	70.95	58	35	.93	67	40						
Resistive	236				236							
					303	40	.30563	327.19	7.52	333.74	330.87+j43.68	
<u>ES MCC 3AB</u>												
		98	60	.93	113	69						
	39				39							
					152	69	.16693	599.06	24.42	611.04	556.38+j252.62	
<u>Plant Aux xfr 3</u>												
	733						.733	136.43	0	139.15	139.15+j0	

SUBJECT	ENGINEERED SAFEGUARDS	CISID	04-5011-113	PAGE	16
REV.	0	1	2	3	OF
MICROFILMED					40
ORIGINATOR	TC				PAGES
DATE	7/8/82				

NOTE: As ES MCC 3AB can be supplied from either ES Bus 3A or ES Bus 3B, for the purpose of the calculation it was assumed to be supplied from ES Bus 3A.



Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS		CISID		PAGE	
		BUSES VOLTAGE CALCULATIONS		04-5011-113		17	
REV.	0	1	2	3	OF		40
MICROFILMED					PAGES		
ORIGINATOR	R. Wilson						
DATE	7/8/82						

CABLE IMPEDANCES


4.16 and 6.9 KV cable impedances were ignored. Previous experience has shown that for voltage drop calculations, these impedances are so small as to be justifiably disregarded.

Although cable impedances from 480 volt switchgear to Motor Control Centers are of little significance, they were taken into account by using actual lengths; the resistance and reactance for 1000 yards were taken from typical 600 V cable information.

REACTORS

The per unit values of reactance were taken from "Adequacy of Station Electric Distribution Voltages - Crystal River 3" - Calculations dated 11/20/79.

ENGINEERED SAFEGUARDS VOLTAGE CALCULATIONS													PAGE 18
CISID 04-5011-113													PAGE OF 40
/8/82													1
Reactor Aux xfr 3A	Reactor MCC 3A1	500	2	.0294	.0257	538	.00791	.00691	3.433	2.999	-	2.999	1
	Press. Htr. MCC 3A	750	3	.021	.025	313	.00219	.00261	.9505	1.1328	2.1701	3.3029	
	Reactor MCC 3A2	350	2	.0406	.0264	309	.00627	.00408	2.721	1.771	1.997	3.768	
Intake Aux xfr 3A	Intake MCC 3A	350	1	.0406	.0264	60	.00122	.00158	.53	.686	-	.686	2
Turbine Aux xfr 3B	Turbine MCC 3B	500	2	.0294	.0257	356	.00524	.00457	2.274	1.984	1.997	3.981	3
	WT MCC 3B	500	2	.0294	.0257	416	.00612	.00535	2.656	2.322	1.997	4.319	
	Vent MCC 3B	500	2	.0294	.0257	318	.00468	.00409	2.118	1.755	1.997	3.752	
Reactor Aux xfr 3B	Reactor MCC 3B1	500	2	.0294	.0257	530	.00779	.00681	3.381	2.956	-	2.956	4
	Press. Htr. MCC 3B	750	3	.021	.025	326	.00228	.00272	.9896	1.181	2.1701	3.3511	
	Reactor MCC 3B2	500	2	.0294	.0257	347	.0051	.00446	2.214	1.936	-	1.936	
Intake Aux xfr 3B	WT MCC 3C	500	2	.0294	.0257	630	.00926	.0081	4.019	3.516	-	3.516	5
ES Aux xfr 3A	ES MCC 3A1	350	2	.0406	.0264	120	.00244	.00158	1.059	.686	-	.686	6
	ES MCC 3A2	350	2	.0406	.0264	157	.00319	.00207	1.385	.898	-	.898	
	ES MCC 3AB	500	1	.0294	.0257	265	.00779	.00681	3.381	2.956	-	2.956	
ES Aux xfr 3B	ES MCC 3B1	500	2	.0294	.0257	198	.00291	.00254	1.263	1.102	-	1.102	7
	ES MCC 3B2	500	2	.0294	.0257	226	.00332	.0029	1.441	1.259	-	1.259	
	ES MCC 3AB	500	1	.0294	.0257	295	.00867	.00758	3.763	3.29	-	3.29	



SUBJECT
BUSI
REV.
MICROFILME
ORIGINATOR
DATE


CABLE IMPEDANCES

4.16 and 6.9 KV cable impedances for voltage drop calculations, t disregarded.

Although cable impedances from 4. little significance, they were t resistance and reactance for 100 information.

REACTORS

The per unit values of reactance Distribution Voltages - Crystal

 Gilbert Associates, Inc. Reading, Pennsylvania CALCULATION	SUBJECT			ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS	CISID	04-5011-113	PAGE	19
	REV.	0	1	2	3		CF	
	MICROFILMED						PAGES	40
	ORIGINATOR	<i>[Signature]</i>						
DATE	7/8/82							

TRANSFORMER IMPEDANCES

The Start Up Transformer equivalent circuit impedance was developed from test data supplied by telephone 6/15/82 from Florida Power Corporation.

The 4160/480 volt transformer impedances were obtained from Test Reports in Correspondence File EE (letter dated 7/8/1971.) As it was not known which serial number applied to individual transformers an average value was taken for each KVA rating. Individual values were so close that any variation would be insignificant.

The tap setting for the Start Up Transformer was 224 250 volts which was the setting when voltage measurements were taken.

As FPC did not know the taps on which the 4160/480 volt transformer were set, calculations were performed with those transformers on nominal taps. (Telephone conversation with FPC 6/17/82).

START-UP TRANSFORMER IMPEDANCES

Resistance

Load Loss H-X = 31.9 KW at 18 MVA

Load Loss H-Y = 62.5 KW at 15 MVA

Load Loss X-Y = 77.65 KW at 15 MVA

$$R_{pu} \text{ H-X} = \frac{31.9}{18000} = .001772 \text{ at 18 MVA} = .009844 \text{ at 100 MVA}$$

$$\text{H-Y} = \frac{62.5}{15000} = .004167 \text{ at 15 MVA} = .02778 \text{ at 100 MVA}$$

$$\text{X-Y} = \frac{77.65}{15000} = .005177 \text{ at 15 MVA} = .034513 \text{ at 100 MVA}$$



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS		CISID		PAGE	
		BUSES VOLTAGE CALCULATIONS		04-5011-113		20	
REV.	0	1	2	3	OF		
MICROFILMED					40		
ORIGINATOR	C. Wilson				PAGES		
DATE	7/8/82						

$$HO = \frac{HX+HY-XY}{2} = \frac{.009844+.02778-.034513}{2} = .001556 \text{ pu}$$

$$OX = \frac{HX+XY-HY}{2} = \frac{.009844+.034513-.02778}{2} = .008289 \text{ pu}$$

$$OY = \frac{XY+HY-HX}{2} = \frac{.034513+.02778-.009844}{2} = .026225 \text{ pu}$$

$$Zpu \text{ H-X} = .0585 \text{ pu at 18 MVA} = .325 \text{ pu at 100 MVA}$$

$$\text{H-Y} = .086 \text{ pu at 15 MVA} = .57333 \text{ pu at 100 MVA}$$

$$\text{X-Y} = .1158 \text{ pu at 15 MVA} = .772 \text{ pu at 100 MVA}$$

$$HO = \frac{.325+.57333-.772}{2} = .063165$$

$$OX = \frac{.325+.772-.57333}{2} = .261835$$

$$OY = \frac{.772+.57333-.325}{2} = .510165$$

$$Xpu = Zpu^2 - R^2pu \quad 1/2$$

$$HO = .063165^2 - .001556^2 \quad 1/2 = .063146$$

$$OX = .261835^2 - .008289^2 \quad 1/2 = .261704$$

$$OY = .510165^2 - .026225^2 \quad 1/2 = .509491$$



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS				CISID 02-5011-113	PAGE 21
REV.	0	1	2	3	OF 40
MICROFILMED					PAGES
ORIGINATOR <i>R. Wilson</i>					
DATE 7/8/82					

4160/480 VOLT TRANSFORMER IMPEDANCES

KVA	LOAD					DARE	SERIAL NO.	PER UNIT	
	LOSS KW	R%	Z%	X%	IMPEDANCE ON				
500	3.816	.7632	4.85	4.7896	1.29.71	48-20329-C1	100 MVA BASE		
500	3.831	.7662	4.99	4.9315	1.29.71	48-20329-D1	R	X	
Average		<u>.7647</u>		<u>4.8606</u>			1.5294	9.7212	
1000	11.973	1.1973	5.35	5.2143	1.26.71	20329-B1			
	11.871	1.1871	5.32	5.1859		20329-B2			
	11.858	1.1858	5.28	5.1451		20329-B3			
Average	11.9007	<u>1.1907</u>		<u>5.1818</u>			1.1907	5.1818	
1500	13.887	<u>.9258</u>	5.36	<u>5.2794</u>	2.10.71	20329-A3	.6172	3.5196	
2000	18.705	.9533	5.97	5.8934	5.14.71	48-20329-E01			
	18.775	.93875	5.96	5.8856	5.14.71	48-20329-E02			
	19.034	.9517	5.95	5.8734	5.15.71	48-20329-E03			
	18.39	.9195	5.63	5.5544	5.15.71	48-20329-E04			
Average		<u>.9408</u>		<u>5.8017</u>			.4704	2.90085	



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION


**SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS**

**CISID
04-5011-113**

**PAGE 22
OF 40
PAGES**

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>Christman</i>			
DATE	7/8/82			

4.16 KV Unit Bus 3A





Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS

CISID

04-5011-113

PAGE 23

REV. 0 1 2 3

MICROFILMED

ORIGINATOR *S.L. Wilson*


DATE 7/8/82

OF 40
PAGES

10.669+j6.0904

10.669+j6.0904

4.16 KV Unit Bus 3A





Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION


SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS

CISID 04-5011-113

PAGE 24
OF 40
PAGES

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>[Signature]</i>			
DATE	7/8/82			

4.16 KV Unit Bus 3A






Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS		CISID	04-5011-113	PAGE	25
REV.	0	1	2	3		OF	40
MICROFILMED						PAGES	
ORIGINATOR <i>R. Wilson</i>							
DATE 7/8/82							

4.16 KV Unit Bus 3B






Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS		CISID	04-5011-113	PAGE	26
REV.	0	1	2	3		OF	40
MICROFILMED						PAGES	
ORIGINATOR	<i>Wilson</i>						
DATE	7/8/82						

4.16 KV Unit Bus 3B





Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION


SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS


CISID 04-5011-113


PAGE 27
OF 40
PAGES


REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	P. Wilson			
DATE	7/8/82			


4.16 KV Unit Bus 3B

10.82+j6.142


286.514+j187.081


82.648+j10.901


67.122+j28.796


8.274+j4.122




Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT **ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS**

CISID
04-5011-113

PAGE **28**
OF
PAGES **40**

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>R. Wilson</i>			
DATE	7/8/82			

ES 4.16 kV Bus 3B

$1.1907 + j5.1818$

$139.15 + j0$

Plant Bus

$32.691 + j16.264$

$1.1907 + j5.1818$

$1.441 + j1.259$

$330.87 + j43.68$

ES MCC 3B2

$1.263 + j1.102$

$248.52 + j111.16$

ES MCC 3B1

$253.37 + j130.66$

ES BUS 3B

ES 480V Bus 3B

ES 416 kV Bus 3A

$32.691 + j16.264$

$1.1907 + j5.1818$

$3.381 + j2.956$

$556.38 + j252.62$

ES MCC 3AB

$1.385 + j.898$

$269.77 + j120.73$

ES MCC 3A2

$1.059 + j.686$

$323.13 + j60.41$

ES MCC 3A1

$253.37 + j130.66$

ES Bus 3A

ES 480V Bus 3A



Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION

SUBJECT **ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS**

CISID

04-5011-113

PAGE

28

REV.

0

1

2

3

MICROFILMED

ORIGINATOR

R. Wilson

DATE

7/8/82

OF
40
PAGES

ES 4.16 kV Bus 3B

1.1907+j5.1818

139.15+j0

Plant Bus

32.691+j16.264

1.1907+j5.1818

1.441+j1.259

330.87+j43.68

ES MCC 3B2

+j1.102

248.52+j111.16

ES MCC 3B1

253.37+j130.66

ES BUS 3B

32.691+j16.264

3.381+j2.956

556.38+j252.62

ES MCC 3AB

1.385+j.898

269.77+j120.73

ES MCC 3A2

1.1907+j5.1818

1.059+j.686

323.13+j60.41

ES MCC 3A1

253.37+j130.66

ES Bus 3A

ES 480V Bus 3B

ES 480V Bus 3A


ES 416 kV Bus 3A




Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT ENGINEERED SAFEGUARDS BUSES VOLTAGE CALCULATIONS				CISID 04-5011-113	PAGE 29
REV.	0	1	2	3	OF 40
MICROFILMED					PAGES
ORIGINATOR	<i>R. Johnson</i>				
DATE	7/8/82				

ES 4.16 kV Bus 3B



ES 4.16 kV Bus 3A





Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS

CISID 04-5011-113

PAGE 30
OF 40
PAGES

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>W. J. ...</i>			
DATE	7/8/82			

Plant

140.341+j5.1618



ES 4.16 kV Bus 3B

32.691+j16.264



21.226+j8.495



94.566+j39.959



ES 4.16 kV Bus 3A

32.691+j16.264



23.41+j11.347



82.367+j37.3518





Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT **ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS**


CISID **04-5011-113**

PAGE **31**
OF

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>R. Johnson</i>			
DATE	7/8/82			

PAGES **40**

Y Terminals of Start Up Transformer





Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION




SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS

CISID 04-5011-113

PAGE 32
OF 40
PAGES

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	R. Carlson			
DATE	7/8/82			

Voltage At 4.16 kv Buses and 6.9 kv Buses



Volts at 0 = $\frac{Z_2}{Z_1 + Z_2}$ = .9815 of Volts at H

Measured voltage at H = 244.8 kv

Tap = 224.25 kv

Equivalent No load volts at H = 244.8/224.25 = 1.091639 p.u.



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS

CISID
04-5011-113

PAGE
33

REV.	0	1	2	3	OF 40
MICROFILMED					PAGES
ORIGINATOR	<i>C. W. [Signature]</i>				
DATE	7/8/82				

Voltage at 0 = .9815 x 1.091639 = 1.07144 p.u.

Voltage at Y = $\frac{2.902+j1.405}{.026225+j.50949+2.902+j1.405}$ x 1.07144 p.u.

= .92159 x 1.07144 = .98743 p.m. = .98743 x 4.16 = 4.108 kv

This is voltage at 4.16 kv bus.

We used .99% base voltage at 4 kv motor terminals to determine the motor impedance, which is very close to .98743 so that no readjustment of motor impedance is necessary

Voltage at X = $\frac{3.42021+j1.65634}{.008289+j.261835+3.4202+j1.65634}$ x 1.07144 p.u.

= .967305 x 1.07144 = 1.0364 p.u. which is sufficiently close to the value of 1.033 p.u. assumed for motor voltage so that no readjustment of motor impedance is necessary.




Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS		CISID		PAGE	
		BUSES VOLTAGE CALCULATIONS		04-5011-113		34	
REV.	0	1	2	3	OF		
MICROFILMED					40		
ORIGINATOR <i>C. M. ...</i>					PAGES		
DATE 7/8/82							

VOLTAGE AT ES 480V BUS 3A

From page 30

E.S. 4.16kv Bus 3A Volts .98743 p.u.




$$\begin{aligned} \text{Voltage at 480V Bus} &= \frac{81.176+j32.19}{1.1907+j5.1618+81.176+j32.19} \times .98743 \text{ p.u.} \\ &= .96556 \times .98743 = .95342 \text{ p.u.} \\ &= .95342480 = 457.6 \end{aligned}$$

VOLTAGE AT ES 480V BUS 3B

From page 30

ES 4.16kv Bus 3B Volts = .98743 p.u.



$$\begin{aligned} \text{Voltage at 480V Bus} &= \frac{93.375+j34.797}{1.1907+j5.1618+93.375+j34.797} \times .98743 \\ &= .97065 \times .98743 = .95845 \text{ p.u.} \\ &= .95845 \times 480 = 460\text{V} \end{aligned}$$




Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS		CISID		PAGE	
		BUSES VOLTAGE CALCULATIONS		04-5011-113		35	
REV.	0	1	2	3	OF		
MICROFILMED					40		
ORIGINATOR <i>W. Johnson</i>					PAGES		
DATE 7/8/82							

VOLTAGE AT ESMCC3A1


From page 29



$$\begin{aligned} \text{Voltage at MCC 3A1} &= \frac{323.13+j60.41}{1.059+j.686+323.13+j60.41} \times .95342 \\ &= .99646 \times .95342 = .95004 \text{ p.u.} \\ &= .95004 \times 480 = 456 \text{ volts} \end{aligned}$$

VOLTAGE AT ES MCC 3A2

From page 29



$$\begin{aligned} \text{Voltage at MCC 3A2} &= \frac{269.77+j120.73}{1.385+j.898+269.77+j120.73} \times .95342 \text{ p.u.} \\ &= .99451 \times .95342 = .94819 \text{ p.u.} \\ &= .94819 \times 480 = 455.1 \text{ volts} \end{aligned}$$



Gilbert Associates, Inc.


Reading, Pennsylvania

CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS		CISID		PAGE	
		BUSES VOLTAGE CALCULATIONS		04-5011-113		37	
REV.	0	1	2	3	OF		
MICROFILMED					40		
ORIGINATOR <i>TC Johnson</i>					PAGES		
DATE 7/8/82							

VOLTAGE AT ESMCC 3B1


From page 29



$$\begin{aligned} \text{Voltage at MCC 3B1} &= \frac{248.52 + j111.16}{1.263 + j1.102 + 248.52 + j111.16} \times .95845 \text{ p.u.} \\ &= .99415 \times .95845 = .9528 \text{ p.u.} \\ &= .9528 \times 480 = 457.3 \text{ volts} \end{aligned}$$

VOLTAGE AT ES MCC 3B2

From page 29



$$\begin{aligned} \text{Voltage at MCC 3B2} &= \frac{330.87 + j43.68}{1.441 + j1.259 + 330.87 + j43.68} \times .95845 \text{ p.u.} \\ &= .99524 \times .95845 = .95389 \text{ p.u.} \\ &= .95389 \times 480 = 457.9 \text{ volts} \end{aligned}$$



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS

CISID 04-5011-113


PAGE 36
OF 40
PAGES

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>R. Wilson</i>			
DATE	7/8/82			

VOLTAGE AT ESMCC3AB

from page 29

ES480VBus3A Volts .95342 p.u.



$$\text{Voltage at ESMCC3AB} = \frac{556.38+j252.62}{3.381+j2.956+j556.38+j252.62} \times .95342$$

$$= .99301 \times .95342 = .94676 \text{ p.u.}$$

$$= .94676 \times 480 = 454.4 \text{ volts}$$



Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS		CISID		PAGE	
		BUSES VOLTAGE CALCULATIONS		04-5011-113		38	
REV.	0	1	2	3	OF		
MICROFILMED					40		
ORIGINATOR: <i>Chulson</i>					PAGES		
DATE 7/8/82							

Bus	Calculated Value	Measured Values Plant At Full Load Steady State Condition
230kv Grid	244.8kv	244.8kv
4160V Switchgear		
ES Bus 3A	4108V	4183V
ES Bus 3B	4108V	4179V
480V Switchgear		
ES Bus 3A	458V	472V
ES Bus 3B	460V	475V
MCC480V		
ES 3A1	456V	469V
ES 3A2	455V	468V
ES 3AB	454V	468V
ES 3B1	457V	472V
ES 3B2	458V	471V

The calculations were made on the basis of the 4160/480 volt transformers being on the nominal tap. If, however the tap was such as to give a 2-1/2% voltage boost then the 480V switchgear and MCC voltages would be increased by approximately 2-1/2%.

If the voltage on the high voltage side of the startup transformer were $240 - 1\frac{1}{2}\% = 236.4\text{kv}$, the calculated voltages would be obtained as a very close approximation by multiplying the calculated voltages in the above table by .965686.



Gilbert Associates, Inc.
Reading, Pennsylvania
CALCULATION

SUBJECT **ENGINEERED SAFEGUARDS
BUSES VOLTAGE CALCULATIONS**

CISID
04-5011-113

PAGE
39
OF
40
PAGES

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	<i>R. Wilson</i>			
DATE	7/8/82			

Impedance of Load on Y winding of Start Up Transformers = $2.902 + j1.405 = 3.224$ pu
which corresponds to a load of $\frac{100}{3.224} = 31.015$ MVA at .9 pf.

FOA 65C rating of Y winding = 28 MVA.

Impedance of load on ES Aux Transformers 3A = $81.176 + j32.19 = 87.325$ pu. which
corresponds to a load of $\frac{100}{87.325} = 1.145$ MVA

OA rating of transformers = 1 MVA

Impedance of load on ES Aux Transformer 3B = $93.375 + j34.797 = 99.648$ pu which
corresponds to a load of $\frac{100}{99.648} = 1.004$ MVA

OA rating of Transformer = 1 MVA

No load
volts of Start Up Transformer Y winding = $\frac{244.8}{224.25} \times 4160 = 4541$ volts

Measured volts on ES 4.16 KV Bus 3A = 4183 volts
Drop through Y winding = $4541 - 4183 = 358$ volts

Calculated volts on ES 4.16 KV Bus 3A = 4108
Calculated drop through Y winding = $4541 - 4108 = 433$

i.e. calculated drop is $(\frac{433}{358} - 1) \times 100 = 20.95\%$ greater than measured volt drop.

Measured no load volts on ES Aux Transformer 3A
= $4179 \times \frac{480}{4160} = 482$ assuming on nominal tap.



Gilbert Associates, Inc.
Reading, Pennsylvania

CALCULATION

SUBJECT		ENGINEERED SAFEGUARDS BUSBS VOLTAGE CALCULATIONS			CISID	04-5011-113		PAGE	40
REV.	0	1	2	3				OF	40
MICROFILMED								PAGES	
ORIGINATOR	<i>W. J. ...</i>								
DATE	7/8/82								

Measured volts on ES 480 V Bus 3A = 472

Measured Volt drop through ES Aux Transformer 3A = 482-472 = 10

Calculated no load volts on ES Aux. Transformer 3A

$$= 4108 \times \frac{480}{4160} = 474$$

Calculated voltage on 480 V swgr. bus = 458

Calculated volt drop through ES Aux. Transformer 3A = 474-458 = 16

The discrepancy between calculated and measured voltages is most probably due to loads as measured being appreciably lower than loads used in the calculation.

The calculated load on the 4.16 KV winding of the Start Up Transformer was approximately 31 MVA; the FOA 65 C rating of this winding is 28 MVA. It is improbable that the measurements would be made with a load as great as 28 MVA.

The calculated load on ES Auxiliary Transformer 3A was approximately 1.15 MVA, the OA rating of the transformer being 1 MVA.

Calculated loads in many cases were taken as rated loads of equipment also the condition used in the calculations was that of Maximum Plant Loading including Maximum Engineered Safeguard Loads.

Previous calculations were approximate and are superseded by the present calculations from which the comparative voltage table is compiled, so that relay settings should be based on the above table.

LICENSING PLAN FOR DEGRADED GRID VOLTAGE UNDERVOLTAGE RELAYING

PROJECT MANAGEMENT ITEM NO.	PROJECT SCHEDULE DESCRIPTION	SCHEDULED COMPLETION DATE
282901007	This activity is the completion of the as-builts of relay cabinets to correct constructibility problem for an installation of the second level undervoltage relays.	9/2/82
282901042	This activity is the preparation of a scope letter to Gilbert Associates for their preparation of an estimate to perform a Field Change Notice for the second level undervoltage relaying design package to resolve constructibility problem.	12/3/82
282901049	This represents the activity of Gilbert Associates preparing the scope letter to prepare FCN for MAR 81-1-2.	12/17/82
282901065	This activity is FPC preparing the work authorization and approval for Gilbert Associates to prepare the FCN to correct the constructibility problem with the undervoltage relaying MAR.	1/12/83
282901069	This activity is the actual preparation of the FCN by Gilbert Associates.	2/24/83
282901084	This activity is the FPC review and approval of the FCN.	3/10/83
282901090	This is a milestone activity. This represents the FPC issuing of the FCN to MAR 81-1-2.	3/10/83
282900100	This activity represents the October transmittal to the NRC of the latest distribution voltage calculations.	11/12/82
282900103	This is the NRC review of the calculations submitted in October 1982.	1/14/83
282900121	This activity is the development of the licensing plan and schedule.	11/22/82
282900123	This activity is the NRC review of the Tech Spec licensing plan.	12/14/82

PROJECT
MANAGEMENT
ITEM NO.

DESCRIPTION

SCHEDULED
COMPLETION
DATE

282900125	This activity represents a possible meeting between FPC and the NRC to review the content of the licensing plan.	12/16/82
282900127	This is the milestone activity of the NRC approving the proposed licensing plan.	1/4/83
282900130	This represents the NRC approving the temporary relay settings submitted in the October 1982 submittal.	1/4/83
282900105	This represents the installation of MAR 81-1-2, the second level undervoltage relaying system.	5/13/83
282900110	This represents the FPC monitor and review of the performance of the second level undervoltage system and temporary relaying setting.	5/13/83
282900120	This represents the quarterly (or semiannually) calibration checks on the relay settings.	5/13/83
282900131	This is FPC's preparation of scope letter to Gilbert Associates for their preparation of additional calculations.	11/15/82
282900133	This activity represents Gilbert preparing the scope letter for revised calculations for changing taps on the 4160 volt transformer.	1/18/83
282900135	This represents the FPC preparation of the work authorization and approval for Gilbert Associates to proceed with performing the calculations for revised tap settings.	2/16/83
282900137	This activity is the actual Gilbert performance of the revised calculations.	12/15/83
282900139	This activity is the FPC review of the results of the Gilbert calculations.	1/17/84
282900150	This is a possible activity based upon positive results from the calculations and is a milestone activity.	1/17/84

<u>PROJECT MANAGEMENT ITEM NO.</u>	<u>DESCRIPTION</u>	<u>SCHEDULED COMPLETION DATE</u>
282900140	This is the other possible milestone activity based upon results of the calculations being negative.	1/17/84
282900160	This activity is transmitting the revised calculations to the NRC.	1/17/84
282900161	This activity represents the NRC review of the calculations.	3/15/84
282900163	This activity is the FPC preparation of revised Tech Specs based on revised tap settings and new relay settings.	4/13/84
282900165	This activity is the changing of the transformer taps at the plant.	5/14/84
282900167	This activity is rework of the voltage test measurements based on new tap settings.	8/9/84
282900169	This activity represents FPC review of test measurements.	9/7/84
282900171	This activity represents transmittal of the test measurements and revised calculations to the NRC.	9/14/84
282900173	This activity represents the NRC review of test measurements.	11/13/84
282900175	This activity represents preparation of the final Tech Specs.	1/10/85
282900179	This activity represents internal FPC review of the revised Tech Specs by the NGRC Committee.	2/8/85
282900181	This activity is the NRC review and approval of Tech Specs.	4/9/85
282900183	This activity is FPC preparing final relay settings to the plant.	5/8/85
282900190	This activity is the issuance of final relay settings to the plant.	5/8/85