



February 12, 1991

2CAN029108

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUBJECT: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Annual Diesel Generator
Data Report - 1990

Gentlemen:

Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specification 6.9.1.5.d requires an annual submittal of a diesel generator data report for the previous calendar year. This report provides the number of valid tests and the number of valid failures for each diesel generator. The purpose of this letter is to provide this information for 1990.

Nineteen (19) tests were performed on diesel generator 2K-4A and thirty seven (37) tests were performed on 2K-4B during 1990. There were no failures on either of the diesel generators during this time period.

This letter completes the reporting requirements for Technical Specification 6.9.1.5.d. Should you have any questions regarding this submittal, please contact me.

Very truly yours,

James J. Fisicaro
Manager, Licensing

JJF:RWC:sgw

9102210168 910212
PDR ADOCK 05000368
R PDR

A001
110

U. S. NRC
February 12, 1991
Page 2

cc: Mr. Robert Martin
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Thomas W. Alexion
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 11-B-19
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

NRC Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Ms. Shari Peterson
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 11-B-19
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852