



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 16, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Containment Main Steam Tunnel
Temperature in Excess of
Allowable Value (Special
Report)
Reference: LER 82-111/99 X-0
AECM-82/553

On October 17, 1982, reactor operators discovered the Containment Main Steam Tunnel temperature in excess of the allowable value of T.S.3.7.8. An LCO was entered and corrective action taken. Attached is LER 82-111/99 X-0 with supplementary information.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY
IE 22