

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M | S | G | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 1 | 4 | 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T  
01 | L | 6 | 0 | 5 | 0 | 0 | 0 | 4 | 1 | 6 | 7 | 1 | 0 | 2 | 0 | 8 | 2 | 8 | 1 | 1 | 1 | 1 | 6 | 8 | 2 | 9  
7 8 9 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
02 | During shutdown, while performing surveillance procedure 06-EL-1111-W-0001-125 Volt |  
03 | Battery Bank Pilot Cell Check, pilot cell 19 failed to meet T.S.4.8.2.1.a specific |  
04 | gravity minimum of 1.200. The corrected S. G. was 1.1982. Operations was notified |  
05 | and an LCO entered due to the Division III Batteries being declared inoperable. These |  
06 | batteries provide control power to the HPCS pump breakers. This had no effect on the |  
07 | health and safety of the public and did not constitute a threat to plant safety. |  
08 | \_\_\_\_\_ |

09 | E | C | 11 | E | 12 | A | 13 | B | A | T | T | R | Y | 14 | Z | 15 | Z | 16  
7 8 9 SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 19 VALVE SUBCODE 20  
17 | LER/RO REPORT NUMBER 18 | 8 | 2 | 19 | - | 20 | 1 | 1 | 7 | 21 | / | 22 | 0 | 3 | 23 | L | 24 | - | 25 | 0  
21 22 23 24 26 27 28 29 OCCURRENCE CODE 30 REPORT TYPE 31 REVISION NO. 32  
33 | X | 34 | Z | 35 | Z | 36 | Z | 37 | 0 | 0 | 0 | 0 | 38 | N | 39 | N | 40 | N | 41 | N | 42 | E | 43 | 2 | 44 | 2 | 45 | 6 | 46  
ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 38 NPD-4 FORM SUB. 39 PRIME COMP. SUPPLIER 40 COMPONENT MANUFACTURER 41

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
10 | The battery bank was put on an "equalize" charge for 24 hours and retested in |  
11 | accordance with procedure 06-EL-1111-0-0001-125 Volt Battery Bank All Cells Check. |  
12 | The battery surveillance requirements of T.S. Table 4.8.2.1-1 were satisfied and the |  
13 | batteries were returned to operable status. The LCO was lifted on October 22, 1982. |  
14 | This is being submitted as a final report. |

15 | G | 28 | 0 | 0 | 0 | 29 | NA | 30 | B | 31 | Surveillance Testing | 32  
7 8 9 FACILITY STATUS 10 % POWER 11 OTHER STATUS 12 METHOD OF DISCOVERY 13 DISCOVERY DESCRIPTION 14

16 | Z | 33 | Z | 34 | NA | 35 | NA | 36  
7 8 9 ACTIVITY CONTENT 10 RELEASED OF RELEASE 11 AMOUNT OF ACTIVITY 12 LOCATION OF RELEASE 13

17 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39  
7 8 9 PERSONNEL EXPOSURES 10 NUMBER 11 TYPE 12 DESCRIPTION 13

18 | 0 | 0 | 0 | 40 | 41  
7 8 9 PERSONNEL INJURIES 10 NUMBER 11 DESCRIPTION 12

19 | Z | 42 | NA | 43 | 8211230377 821116  
7 8 9 LOSS OF OR DAMAGE TO FACILITY 10 TYPE 11 DESCRIPTION 12 PDR ADOCK 05000416  
S PDR

20 | N | 44 | NA | 45 | \_\_\_\_\_ | 46  
7 8 9 PUBLICITY 10 ISSUED 11 DESCRIPTION 12 NRC USE ONLY 13

Original signed by John M. Albert

PHONE: \_\_\_\_\_