

NOV 8 1982

APPENDIX A

NOTICE OF VIOLATION

Southern California Edison Company  
San Onofre Nuclear Generating Station,  
Unit 2

Docket No. 50-361  
License No. NPF-10

As a result of the inspection conducted on September 23 to October 25, 1982, and in accordance with NRC Enforcement Policy, (10 CFR Part 2, Appendix C), 47 FR 9987 (March 9, 1982) the following violation was identified:

A. Operating License NPF-10 section 2.C(19)b states, in part:

- "1. SCE shall develop and implement administrative procedures to limit the working hours of individuals of the nuclear power plant operating staff who are responsible for manipulating plant controls or for adjusting on-line systems and equipment affecting plant safety which would have an immediate impact on public health and safety.

Adequate shift coverage shall be maintained without routine heavy use of overtime. However, in the event that unforeseen problems require substantial amounts of overtime to be used, the following guidelines shall be followed:

2. An individual shall not be permitted to work more than 24 hours in any 48-hour period, not more than 72 hours in any seven-day period (all excluding shift turnover time).

Any deviation from the above guidelines shall be authorized by the station manager, his deputy, the operations manager, or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime will be reviewed monthly by the station manager or his designee to assure that excessive hours have not been assigned. Routine deviation from the above guidelines is not authorized."

8211230387 821108  
PDR ADOCK 05000361  
G PDR

Contrary to the above, one Unit 2 Senior Reactor Operator worked more than 72 hours between July 21 and July 27, 1982 and another Unit 2 Senior Reactor Operator worked more than 72 hours between August 4 and August 10, 1982 (both, seven day periods) without appropriate management authorization.

This is a severity level V violation (Supplement I).

No written response required.

NOV 8 1982

---

Date

151  

---

D. F. Kirsch, Chief  
Reactor Projects Section 3