

Docket No. 50-245
813739

Attachment 1

Millstone Nuclear Power Station, Unit No. 1

Proposed Revision to Technical Specifications
Integrated Leak Rate Test--Mass Point Method

9102260053 910215
PDR ADOCK 05000245
P PDR

February 1991

LIMITING CONDITION FOR OPERATION

3.7 CONTAINMENT SYSTEMS

- 3.7.A.3. Primary containment integrity, as defined in Section 1.0, shall be maintained at all times when the reactor is critical or when the reactor water temperature is above 212°F and fuel is in the reactor vessel.

SURVEILLANCE REQUIREMENT

- 4.7.A.3. The primary containment integrity shall be demonstrated as follows:

a. Integrated Primary Containment Leak Test (IPCLT)

The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR 50 using the methods and provisions of ANSI N45.4-1972 (Total Time Method), BN-TOP-1, and/or the Mass Point Method.

1. Three Type A Overall Integrated Containment Leakage Rate tests shall be conducted at 40 ± 10 month intervals during shutdown at P_a (43 psig) during each ten-year service period. The^a third test of each set shall be conducted during the shutdown for the ten-year plant inservice inspection.
2. If any periodic Type A test fails to meet $0.75 L_a$, the test schedule for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet $0.75 L_a$, a Type A test shall be performed at least every 18 months until two consecutive Type A tests meet $0.75 L_a$, at which time the above schedule may be resumed.
3. The accuracy of each Type A test shall be verified by a supplemental test which:
 - a. Confirms the accuracy of the test by verifying that the difference between the supplemental data and the Type A test data is within $0.25 L_a$.
 - b. Has duration sufficient to establish accurately the change in leakage rate between the Type A test and the supplemental test.
 - c. Requires the quantity of gas injected into containment or bled from containment during the supplemental test to be equivalent to at least 25 percent of the total measured leakage at P_a .