



Donald C. Shelton  
Vice President - Nuclear  
Davis-Besse

300 Madison Avenue  
Toledo, OH 43652-0001  
(419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 1886

February 15, 1991

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Subject: License Amendment Request to Delete References to Deaerator  
Storage Tanks (TAC Number M79673)

Gentlemen:

The enclosed application requests that the Davis-Besse Nuclear Power Station, Unit Number 1 Operating License, Appendix A, Technical Specifications (TS) be revised to reflect the changes attached. The proposed changes involve TS 3/4.7.1.3, Plant Systems, Condensate Storage Tank, and Bases Section 3/4.7.1.3, Plant Systems, Condensate Storage Facilities.

The proposed changes would delete the reference to the Deaerator Storage Tanks (DSTs) as condensate storage facilities for the Auxiliary Feedwater System in Limiting Condition for Operation (LCO) 3.7.1.3, and would revise the nomenclature for "condensate storage tank" and "condensate storage facilities" to "Condensate Storage Tanks" in LCO 3.7.1.3, Surveillance Requirement 4.7.1.3.1, and Bases Section 3/4.7.1.3. These changes are being made to correct the TS in that the alignment of the DSTs to the Auxiliary Feedwater Pumps (AFPs) is not allowed because 1) the high-temperature water from the DSTs can damage the AFPs' bearings, and 2) the AFPs' discharge lines would be considered high energy lines. The changes in nomenclature are being made because, with the deletion of the deaerator storage tanks, the only condensate storage facilities remaining are the condensate storage tanks.

9102260116 910215  
PDR ADUCK 05000346  
P PDR

Operating Companies:  
Cleveland Electric Illuminating  
Toledo Edison

250088

*Adol*  
*1/11*

Docket Number 50-346

License Number NPF-3

Serial Number 1886

Page 2

Toledo Edison requests that the Nuclear Regulatory Commission Staff issue this amendment by November 29, 1991. If you have any questions concerning the above, please contact Mr. R. W. Schrauder, Manager - Nuclear Licensing, at (419) 249-2366.

Very truly yours,

*DC Shelton*  
RMC/mmb

cc: P. M. Byron, DB-1 Senior Resident Inspector  
A. B. Davis, Regional Administrator, NRC Region III  
D. C. Di Ianni, DB-1 NRC Senior Project Manager  
General J. Williams, Chief of Staff, Ohio Adjutant General's Office  
Utility Radiological Safety Board