



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GPU NUCLEAR CORPORATION

AND

JERSEY CENTRAL POWER & LIGHT COMPANY

DOCKET NO. 50-219

OYSTER CREEK NUCLEAR GENERATING STATION

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 146
License No. DPR-16

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by GPU Nuclear Corporation, et al., (the licensee), dated December 17, 1990, as supplemented January 7, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Provisional Operating License No. DPR-16 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 146, are hereby incorporated in the license. GPU Nuclear Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Director
Project Directorate 1-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 29, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 146

PROVISIONAL OPERATING LICENSE NO. DPR-16

DOCKET NO. 50-219

Replace the following page of the Appendix A Technical Specifications with the enclosed page. The revised page is identified by amendment number and contains vertical lines indicating the areas of change.

Remove

Page 4.13-2

Insert

Page 4.13-2

TABLE 4.13-1

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHECK</u>	<u>CALIBRATION</u>
1. Primary and Safety Valve Position Indicator (Primary Detector*)	A	B
Relief and Safety Valve Position Indicator (Backup Indications**)	A	B
Relief Valve Position Indicator (Common Header Temperature Element**)	C	B
2. Wide Range Drywell Pressure Monitor (PT/PR 53 & 54)	A	D
3. Wide Range Torus Water Level Monitor (LT/LR 37 & 38)	A	D
4. Drywell H ₂ Monitor	A ¹	E
5. Containment High Range Radiation Monitor	A	F***
6. High Range Radioactive Noble Gas Effluent Monitor		
a. Main Stack	A	F
b. Turbine Building Vent	A	F

Legend:

- A = at least once per 31 days
- B = at least once per 24 months
- C = at least once per 15 days until channel calibration is performed and thence at least once per 31 days
- D = at least once per 6 months
- E = at least once per 12 months
- 1 = Span and Zero using calibration gases
- F = each refueling outage

1 = Span and Zero using calibration gases

* Acoustic Monitor

** Thermocouple

*** Channel calibration shall consist of electronic signal substitution of the channel, not including the detector, for all decades above 10R/hr and a one point calibration check of the detector at or below 10R/hr by means of a calibrated portable radiation source traceable to NBS.