UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-344

PORTLAND GENERAL ELECTRIC COMPANY, ET AL.

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 77 to Facility Operating License No. NPF-1, issued to Portland General Electric Company, the City of Eugene, Oregon, and Pacific Power and Light Company (the licensees), which revised the Technical Specifications for operation of the Trojan Nuclear Plant (the facility) located in Columbia County, Oregon. The amendment is effective as of the date of issuance.

The amendment requires that (1) the containment purge and hydrogen verse containment isolation valves be tested for proper closure on a containment high radiation signal once per 18 months, (2) the hydrogen vent containment isolation valves be similarly tested for proper closure on a containment ventilation isolation signal, (3) the containment purge valves be locked closed and verified to be locked closed every 31 days when the plant is not in a refueling or cold shutdown condition, (4) the containment purge valves be leak tested every nine months and each time before leaving the cold shutdown condition if opened (prior to power operation), and (5) the hydrogen vent valves be normally closed and opened only when necessary for safety reasons. In addition, the amendment adds several new containment sample isolation valves to the list of containment isolation valves thereby subjecting them to operability and testing requirements.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since this amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated May 6, 1982, (2) Amendment No. to License No. NPF-1 and (3) the Commission's related letter dated November 10, 1982.

All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the local public document room located at the Multnomah County Library,

Social Science and Science Department, 801 S.W. 10th Avenue, Portland,

Oregon 97205. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 10th day of November, 1982.

D40-

FOR THE NUCLEAR REGULATORY COMMISSION

Charles M. Trammell, Acting Chief

Operating Reactors Branch #3

Division of Licensing