

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I | A | D | A | C | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 1 | 4 | 5

CON'T
01 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 1 | 7 | 1 | 0 | 2 | 6 | 8 | 2 | 8 | 1 | 1 | 1 | 2 | 8 | 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | During normal operation surveillance testing, the pressure switches whic
03 | h control reactor building to suppression chamber vacuum breakers CV-430
04 | 4 and CV-4305 tripped conservatively out-of-spec. PDS-4304 and PDS-4305
05 | tripped at 0.35 psid. T.S.3.7.A.3.A requires the setpoint to be 0.5 +/-
06 | 0.1 psid. There have been ten previous similar occurrences. (See A0 75-3
07 | 3; R0 77-55, 78-37, 79-18, 80-23, 81-48, 82-31, 82-43, 82-47, and 82-67)
08 | _____

09 | SYSTEM CODE: S A 11 | CAUSE CODE: E 12 | CAUSE SUBCODE: E 13 | COMPONENT CODE: I N S T R U 14 | COMP. SUBCODE: S 15 | VALVE SUBCODE: Z 16
17 | LER/RO REPORT NUMBER: 8 2 21 | SEQUENTIAL REPORT NO.: 0 7 2 24 | OCCURRENCE CODE: 0 3 27 | REPORT TYPE: L 30 | REVISION NO.: 0 32
ACTION TAKEN: E 18 | FUTURE ACTION: A 19 | EFFECT ON PLANT: Z 20 | SHUTDOWN METHOD: Z 21 | HOURS: 0 0 0 0 22 | ATTACHMENT SUBMITTED: N 23 | NRC-4 FORM SUB: N 24 | PRIME COMP. SUPPLIER: A 25 | COMPONENT MANUFACTURER: B 0 8 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | Instrument drift. Contributing cause is large range of switches resultin
11 | g in decreased setpoint accuracy and difficulty in calibration. PDS-4304
12 | and PDS-4305, Barton Model 288A, were immed recal and funct tested sat.
13 | New bellows units for PDS-4304 and PDS-4305 are on order and will be ins
14 | talled upon arrival. Increased surveillance testing is continuing.

15 | FACILITY STATUS: E 28 | % POWER: 0 4 9 29 | OTHER STATUS: NA 30 | METHOD OF DISCOVERY: B 31 | DISCOVERY DESCRIPTION: Surveillance test 32

16 | ACTIVITY CONTENT RELEASED OF RELEASE: Z 33 | AMOUNT OF ACTIVITY: NA 34 | LOCATION OF RELEASE: NA 35

17 | PERSONNEL EXPOSURES NUMBER: 0 0 0 37 | TYPE: Z 38 | DESCRIPTION: NA 39

18 | PERSONNEL INJURIES NUMBER: 0 0 0 40 | DESCRIPTION: NA 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z 42 | DESCRIPTION: NA 43
PDR ADOCK 05000331
S PDR

20 | PUBLICITY ISSUED DESCRIPTION: N 44 | DESCRIPTION: NA 45
NAME OF PREPARER: Kimuel L. Hill
PHONE: 319-851-5611
NRC USE ONLY