

Westinghouse Energy Systems



9102040249 910128  
PDR ADOCK 05000348  
F PDR

WCAP-12826

TECHNICAL JUSTIFICATION FOR ELIMINATING LARGE  
PRIMARY LOOP PIPE RUPTURE AS THE STRUCTURAL  
DESIGN BASIS FOR THE JOSEPH M. FARLEY  
UNITS 1 AND 2 NUCLEAR POWER PLANTS

JANUARY 1991

D. C. Bhowmick  
C. C. Kim

F. J. Witt

S. A. Swamy  
Y. S. Lee

VERIFIED:

*John C. Schmertz*  
J. C. Schmertz

APPROVED:

*D. C. Adamonis*  
D. C. Adamonis  
D. C. Adamonis, Acting Manager  
Structural Mechanics Technology

WESTINGHOUSE ELECTRIC CORPORATION  
Power Systems Division  
P. O. Box 2728  
Pittsburgh, Pennsylvania 15230-2728

© 1991 Westinghouse Electric Corp.

## FOREWORD

This document contains Westinghouse Electric Corporation proprietary information and data which has been identified by brackets. Coding associated with the brackets sets forth the basis on which the information is considered proprietary. These codes are listed with their meanings in WCAP-7211.

The proprietary information and data contained in this report were obtained at considerable Westinghouse expense and its release could seriously affect our competitive position. This information is to be withheld from public disclosure in accordance with the Rules of Practice 10 CFR 2.790 and the information presented herein be safeguarded in accordance with 10 CFR 2.903. Withholding of this information does not adversely affect the public interest.

This information has been provided for your internal use only and should not be released to persons or organizations outside the Directorate of Regulation and the ACRS without the express written approval of Westinghouse Electric Corporation. Should it become necessary to release this information to such persons as part of the review procedure, please contact Westinghouse Electric Corporation, which will make the necessary arrangements required to protect the Corporation's proprietary interests.

The proprietary information is deleted in the unclassified version of this report (WCAP-12826).

## TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
	EXECUTIVE SUMMARY	xiii
1.0	INTRODUCTION	1-1
	1.1 Purpose	1-1
	1.2 Scope	1-1
	1.3 Objectives	1-1
	1.4 Background Information	1-2
	1.5 References	1-3
2.0	OPERATION AND STABILITY OF THE REACTOR COOLANT SYSTEM	2-1
	2.1 Stress Corrosion Cracking	2-1
	2.2 Water Hammer	2-3
	2.3 Low Cycle and High Cycle Fatigue	2-4
	2.4 References	2-4
3.0	PIPE GEOMETRY AND LOADING	3-1
	3.1 Introduction to Methodology	3-1
	3.2 Calculation of Loads and Stresses	3-2
	3.3 Loads for Leak Rate Evaluation	3-2
	3.4 Load Combination for Crack Stability Analysis	3-3
	3.5 References	3-4
4.0	MATERIAL CHARACTERIZATION	4-1
	4.1 Primary Loop Pipe and Fittings Materials	4-1
	4.2 Tensile Properties	4-1
	4.3 Fracture Toughness Properties	4-2
	4.4 References	4-4
5.0	CRITICAL LOCATIONS AND EVALUATION CRITERIA	5-1
	5.1 Critical Locations	5-1
	5.2 Fracture Criteria	5-2

TABLE OF CONTENTS (Cont'd.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
6.0	LEAK RATE PREDICTIONS	6-1
6.1	Introduction	6-1
6.2	General Considerations	6-1
6.3	Calculation Method	6-1
6.4	Leak Rate Calculations	6-2
6.5	References	6-3
7.0	FRACTURE MECHANICS EVALUATION	7-1
7.1	Local Failure Mechanism	7-1
7.2	Global Failure Mechanism	7-2
7.3	Results of Crack Stability Evaluation	7-3
7.4	References	7-4
8.0	FATIGUE CRACK GROWTH ANALYSIS	8-1
8.1	References	8-2
9.0	ASSESSMENT OF MARGINS	9-1
10.0	CONCLUSIONS	10-1
APPENDIX A	Limit Moment	A-1
APPENDIX B	Alternate Toughness Criteria for the Farley Units 1 and 2 Cast Primary Loop Components	B-1
B.1	Introduction	B-1
B.2	Chemistry and KCU Toughness	B-1
B.3	Alternative Toughness Criteria for the Farley Primary Loop Material on a Component by Component Basis	B-1
B.4	References	B-2

## LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
3-1	Dimensions, Normal Loads and Normal Stresses for Farley Unit 1	3-5
3-2	Dimensions, Normal Loads and Normal Stresses for Farley Unit 2	3-6
3-3	Faulted Loads and Stresses for Farley Unit 1	3-7
3-4	Faulted Loads and Stresses for Farley Unit 2	3-8
4-1	Measured Tensile Properties for Farley Unit 1 Primary Loop Piping and Fittings	4-5
4-2	Measured Tensile Properties for the Primary Loop Piping and Fittings (all SA351 CF8A) of Farley Unit 2	4-6
4-3	Mechanical Properties for the Farley Unit 1 Materials at 544°F and 611°F	4-7
4-4	Mechanical Properties for the Farley Unit 2 Materials (SA351 CF8A) at 544°F and 611°F	4-8
4-5	Enveloped Fracture Toughness Properties for Farley Units 1 and 2 Primary Loops for Leak-Before-Break Evaluation	4-9
6-1	Flaw Sizes Yielding a Leak Rate of 10 gpm at the Four Locations	6-4

LIST OF TABLES (Cont'd)

<u>Table</u>	<u>Title</u>	<u>Page</u>
7-1	Stability Results for Farley Units 1 and 2 Based on Elastic-Plastic J-Integral Evaluations	7-6
7-2	Stability Results Based on Limit Load Analyses	7-7
8-1	Summary of Reactor Vessel Transients	8-4
8-2	Typical Fatigue Crack Growth at [ j <sup>a,c,e</sup> (40 Years)	8-5
B-1	Chemistry and Fracture Toughness Properties of the Material Heats of Farley Unit 1	B-3
B-2	Chemistry and Fracture Toughness Properties of the Material Heats of Farley Unit 2	B-12



LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3-1	Hot Leg Coolant Pipe of Farley Unit 1	3-9
3-2	Schematic Diagram of the Farley Plants RCL Showing Weld Locations	3-10
4-1	Average True Stress-True Strain Curve for the SA351 CFBA Material of Farley Unit 1 at 544°F	4-10
4-2	Lower Bound True Stress-True Strain Curve for the SA351 CFBA Material of Farley Unit 1 at 544°F	4-11
4-3	Average True Stress-True Strain Curve for the SA351 CFBA Material of Farley Unit 1 at 611°F	4-12
4-4	Lower Bound True Stress-True Strain Curve for the SA351 CFBA Material of Farley Unit 1 at 611°F	4-13
4-5	Average True Stress-True Strain Curve for the SA351 CFBM Material of Farley Unit 1 at 544°F	4-14
4-6	Lower Bound True Stress-True Strain Curve for the SA351 CFBM Material of Farley Unit 1 at 544°F	4-15
4-7	Average True Stress-True Strain Curve for the SA351 CFBM Material of Farley Unit 1 at 611°F	4-16
4-8	Lower Bound True Stress-True Strain Curve for the SA351 CFBM Material of Farley Unit 1 at 611°F	4-17

LIST OF FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
4-5	Average True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 2 at 544°F	4-18
4-10	Lower Bound True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 2 at 544°F	4-19
4-11	Average True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 2 at 611°F	4-20
4-12	Lower Bound True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 2 at 611°F	4-21
4-13	J vs. $\Delta a$ for SA351 CF8M Cast Stainless Steel at 600°F	4-22
4-14	J vs. $\Delta a$ at Different Temperatures for Aged Material [ $J^{a,c,e}$ (7500 Hours at 400°C)	4-23
6-1	Analytical Predictions of Critical Flow Rates of Steam-Water Mixtures	6-5
6-2	[ $J^{a,c,e}$ Pressure Ratio as a Function of L/D	6-6
6-3	Idealized Pressure Drop Profile Through a Postulated Crack	6-7
7-1	[ $J^{a,c,e}$ Stress Distribution	7-8
7-2	Critical Flaw Size Prediction - Hot Leg at Location 1 for Farley Unit 1	7-9

LIST OF FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
7-3	Critical Flaw Size Prediction - Hot Leg at Location 2 for Farley Unit 1	7-10
7-4	Critical Flaw Size Prediction - Hot Leg at Location 3 for Farley Unit 1	7-11
7-5	Critical Flaw Size Prediction - Hot Leg at Location 1 for Farley Unit 2	7-12
8-1	Typical Cross-Section of [ ] <sup>a,c,e</sup>	8-6
8-2	Reference Fatigue Crack Growth Curves for [ ] <sup>a,c,e</sup>	8-7
8-3	Reference Fatigue Crack Growth Law for [ ] <sup>a,c,e</sup> in a Water Environment at 600°F	8-8
A-1	Pipe with a Through-Wall Crack in Bending	A-2

## EXECUTIVE SUMMARY

The existing structural design basis for the reactor coolant systems of the Joseph M. Farley Units 1 and 2 nuclear reactor power plants requires that the dynamic effects of pipe breaks be evaluated and that protective measures for such breaks be incorporated into the design. However, within the last decade, such breaks have been shown to be highly unlikely and should not be included, in general, in the structural design basis of Westinghouse type pressurized water reactors, for example. To eliminate primary loop pipe breaks from the design basis, it must be demonstrated to the satisfaction of the U.S. Nuclear Regulatory Commission that a leak-before-break situation exists. This report provides such a demonstration for the Joseph M. Farley Units 1 and 2 nuclear power plants.

In this report it is shown that the primary loops are highly resistant to stress corrosion cracking and high and low cycle fatigue. Water hammer is mitigated by system design and operating procedures.

The primary loops were extensively examined. The as-built geometries for the pipe and elbows and loadings were obtained. The materials were evaluated using the Certified Materials Test Reports. Mechanical properties were determined at operating temperatures. Since the piping systems are fabricated from cast stainless steel, fracture toughnesses considering thermal aging were determined for each heat of material.

Based on loading, pipe geometry and fracture toughness considerations, enveloping critical locations were determined at which leak-before-break crack stability evaluations were made. Through-wall flaw sizes were found which would leak at a rate of ten times the leakage detection system capabilities of the plants. Large margins in such flaw sizes were shown against flaw instability. Finally, fatigue crack growth was shown not to be an issue for the primary loops.

It is concluded that dynamic effects of reactor coolant system primary loop pipe breaks need not be considered in the structural design basis of the Joseph M. Farley Units 1 and 2 nuclear power plants.

## SECTION 1.0 INTRODUCTION

### 1.1 Purpose

This report applies to the Joseph M. Farley Nuclear Power Plant Units 1 and 2 (Farley) Reactor Coolant System (RCS) primary loop piping. It is intended to demonstrate that for the specific parameters of the Farley plants, RCS primary loop pipe breaks need not be considered in the structural design basis. The approach taken has been accepted by the Nuclear Regulatory Commission (NRC) (reference 1-1).

### 1.2 Scope

The existing structural design basis for the RCS primary loop requires that dynamic effects of pipe breaks be evaluated. Specifically, the LOCA design basis for the Farley plants includes eleven breaks postulated in the RCS primary loop piping: the six terminal ends in the cold, hot, and crossover legs; a split in the steam generator inlet elbow, the loop closure weld in the crossover leg; and the nozzle welds for the three large branch lines (accumulator, residual heat removal, and surge lines). However, Westinghouse has demonstrated on a generic basis that RCS primary loop pipe breaks are highly unlikely and should not be included in the structural design basis of Westinghouse plants (see reference 1-2). In order to demonstrate this applicability of the generic evaluations to the Farley plants, Westinghouse has performed a fracture mechanics evaluation, a determination of leak rates from a through-wall crack, a fatigue crack growth evaluation, and an assessment of margins against crack instability consistent with the leak-before-break (LBB) methodology. Through this successful application of the LBB methodology, the eight break locations in the RCS primary loop piping (the branch lines have not been included in this evaluation) are eliminated from Farley's structural design basis.

### 1.3 Objectives

In order to validate the elimination of RCS primary loop pipe breaks for the Farley plants, the following objectives must be achieved:

- a. Demonstrate that margin exists between the critical crack size and a postulated crack which yields a detectable leak rate.
- b. Demonstrate that there is sufficient margin between the leakage through a postulated crack and the leak detection capability of the Farley plants.
- c. Demonstrate margin on applied load.
- d. Demonstrate that fatigue crack growth is negligible.

#### 1.4 Background Information

Westinghouse has performed considerable testing and analysis to demonstrate that RCS primary loop pipe breaks can be eliminated from the structural design basis of all Westinghouse plants. The concept of eliminating pipe breaks in the RCS primary loop was first presented to the NRC in 1978 in WCAP-9283 (reference 1-3). That topical report employed a deterministic fracture mechanics evaluation and a probabilistic analysis to support the elimination of RCS primary loop pipe breaks. That approach was then used as a means of addressing Generic Issue A-2 and Asymmetric LOCA Loads.

Westinghouse performed additional testing and analysis to justify the elimination of RCS primary loop pipe breaks. This material was provided to the NRC along with Letter Report NS-EPR-2519 (reference 1-4).

The NRC funded research through Lawrence Livermore National Laboratory (LLNL) to address this same issue using a probabilistic approach. As part of the LLNL research effort, Westinghouse performed extensive evaluations of specific plant loads, material properties, transients, and system geometries to demonstrate that the analysis and testing previously performed by Westinghouse and the research performed by LLNL applied to all Westinghouse plants (references 1-5 and 1-6). The results from the LLNL study were released at a March 28, 1983 ACRS Subcommittee meeting. These studies which are applicable to all Westinghouse plants east of the Rocky Mountains determined the mean probability of a direct LOCA (RCS primary loop pipe break) to be  $4.4 \times 10^{-12}$

per reactor year and the mean probability of an indirect LOCA to be  $10^{-7}$  per reactor year. Thus, the results previously obtained by Westinghouse (reference 1-3) were confirmed by an independent NRC research study.

Based on the studies by Westinghouse, LLNL, the ACRS, and the AIF, the NRC completed a safety review of the Westinghouse reports submitted to address asymmetric blowdown loads that result from a number of discrete break locations on the PWR primary systems. The NRC Staff evaluation (reference 1-1) concludes that an acceptable technical basis has been provided so that asymmetric blowdown loads need not be considered for those plants that can demonstrate the applicability of the modeling and conclusions contained in the Westinghouse response or can provide an equivalent fracture mechanics demonstration of the primary coolant loop integrity. In a more formal recognition of LBB methodology applicability for PWRs, the NRC appropriately modified 10 CFR 50, General Design Criterion 4, "Requirements for Protection Against Dynamic Effects for Postulated Pipe Rupture" (reference 1-7).

This report provides a fracture mechanics demonstration of primary loop integrity for the Farley plants consistent with the NRC position for exemption from consideration of dynamic effects.

Several computer codes are used in the evaluations. The main-frame computer programs are under Configuration Control which has requirements conforming to Standard Review Plan 3.9.1. The fracture mechanics calculations are independently verified (benchmarked).

## 1.5 References

- 1-1 USNRC Generic letter 84-04, Subject: "Safety Evaluation of Westinghouse Topical Reports Dealing with Elimination of Postulated Pipe Breaks in PWR Primary Main Loops," February 1, 1984.
- 1-2 Letter from Westinghouse (E. P. Rahe) to NRC (R. H. Vollmer), NS-EPR-2768, dated May 11, 1983.
- 1-3 WCAP-9283, "The Integrity of Primary Piping Systems of Westinghouse Nuclear Power Plants During Postulated Seismic Events," March, 1978.

- 1-4 Letter Report NS-EPR-2519, Westinghouse (E. P. Rahe) to NRC (D. G. Eisenhut), Westinghouse Proprietary Class 2, November 10, 1981.
- 1-5 Letter from Westinghouse (E. P. Rahe) to NRC (W. V. Johnston) dated April 25, 1983.
- 1-6 Letter from Westinghouse (E. P. Rahe) to NRC (W. V. Johnston) dated July 25, 1983.
- 1-7 Nuclear Regulatory Commission, 10 CFR 50, Modification of General Design Criteria 4 Requirements for Protection Against Dynamic Effects of Postulated Pipe Ruptures, Final Rule, Federal Register/Vol. 52, No. 207/Tuesday, October 27, 1987/Rules and Regulations, pp. 41288-41295.



SECTION 2.0  
OPERATION AND STABILITY OF THE REACTOR COOLANT SYSTEM

2.1 Stress Corrosion Cracking

The Westinghouse reactor coolant system primary loops have an operating history that demonstrates the inherent operating stability characteristics of the design. This includes a low susceptibility to cracking failure from the effects of corrosion (e.g., intergranular stress corrosion cracking). This operating history totals over 450 reactor-years, including five plants each having over 17 years of operation and 15 other plants each with over 12 years of operation.

In 1978, the United States Nuclear Regulatory Commission (USNRC) formed the second Pipe Crack Study Group. (The first Pipe Crack Study Group established in 1975 addressed cracking in boiling water reactors only.) One of the objectives of the second Pipe Crack Study Group (PCSG) was to include a review of the potential for stress corrosion cracking in Pressurized Water Reactors (PWR's). The results of the study performed by the PCSG were presented in NUREG-0531 (reference 2-1) entitled "Investigation and Evaluation of Stress Corrosion Cracking in Piping of Light Water Reactor Plants." In that report the PCSG stated:

"The PCSG has determined that the potential for stress-corrosion cracking in PWR primary system piping is extremely low because the ingredients that produce IGSCC are not all present. The use of hydrazine additives and a hydrogen overpressure limit the oxygen in the coolant to very low levels. Other impurities that might cause stress-corrosion cracking, such as halides or caustic, are also rigidly controlled. Only for brief periods during reactor shutdown when the coolant is exposed to the air and during the subsequent startup are conditions even marginally capable of producing stress-corrosion cracking in the primary systems of PWRs. Operating experience in PWRs supports this determination. To date, no stress-corrosion cracking has been reported in the primary piping or safe ends of any PWR."

During 1979, several instances of cracking in PWR feedwater piping led to the establishment of the third PCSG. The investigations of the PCSG reported in NUREG-0691 (reference 2-2) further confirmed that no occurrences of IGSCC have been reported for PWR primary coolant systems.

As stated above, for the Westinghouse plants there is no history of cracking failure in the reactor coolant system loop. The discussion below further qualifies the PCSG's findings.

For stress corrosion cracking (SCC) to occur in piping, the following three conditions must exist simultaneously: high tensile stresses, susceptible material, and a corrosive environment. Since some residual stresses and some degree of material susceptibility exist in any stainless steel piping, the potential for stress corrosion is minimized by properly selecting a material immune to SCC as well as preventing the occurrence of a corrosive environment. The material specifications consider compatibility with the system's operating environment (both internal and external) as well as other material in the system, applicable ASME Code rules, fracture toughness, welding, fabrication, and processing.

The elements of a water environment known to increase the susceptibility of austenitic stainless steel to stress corrosion are: oxygen, fluorides, chlorides, hydroxides, hydrogen peroxide, and reduced forms of sulfur (e.g., sulfides, sulfites, and thionates). Strict pipe cleaning standards prior to operation and careful control of water chemistry during plant operation are used to prevent the occurrence of a corrosive environment. Prior to being put into service, the piping is cleaned internally and externally. During flushes and preoperational testing, water chemistry is controlled in accordance with written specifications. Requirements on chlorides, fluorides, conductivity, and pH are included in the acceptance criteria for the piping.

During plant operation, the reactor coolant water chemistry is monitored and maintained within very specific limits. Contaminant concentrations are kept below the thresholds known to be conducive to stress corrosion cracking with the major water chemistry control standards being included in the plant operating procedures as a condition for plant operation. For example, during

normal power operation, oxygen concentration in the RCS is expected to be in the ppb range by controlling charging flow chemistry and maintaining hydrogen in the reactor coolant at specified concentrations. Halogen concentrations are also stringently controlled by maintaining concentrations of chlorides and fluorides within the specified limits. Thus during plant operation, the likelihood of stress corrosion cracking is minimized.

## 2.2 Water Hammer

Overall, there is a low potential for water hammer in the RCS since it is designed and operated to preclude the voiding condition in normally filled lines. The reactor coolant system, including piping and primary components, is designed for normal, upset, emergency, and faulted condition transients. The design requirements are conservative relative to both the number of transients and their severity. Relief valve actuation and the associated hydraulic transients following valve opening are considered in the system design. Other valve and pump actuations are relatively slow transients with no significant effect on the system dynamic loads. To ensure dynamic system stability, reactor coolant parameters are stringently controlled. Temperature during normal operation is maintained within a narrow range by control rod position; pressure is controlled by pressurizer heaters and pressurizer spray also within a narrow range for steady-state conditions. The flow characteristics of the system remain constant during a fuel cycle because the only governing parameters, namely system resistance and the reactor coolant pump characteristics, are controlled in the design process. Additionally, Westinghouse has instrumented typical reactor coolant systems to verify the flow and vibration characteristics of the system. Preoperational testing and operating experience have verified the Westinghouse approach. The operating transients of the RCS primary piping are such that no significant water hammer can occur.

### 2.3 Low Cycle and High Cycle Fatigue

Low cycle fatigue considerations are accounted for in the design of the piping system through the fatigue usage factor evaluation to show compliance with the rules of Section III of the ASME Code. A further evaluation of the low cycle fatigue loadings was carried out as part of this study in the form of a fatigue crack growth analysis, as discussed in section 8.0

High cycle fatigue loads in the system would result primarily from pump vibrations. These are minimized by restrictions placed on shaft vibrations during hot functional testing and operation. During operation, an alarm signals the exceedence of the vibration limits. Field measurements have been made on a number of plants during hot functional testing, including plants similar to the Farley Units 1 and 2. Stresses in the elbow below the reactor coolant pump resulting from system vibration have been found to be very small, between 2 and 3 ksi at the highest. These stresses are well below the fatigue endurance limit for the material and would also result in an applied stress intensity factor below the threshold for fatigue crack growth.

### 2.4 References

- 2-1 Investigation and Evaluation of Stress-Corrosion Cracking in Piping of Light Water Reactor Plants, NUREG-0531, U.S. Nuclear Regulatory Commission, February 1979.
- 2-2 Investigation and Evaluation of Cracking Incidents in Piping in Pressurized Water Reactors, NUREG-0691, U.S. Nuclear Regulatory Commission, September 1980.

SECTION 3.0  
PIPE GEOMETRY AND LOADING

3.1 Introduction to Methodology

The general approach is discussed first. As an example a segment of the primary coolant hot leg pipe of Farley Unit 1 is shown in figure 3-1. The as-built outside diameter and minimum wall thickness of the pipe are 33.78 in. and 2.28 in., respectively, as seen in the figure. Normal stresses at the weld locations result from the load combination procedure discussed in section 3.3 while faulted load are developed as outlined in section 3.4. The components for normal loads are pressure, dead weight and thermal expansion. An additional component, Safe Shutdown Earthquake (SSE), is considered for faulted loads. As seen later the highest stressed location in the pipe is at the reactor vessel outlet nozzle to pipe weld. This location is the load critical location and is one of the locations at which, as an enveloping location, leak-before-break is to be established. Essentially a circumferential flaw is postulated to exist at this location thus the normal loads and faulted loads must be available to assess leakage and stability, respectively. The loads (developed below) at this location for Farley Unit 1 are also given in Figure 3-1.

Since the pipe and fittings are cast stainless steel, thermal aging must be considered (see section 4.0). Thermal aging results in lower fracture toughness criteria; thus, other locations than the highest stressed location must be examined taking into consideration both fracture toughness and stress. The enveloping locations so determined are called toughness critical locations. The single most critical location is apparent only after the full analyses is completed. Once loads (this section) and fracture toughnesses (section 4.0) are available, the load critical and toughness critical locations are determined (see section 5.0). At these locations, leak rate evaluations (see section 6.0) and fracture mechanics evaluations (see section 7.0) are performed per the guidance of reference 3-1. Fatigue crack growth (see section 8.0) and stability margins are also evaluated (see section 9.0).

The locations for evaluation are those shown in figure 3-2.

### 3.2 Calculation of Loads and Stresses

The stresses due to axial loads and bending moments are calculated by the following equation:

$$\sigma = \frac{F}{A} + \frac{M}{Z} \quad (3-1)$$

where,

$\sigma$	=	stress
F	=	axial load
M	=	bending moment
A	=	pipe cross-sectional area
Z	=	section modulus

The bending moments for the desired loading combinations are calculated by the following equation:

$$M = \sqrt{M_Y^2 + M_Z^2} \quad (3-2)$$

where,

M	=	bending moment for required loading
$M_Y$	=	Y component of bending moment
$M_Z$	=	Z component of bending moment

The axial load and bending moments for leak rate predictions and crack stability analysis are computed by the methods to be explained in sections 3.3 and 3.4.

### 3.3 Loads for Leak Rate Evaluation

The normal operating loads for leak rate predictions are calculated by the following equations:

$$F = F_{DW} + F_{TH} + F_P \quad (3-3)$$

$$M_Y = (M_Y)_{DW} + (M_Y)_{TH} + (M_Y)_P \quad (3-4)$$

$$M_Z = (M_Z)_{DW} + (M_Z)_{TH} + (M_Z)_P \quad (3-5)$$

The subscripts of the above equations represent the following loading cases:

- DW = deadweight
- Th = normal thermal expansion
- P = load due to internal pressure

This method of combining loads is often referred as the algebraic sum method.

The loads based on this method of combination are provided in tables 3-1 and 3-2 for Farley Units 1 and 2, respectively, at all the locations identified in figure 3-2. The as-built dimensions are also given.

### 3.4 Load Combination for Crack Stability Analysis

In accordance with standard review plan 3.6.3 the absolute sum of loading components can be applied which results in higher magnitude of combined loads. If crack stability is demonstrated using these loads, the LBB margin on loads can be reduced from  $\sqrt{2}$  to 1.0. The absolute summation of loads results in the following equations:

$$F = |F_{DW}| + |F_{TH}| + |F_P| + |F_{SSEINERTIA}| + |F_{SSEAM}| \quad (3-6)$$

$$M_Y = |(M_Y)_{DW}| + |(M_Y)_{TH}| + |(M_Y)_P| + |(M_Y)_{SSEINERTIA}| + |(M_Y)_{SSEAM}| \quad (3-7)$$

$$M_Z = |(M_Z)_{DW}| + |(M_Z)_{TH}| + |(M_Z)_P| + |(M_Z)_{SSEINERTIA}| + |(M_Z)_{SSEAM}| \quad (3-8)$$

where subscripts SSE, INERTIA and AM mean safe shutdown earthquake, inertia and anchor motion, respectively.

The loads so determined are used in the fracture mechanics evaluations (section 7.0) to demonstrate the LBB margins at the locations established to be the governing locations. The loads at all the locations of interest (see figure 3-2) are summarized in tables 3-3 and 3-4 for Farley Units 1 and 2, respectively.

3.5 References

- 3-1 USNRC Standard Review Plan 3.6.3, Leak-Before-Break Evaluation Procedures, NUREG-0800.



TABLE 3-1  
 DIMENSIONS, NORMAL LOADS AND NORMAL STRESSES FOR  
 FARLEY UNIT 1

Location <sup>a</sup>	Outside Diameter (in.)	Thickness (in.)	Axial Load <sup>b</sup> (kips)	Bending Moment (in-kips)	Stress (ksi)
1	33.78	2.28	1458	25150	21.6
2	33.78	2.28	1456	12519	14.0
3	36.96	2.88	1519	20635	13.4
4	36.76	2.88	1644	6412	8.0
5	36.05	2.42	1630	5168	8.9
6	36.05	2.42	1625	4929	8.8
7	36.05	2.42	1711	7406	7.1
8	36.05	2.42	1711	3091	8.2
9	37.16	2.98	1819	8586	9.1
10	32.03	2.16	1369	4427	9.9
11	32.03	2.16	1370	4389	9.9
12	32.03	2.56	1365	4314	8.1

---

<sup>a</sup> See figure 3-2  
<sup>b</sup> Includes pressure

TABLE 3-2  
 DIMENSIONS, NORMAL LOADS AND NORMAL STRESSES FOR  
 FARLEY UNIT 2

Location <sup>a</sup>	Outside Diameter (in.)	Thickness (in.)	Axial Load <sup>b</sup> (kips)	Bending Moment (in-kips)	Stress (ksi)
1	33.81	2.30	1456	25150	21.4
2	33.81	2.30	1456	12519	13.8
3	36.20	2.50	1519	20635	15.6
4	35.20	2.50	1644	6412	9.3
5	36.11	2.45	1630	5168	8.8
6	36.11	2.45	1625	4929	8.7
7	36.11	2.45	1711	7406	7.0
8	36.11	2.45	1711	3091	8.1
9	37.52	3.16	1819	8586	8.5
10	32.07	2.18	1369	4427	9.8
11	32.07	2.18	1369	4389	9.8
12	32.14	2.22	1365	4314	9.5

---

<sup>a</sup> See figure 3-2  
<sup>b</sup> Includes pressure

TABLE 3-3  
 FAULTED LOADS AND STRESSES FOR FAILURE UNIT 1


Location <sup>a,b</sup>	Axial Load <sup>c</sup> (kips)	Bending Moment (in-kips)	Stress (ksi)
1	1768	30130	25.9
2	1765	16101	17.5
3	2072	26015	17.4
4	1937	19498	14.3
5	1895	13837	14.3
6	1890	6889	10.8
7	1840	7274	10.8
8	1831	10206	12.2
9	1896	16486	12.4
10	1576	10665	15.3
11	1530	8615	13.9
12	1539	8689	11.4

- 
- a See Figure 3-2  
 b See table 3-1 for dimensions  
 c Includes pressure

TABLE 3-4  
 FAULTED LOADS AND STRESSES FOR FARLEY UNIT 2

Location <sup>a,b</sup>	Axial Load <sup>c</sup> (kips)	Bending Moment (in-kips)	Stress (ksi)
1	1767	30130	25.7
2	1765	16101	17.3
3	2072	26015	20.3
4	1937	19498	16.7
5	1895	13427	14.1
6	1690	6889	10.7
7	1840	7274	10.7
8	1834	10206	12.1
9	1896	16486	11.7
10	1576	10665	15.1
12	1580	8615	13.7
12	1539	8689	13.3

- <sup>a</sup> See Figure 3-2  
<sup>b</sup> See table 3-2 for dimensions  
<sup>c</sup> Includes pressure



Normal Loads


force<sup>a</sup>: 1458 kips  
 bending moment: 25150 in-kips

Faulted Loads

force<sup>a</sup>: 1768 kips  
 bending moment: 30130 in-kips

<sup>a</sup>Includes the force due to a pressure of 2235 psig

Figure 3-1. Hot Leg Coolant Pipe of Farley Unit 1



Hot Leg Temperature: 611°F  
 Cold Leg Temperature: 544°F




Figure 3-2 Schematic Diagram of the Farley Plants RCL Showing Weld Locations

SECTION 4.0  
MATERIAL CHARACTERIZATION

4.1 Primary Loop Pipe and Fittings Materials

The primary loop piping material for both Farley Unit 1 and Farley Unit 2 are SA351 CF8A. The elbow fittings for Farley Unit 1 are SA351 CF8M, while for Farley Unit 2, they are SA351 CF8A. The field welds are SMAW following GTAW root passes. The shop welds are SAW.

4.2 Tensile Properties

The Certified Materials Test Reports (CMTRs) for Farley Units 1 and 2 were used to establish the tensile properties for the leak-before-break analyses. The CMTRs include tensile properties at room temperature for each of the heats of material and some tensile properties at 650°F. The properties for the heats of Farley Unit 1 and Farley Unit 2 are given in Tables 4-1 and 4-2, respectively. The average properties are given and the lower bound properties are identified. The 1989 ASME Code minimum on properties are also given.

The properties at 544°F and 611°F were established by scaling the plant specific values by the ratio of the ASME Code minimum properties. Preference was given to values at 650°F when available; otherwise, a scaling based on room temperature was made. The average and lower bound yield stresses and ultimate strengths, so scaled, are given in tables 4-3 and 4-4 for Farley Units 1 and 2, respectively. The ASME Code Modulus of Elasticity is also given at each temperature. Poisson's Ratio was taken as 0.3. The study of critical locations (Section 5.0) showed that the properties at only 611°F are required for the LBB evaluation. The 544°F properties are included for completeness.

For leak-before-break fracture evaluations the true stress-true strain curves must be available. Such curves were obtained using the Nuclear Systems Materials Handbook (reference 4-1). The average and lower bound true stress-true strain curves are given for Farley Unit 1 in Figures 4-1 through 4-8. Similar curves for Farley Unit 2 are given in figures 4-9 through 9-12. Curves at both 544°F and 611°F are presented.

#### 4.3 Fracture Toughness Properties

The pre-service fracture toughness of cast materials in terms of  $J$  have been found to be very high at 600°F. Typical results for a cast material are given in figure 4-13 taken from reference 4-2.  $J_{1c}$  is observed to be over 5000 in-lbs/in<sup>2</sup>. However cast stainless steels are subject to thermal aging during service. This thermal aging causes an elevation in the yield strength of the material and a degradation of the fracture toughness, the degree of degradation being somewhat proportional to the level of ferrite in the material.

To determine the effects of thermal aging on piping integrity, a detailed study was carried out in reference 4-3. In that report, fracture toughness results were presented for a material [

] <sup>a,c,e</sup> The effects of the aging process on the end-of-service life fracture toughness are further discussed in Appendix B.



End-of-service life toughness for the heats are established using the alternate toughness criteria methodology of reference 4-6 (appendix B). By that methodology a heat of material is said to be as good as [ ]<sup>a,c,e</sup> if it can be demonstrated that its end-of-service fracture toughnesses equal or exceed those of [ ]<sup>a,c,e</sup>.

The worst case fracture toughness values for all the loops of each plant at each location (see figure 3-2), as taken from Appendix B, are given in table 4-5. All locations for Farley Unit 2 qualify for the highest assignable toughness values as discussed above. Only four locations so qualify for Farley Unit 1. The lowest fracture toughness values for Farley Unit 1 occur at locations 2 and 3.

Available data on aged stainless steel welds (references 4-3 and 4-4) indicate that  $J_{Ic}$  values for the worst case welds are of the same order as the aged material. However, the slope of the J-R curve is steeper, and higher J-values have been obtained from fracture tests (in excess of 3000 in-lb/in<sup>2</sup>). The applied value of the J-integral for a flaw in the weld regions will be lower than that in the base metal because the yield stress for the weld materials is much higher at temperature<sup>a</sup>. Therefore, weld regions are less limiting than the cast material.

It is thus conservative to choose the end-of-service life toughness properties of [ ]<sup>a,c,e</sup> as representative of those of the welds. Also, such pipes and fittings having an end-of-service life calculated room temperature charpy U-notch energy, (KCU), greater than that of [ ]<sup>a,c,e</sup> are also conservatively assumed to have the properties of [ ]<sup>a,c,e</sup>.

In the fracture mechanics analyses that follow, the fracture toughness properties given in table 4-5 will be used as the criteria against which the applied fracture toughness values will be compared.

---

<sup>a</sup> In the report all  $J_{applied}$  values were conservatively determined by using base metal strength properties.

#### 4.4 References

- 4-1 Nuclear Systems Materials Handbook, Part I - Structural Materials, Group 1 - High Alloy Steels, Section 2, ERDA Report TID 26666, November, 1975.
- 4-2 WCAP-9558 Rev. 2, "Mechanistic Fracture Evaluation of Reactor Coolant Pipe Containing a Postulated Circumferential Through-Wall Crack," Westinghouse Proprietary Class 2, June 1981.
- 4-3 WCAP-10456, "The Effects of Thermal Aging on the Structural Integrity of Cast Stainless Steel Piping for W NSSS," W Proprietary Class 2, November 1983.
- 4-4 Slama, G., Petrequin, P., Masson, S.H., and Mager, T.R., "Effect of Aging on Mechanical Properties of Austenitic Stainless Steel Casting and Welds", presented at SMIRT 7 Post Conference Seminar 6 - Assuring Structural Integrity of Steel Reactor Pressure Boundary Components, August 29/30, 1983, Monterey, CA.
- 4-5 Appendix II of Letter from Dominic C. DiIanni, NRC to D. M. Musolf, Northern States Power Company, Docket Nos. 50-282 and 50-306, December 22, 1986.
- 4-6 Witt, F.J., Kim, C.C., "Toughness Criteria for Thermally Aged Cast Stainless Steel," WCAP-10931, Revision 1, Westinghouse Electric Corporation, July 1986, (Westinghouse Proprietary Class 2).

TABLE 4-1  
 MEASURED TENSILE PROPERTIES FOR FARLEY UNIT 1  
 PRIMARY LOOP PIPING AND FITTINGS

Component	Loop No.	Heat No.	Material	Yield Stress (psi)		Ultimate Strength (psi)	
				Room Temp.	650°F	Room Temp.	650°F

PIPE

a.c.e

4-5

TABLE 4-2  
 MEASURED TENSILE PROPERTIES FOR THE PRIMARY LOOP PIPING  
 AND FITTINGS (ALL SA351 CF8A) OF FARLEY UNIT 2

Component	Loop No.	Heat No.	Yield Stress (psi) Room Temp. 650°F	Ultimate Strength (psi) at Room Temp.
-----------	----------	----------	--	--

PIPE

a.c.e

4-6

TABLE 4-3  
 MECHANICAL PROPERTIES FOR FARLEY UNIT 1  
 MATERIALS AT 544°F AND 611°F

Material	Temperature (°F)	Average		Lower Bound		
		Yield Stress (psi)	Ultimate Strength (psi)	Yield Stress (psi)	Ultimate Strength (psi)	
SA351 CF8A	[					] a,c,e
SA351 CF8M						

4-7

Modulus of Elasticity for Both Materials:

at 544°F,  $E = 25.6 \times 10^6$  psi

at 611°F,  $E = 25.2 \times 10^6$  psi

Poisson's Ratio: 0.3

TABLE 4-4  
 MECHANICAL PROPERTIES FOR FARLEY UNIT 2  
 MATERIAL (SA351 CF8A) AT 544°F AND 611°F

Temperature (°F)	Average		Lower Bound	
	Yield Stress (psi)	Ultimate Strength (psi)	Yield Stress (psi)	Ultimate Strength (psi)
544	[ a, c, e ]			
611				

Modulus of Elasticity: at 544°F,  $E = 25.6 \times 10^6$  psi  
 at 611°F,  $E = 25.2 \times 10^6$  psi

Poisson's Ratio: 0.3

TABLE 4-5  
 ENVELOPED FRACTURE TOUGHNESS PROPERTIES FOR  
 FARLEY UNITS 1 AND 2 PRIMARY  
 LOOPS FOR LEAK-BEFORE-BREAK EVALUATION

Location <sup>a,b</sup>	HT. NO.	KCU (daJ/cm <sup>2</sup> )	J <sub>Ic</sub> (in-lb/in <sup>2</sup> )	T <sub>mat</sub> (non-dim)	J <sub>max</sub> (in-lb/in <sup>2</sup> )
<u>Farley Unit 1</u>					
1					a, c, e
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					




Figure 4-1: Average True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 1 at 544°F






Figure 4-2: Lower Bound True Stress-True Strain Curve for the SA351 CFBA Material of Farley Unit 1 at 544°F




Figure 4-3: Average True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 1 at 611°F




Figure 4-4: Lower Bound True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 1 at 611°F




Figure 4-5: Average True Stress-True Strain Curve for the SA351 CF8M Material of Farley Unit 1 at 544°F




Figure 4-6: Lower Bound True Stress-True Strain Curve for the SA351 CF8M Material of Farley Unit 1 at 544°F




Figure 4-7: Average True Stress-True Strain Curve for the SA351 CF8M Material of Farley Unit 1 at 611°F




Figure 4-8: Lower Bound True Stress-True Strain Curve for the SA351 CF8M Material of Farley Unit 1 at 611°F




Figure 4-9: Average True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 2 at 544°F






Figure 4-10: Lower Bound True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 2 at 544°F




Figure 4-11: Average True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 2 at 611°F




Figure 4-12: Lower Bound True Stress-True Strain Curve for the SA351 CF8A Material of Farley Unit 2 at 611°F




Figure 4-13: J vs.  $\Delta a$  for SA351 CF8M Cast Stainless Steel at 600°F




Figure 4-14: J Vs.  $\Delta a$  at Different Temperatures for Aged Material  
 [ ]<sup>a,c,e</sup> (7500 Hours at 400°C)

SECTION 5.0  
CRITICAL LOCATIONS AND EVALUATION CRITERIA

5.1 Critical Locations

The leak-before-break (LBB) evaluation margins are to be demonstrated for the limiting location (governing location). Candidate locations are designated load critical locations or toughness critical locations as discussed in Section 3.0. Such locations are established considering the loads (section 3.0) and the material properties established in section 4.0. These locations are defined below for Farley Units 1 and 2. Tables 3-1 through 3-4 and 4-5 are used for this evaluation along with figure 3-2.

Farley Unit 1

Location 1 is the highest stressed location and is the load critical location by definition. The lowest toughness values are at locations 2 and 3 with the loads being about the same. These two locations are thus toughness critical locations. These locations are now compared with the remaining locations in the crossover leg and cold leg. It is observed that (1) the temperature at locations 2 and 3 is higher thus the tensile properties are worse (2) the stresses at locations 2 and 3 are higher and (3) the fracture toughness,  $J_{max}$ , at locations 2 and 3 is at least a factor of three less, the factor being over 10 for  $T_{mat}$ . It is thus concluded that the enveloping locations in Farley Unit 1 for which the LBB methodology is to be applied are locations 1, 2 and 3.

Farley Unit 2

Location 1 is the highest stressed location and is thus the load critical location. Since this location is at the higher temperature (i.e., has the worst tensile properties) and all locations are assigned the same toughnesses, this location envelopes the other locations and is the only one at which LBB evaluations are required.

## 5.2 Fracture Criteria

As discussed later, fracture mechanics analyses are made based on loads and postulated flaw sizes related to leakage. The stability criteria against which the calculated  $J$  (i.e.  $J_{app}$ ) and tearing modulus ( $T_{app}$ ) are compared are:

(1) If  $J_{app} < J_{Ic}$ , then the crack is stable;

(2) If  $J_{app} \geq J_{Ic}$ , then, if  $T_{app} < T_{mat}$

and  $J_{app} < J_{max}$ , the crack is stable.

The toughness criteria at each location have previously been determined and are given in table 4-5.

SECTION 6.0  
LEAK RATE PREDICTIONS

6.1 Introduction

The purpose of this section is to discuss the method which is used to predict the flow through postulated through-wall cracks and present the leak rate calculation results for through-wall circumferential cracks.

6.2 General Considerations

The flow of hot pressurized water through an opening to a lower back pressure causes flashing which can result in choking. For long channels where the ratio of the channel length,  $L$ , to hydraulic diameter,  $D_H$ , ( $L/D_H$ ) is greater than [ ]<sup>a,c,e</sup>, both [

]<sup>a,c,e</sup>.

6.3 Calculation Method

The basic method used in the leak rate calculations is the method developed by [

]

The flow rate through a crack was calculated in the following manner. Figure 6-1 from reference 6-1 was used to estimate the critical pressure,  $P_c$ , for the primary loop enthalpy condition and an assumed flow. Once  $P_c$  was found for a given mass flow, the [ ]<sup>a,c,e</sup> was found from figure 6-2 taken from reference 6-1. For all cases considered, since [ ]<sup>a,c,e</sup> Therefore, this method will yield



the two-phase pressure drop due to momentum effects as illustrated in figure 6-3. Now using the assumed flow rate, G, the frictional pressure drop can be calculated using

$$\Delta P_f = [ \quad ]^{a,c,e} \quad (6-1)$$

where the friction factor  $f$  is determined using the [  $\quad ]^{a,c,e}$ . The crack relative roughness,  $\epsilon$ , was obtained from fatigue crack data on stainless steel samples. The relative roughness value used in these calculations was [  $\quad ]^{a,c,e}$ .

The frictional pressure drop using equation 6-1 is then calculated for the assumed flow and added to the [  $\quad ]^{a,c,e}$  to obtain the total pressure drop from the primary system to the atmosphere. That is, for the primary loop

$$\text{Absolute Pressure} - 14.7 = [ \quad ]^{a,c,e} \quad (6-2)$$

for a given assumed flow G. If the right-hand side of equation 6-2 does not agree with the pressure difference between the primary loop and the atmosphere, then the procedure is repeated until equation 6-2 is satisfied to within an acceptable tolerance and this results in the flow value through the crack.

#### 6.4 Leak Rate Calculations

Leak rate calculations were made as a function of crack length at the four locations previously identified in section 5.2. The normal operating loads of tables 3-1 and 3-2 were applied as appropriate, in these calculations. The crack opening areas were estimated using the method of reference 6-2 and the leak rates were calculated using the two-phase flow formulation described above. The average material properties of section 4.0 were used for these calculations.

The flaw sizes to yield a leak rate of 10 gpm were calculated at the four locations and are given in Table 6-1. The flaw sizes so determined are called leakage flaws.

The Farley plant RCS pressure boundary leak detection system, as documented in FSAR Section 5.2.7 and the NRC Safety Evaluation Report Section 5.6, meets the intent of Regulatory Guide 1.45. Thus, to satisfy the margin of 10 on the leak rate, the flaw sizes (leakage flaws) are determined which yield a leak rate of 10 gpm.

### 6.5 References

6-1 [

j<sup>r</sup>,c,e.

6-2 Tada, H., "The Effects of Shell Corrections on Stress Intensity Factors and the Crack Opening Area of Circumferential and a Longitudinal Through-Crack in a Pipe," Section II-1, NUREG/CR-3464, September 1983.

TABLE 6-1  
Flaw Sizes Yielding a Leak Rate of  
10 gpm at the Four Locations

Unit	Location	Flaw Size (in)
1	1	3.25
1	2	5.00
1	3	5.50
2	1	3.10



Figure 6-1. Analytical Predictions of Critical Flow Rates of Steam-Water Mixtures




Figure 6-2. [ ]<sup>a, c, e</sup> Pressure Ratio as a Function of L/D




Figure 6-3. Idealized Pressure Drop Profile Through a Postulated Crack

SECTION 7.0  
FRACTURE MECHANICS EVALUATION

7.1 Local Failure Mechanism

The local mechanism of failure is primarily dominated by the crack tip behavior in terms of crack-tip blunting, initiation, extension and finally crack instability. The local stability will be assumed if the crack does not initiate at all. It has been accepted that the initiation toughness measured in terms of  $J_{IC}$  from a J-integral resistance curve is a material parameter defining the crack initiation. If, for a given load, the calculated J-integral value is shown to be less than the  $J_{IC}$  of the material, then the crack will not initiate. If the initiation criterion is not met, one can calculate the tearing modulus as defined by the following relation:

$$T_{app} = \frac{dJ}{da} \frac{E}{\sigma_f^2}$$

where:

$T_{app}$  = applied tearing modulus

$E$  = modulus of elasticity

$\sigma_f$  =  $0.5 (\sigma_y + \sigma_u)$  (flow stress)

$a$  = crack length

$\sigma_y, \sigma_u$  = yield and ultimate strength of the material, respectively

Stability is said to exist when ductile tearing occurs if  $T_{app}$  is less than  $T_{mat}$ , the experimentally determined tearing modulus. Since a constant  $T_{mat}$  is assumed a further restriction is placed in  $J_{app}$ .  $J_{app}$  must be less than  $J_{max}$  where  $J_{max}$  is the maximum value of  $J$  for which the experimental  $T$  is greater than or equal to the  $T_{mat}$  used.

As discussed in Section 5.2 the local crack stability will be established by the two-step criteria:

(1) If  $K_{app} < J_{Ic}$ , then the crack is stable.

(2) If  $J_{app} \geq J_{Ic}$ , then, if  $T_{app} < T_{mat}$

and  $J_{app} < J_{max}$ , the crack is stable.

## 7.2 Global Failure Mechanism

Determination of the conditions which lead to failure in stainless steel should be done with plastic fracture methodology because of the large amount of deformation accompanying fracture. One method for predicting the failure of ductile material is the plastic instability method, based on traditional plastic limit load concepts, but accounting for strain hardening and taking into account the presence of a flaw. The flawed pipe is predicted to fail when the remaining net section reaches a stress level at which a plastic hinge is formed. The stress level at which this occurs is termed as the flow stress. The flow stress is generally taken as the average of the yield and ultimate tensile strength of the material at the temperature of interest. This methodology has been shown to be applicable to ductile piping through a large number of experiments and will be used here to predict the critical flaw size in the primary coolant piping. The failure criterion has been obtained by requiring equilibrium of the section containing the flaw (figure 7-1) when loads are applied. The detailed development is provided in appendix A for a through-wall circumferential flaw in a pipe with internal pressure, axial force, and imposed bending moments. The limit moment for such a pipe is given by:

$$[ \quad ] \quad a, c, e$$

where:

[

] a, c, e



j a. c. e

The analytical model described above accurately accounts for the piping internal pressure as well as imposed axial force as they affect the limit moment. Good agreement was found between the analytical predictions and the experimental results (reference 7-1).

For application of the limit load methodology, the material, including consideration of the configuration, must have a sufficient ductility and ductile tearing resistance to sustain the limit load.

### 7.3 Results of Crack Stability Evaluation

Stability analyses were performed at the critical locations established in section 5.1. The elastic-plastic fracture mechanics (EPFM) J-integral analyses for through-wall circumferential cracks in a cylinder were performed using the procedure in the EPRI fracture mechanics handbook (reference 7-2).

The lower-bound material properties of section 4.0 were applied (see tables 4-3 and 4-4). The fracture toughness properties established in section 4.3 (see table 4-5) and the normal plus SSE loads given in tables 3-3 and 3-4 were used for the EPFM calculations. The flaw sizes were twice those giving a leak rate of 10 gpm as established in section 6.0 (see table 6-1). Evaluations were performed at the four critical locations identified in section 5.1. The results of the elastic-plastic fracture mechanics J-integral evaluations are

given in table 7-1. It is seen that the fracture criteria are met at all the locations. Specifically a margin of 2 on flaw size is demonstrated. Since the faulted load combination method used in this calculation is based on the absolute sum method, the required margin on load of 1.0 is also accomplished as discussed in SRP 3.6.3.

At the four critical locations identified in section 5.1 stability analyses based on limit load were also performed as described in section 7.2. The weld at these locations are either SMAW with GTAW root passes or SAW. Therefore, "Z" factor corrections for the SMAW welds were applied (reference 7-3) as follows:

$$Z = 1.15 [1.0 + 0.013 (OD-4)]$$

where OD is the outer diameter of the pipe in inches.

The Z-factor for SAW welds is as follows (reference 7-3):

$$Z = 1.30 [1 + 0.010 (OD-4)]$$

The Z-factors were calculated for the four critical locations using the dimensions given in tables 3-1 and 3-2. These factors are given in table 7-2. The applied loads were increased by the Z factor and a plot of limit load versus crack length was generated as shown in figures 7-2 through 7-5. The critical flaw sizes at the four critical locations are given in table 7-2 along with the leakage flaw sizes. A margin well in excess of 2 is demonstrated at each location. The lower bound base metal properties established in section 4.0 were used for this purpose.

#### 7.4 References

- 7-1. Kanninen, M. F., et. al., "Mechanical Fracture Predictions for Sensitized Stainless Steel Piping with Circumferential Cracks," EPRI NP-192, September 1976.

7-2. Kumar, V., German, M. D. and Shih, C. P., "An Engineering Approach for Elastic-Plastic Fracture Analysis," EPRI Report NP-1931, Project 1237-1, Electric Power Research Institute, July 1981.

7-3. ASME Code Section XI, Winter 1985 Addendum, Article IWB-3640.

TABLE 7-1

STABILITY RESULTS FOR FARLEY UNITS 1 AND 2  
 BASED ON ELASTIC-PLASTIC  
 J-INTEGRAL EVALUATIONS

Location	Flaw Size <sup>a</sup> (in)	Fracture Criteria			Calculated Values	
		$J_{Ic}$ (in-lb/in <sup>2</sup> )	$T_{mat}$	$J_{max}$ (in-lb/in <sup>2</sup> )	$J_{app}$ (in-lb/in <sup>2</sup> )	$T_{app}$
<u>Farley Unit 1</u>						
1	6.5	[				] a,c,e
2	10.0					
3	11.0					
<u>Farley Unit 2</u>						
1	6.2	[				] a,c,e

<sup>a</sup> Twice the 10 gpm leakage size flaw established in section 6.0

<sup>b</sup> N.A. - Not applicable;  $J_{app} < J_{Ic}$

TABLE 7-2

STABILITY RESULTS BASED ON LIMIT LOAD ANALYSES

Location	Weld	Z Factor	Leakage Flaw Size (in)	Critical Flaw Size (in)	Margin
<u>Farley Unit 1</u>					
1	SMAW	[			] a,c,e
2	SAW				
3	SMAW				
<u>Farley Unit 2</u>					
1	SMAW	[			] a,c,e




Figure 7-1. [  $a, c, e$  Stress Distribution ]




Figure 7-2. Critical Flaw Size Prediction - Hot Leg at Location 1 for Farley Unit 1



Figure 7-3 Critical Flaw Size Prediction - Hot Leg at  
Location 2 for Farley Unit 1






Figure 7-4 Critical Flaw Size Prediction - Hot Leg  
at Location 3 for Farley Unit 1




Figure 7-5 Critical Flaw Size Prediction - Hot Leg  
at Location 1 for Farley Unit 2

SECTION 8.0  
FATIGUE CRACK GROWTH ANALYSIS

To determine the sensitivity of the primary coolant system to the presence of small cracks, a fatigue crack growth analysis was carried out for the [ ]<sup>a,c,e</sup> region of a typical system (see Location [ ]<sup>a,c,e</sup> of figure 3-2). This region was selected because crack growth calculated here will be typical of that in the entire primary loop. Crack growths calculated at other locations can be expected to show less than 10% variation.

A [ ]<sup>a,c,e</sup> of a plant typical in geometry and operational characteristics to any Westinghouse PWR System. [ ]

[ ]<sup>a,c,e</sup> All normal, upset, and test conditions were considered. A summary of the applied transients is provided in table 8-1. Circumferentially oriented surface flaws were postulated in the region, assuming the flaw was located in three different locations, as shown in figure 8-1. Specifically, these were:

- Cross Section A: [ ]<sup>a,c,e</sup>
- Cross Section B: [ ]<sup>a,c,e</sup>
- Cross Section C: [ ]<sup>a,c,e</sup>

Fatigue crack growth rate laws were used [ ]

[ ]<sup>a,c,e</sup> The law for stainless steel was derived from reference 8-1, with a very conservative correction for the R ratio, which is the ratio of minimum to maximum stress during a transient.

For stainless steel, the fatigue crack growth formula is:

$$\frac{da}{dn} = (5.4 \times 10^{-12}) K_{eff}^{4.48} \text{ inches/cycle}$$

where  $K_{eff} = K_{max} (1-R)^{0.5}$

$$R = K_{min}/K_{max}$$

[

] a,c,e

[

]

a,c,e

where: [ ] a,c,e

The calculated fatigue crack growth for semi-elliptic surface flaws of circumferential orientation and various depths is summarized in table 8-2, and shows that the crack growth is very small, [

] a,c,e

### 8.1 References

- 8-1 Bamford, W. H., "Fatigue Crack Growth of Stainless Steel Piping in a Pressurized Water Reactor Environment," Trans. ASME Journal of Pressure Vessel Technology, Vol. 101, Feb. 1979.

8-2 [

]a.c.e

8-3 [

]a.c.e

TABLE B-1  
SUMMARY OF REACTOR VESSEL TRANSIENTS

NUMBER	TYPICAL TRANSIENT IDENTIFICATION	NUMBER OF CYCLES
<u>Normal Conditions</u>		
1	Heatup and Cooldown at 100°F/hr (pressurizer cooldown 200°F/hr)	200
2	Load Follow Cycles (Unit loading and unloading at 5% of full power/min)	18300
3	Step load increase and decrease	2000
4	Large step load decrease, with steam dump	200
5	Steady state fluctuations	10 <sup>6</sup>
<u>Upset Conditions</u>		
6	Loss of load, without immediate turbine or reactor trip	80
7	Loss of power (blackout with natural circulation in the Reactor Coolant System)	40
8	Loss of Flow (partial loss of flow, one pump only)	80
9	Reactor trip from full power	400
<u>Test Conditions</u>		
10	Turbine roll test	10
11	Hydrostatic test conditions	
	Primary side	5
	Primary side leak test	50
12	Cold Hydrostatic test	10

TABLE 8-2

TYPICAL FATIGUE CRACK GROWTH AT  
 [ ]<sup>a,c,e</sup> (40 YEARS)

INITIAL FLAW (IN)	FINAL FLAW (in)		
	[ ] <sup>a,c,e</sup>	[ ] <sup>a,c,e</sup>	[ ] <sup>a,c,e</sup>
0.292	0.31097	0.30107	0.30698
0.300	0.31949	0.30953	0.31626
0.375	0.39940	0.38948	0.40763
0.425	0.45271	0.4435	0.47421



Dimensions in inches

<sup>a</sup>Farley Unit 1  
<sup>b</sup>Farley Unit 2

Figure 8-1. Typical Cross-Section of [ ]a, c, e



CRACK GROWTH RATE,  $da/dN$  (MICRO-INCHES / CYCLE)

S.C. 8

Figure 8-2. Reference Fatigue Crack Growth Curves for [  
] a, c, e




Figure 8-3. Reference Fatigue Crack Growth Law for [ ] a.c.e  
in a Water Environment at 600°F

SECTION 9.0  
ASSESSMENT OF MARGINS

The results of the leak rates of section 7.4 and the corresponding fracture toughness evaluations of section 7.3 are used in performing the assessment of margins.

Leakage flaws were established at the four critical locations based on a leak rate of 10 gpm. A margin of at least two on the leakage flaw size was established using both elastic-plastic fracture mechanics and limit load analysis (with the Z-factor correction). The faulted loads were determined using the absolute sum method thus a margin on load of 1.0 for the leakage flaw is adequate per SRP 3.6.3.. It follows, of course, that the leakage flaw is stable since a flaw twice as large was shown to be stable. In summary, at all the critical locations relative to:

1. Flaw Size - Using faulted loads obtained by the absolute sum method, a margin of at least 2 exists between the critical flaw and the flaw having a leak rate of 10 gpm (the leakage flaw).
2. Leak Rate - A margin of 10 exists between the calculated leak rate from the leakage flaw and the leak detection capability of 1 gpm.
3. Loads - At the critical locations the leakage flaw was shown to be stable using the faulted loads obtained by the absolute sum method.

SECTION 10.0  
CONCLUSIONS

This report justifies the elimination of RCS primary loop pipe breaks for the Farley Units 1 and 2 nuclear plants as follows:

- a. Stress corrosion cracking is precluded by use of fracture resistant materials in the piping system and controls on reactor coolant chemistry, temperature, pressure, and flow during normal operation.
- b. Water hammer should not occur in the RCS piping because of system design, testing, and operational considerations.
- c. The effects of low and high cycle fatigue on the integrity of the primary piping are negligible.
- d. Adequate margin exists between the leak rate of small stable flaws and the capability of the Farley Units 1 and 2 reactor coolant system pressure boundary Leakage Detection System.
- e. Ample margin exists between the small stable flaw sizes of item d and larger stable flaws.
- f. Ample margin exists in the material properties used to demonstrate end-of-service life (relative to aging) stability of the critical flaws.

For the critical locations flaws are identified that will be stable because of the ample margins in d, e, and f above.

Based on the above, it is concluded that dynamic effects of RCS primary loop pipe breaks need not be considered in the structural design basis of the Farley Units 1 and 2 plants.

APPENDIX A

LIMIT MOMENT

[

] a.c.e



Figure A-1 Pipe with a Through-Wall Crack in Bending

## APPENDIX B

### ALTERNATE TOUGHNESS CRITERIA FOR THE FARLEY UNITS 1 AND 2 CAST PRIMARY LOOP COMPONENTS

#### B.1 Introduction

Not all of the individual cast piping components of the Farley primary loop piping satisfy the original [ ]<sup>a,c,e</sup> criteria (reference 4-3). In this appendix, the alternate toughness criteria for thermally aged cast stainless steel developed in reference 4-6 will be used to categorize the various individual cast piping components thus establishing criteria based upon which the leak-before-break evaluations may be performed. Reference 4-6 has been reviewed by the NRC wherein the NRC concluded that reference 4-6 may be utilized for establishing the fracture criteria for thermally aged cast stainless piping applicable for the leak-before-break analyses (reference B-1).

#### B.2 Chemistry and KCU Toughness

Per the procedure of reference 4-6 the correlations of reference 4-4 which are based on the chemistry of the cast stainless steel piping was used to calculate the associated KCU values. The chemistry and end-of-service life KCU toughness values are given in table B-1 for Unit 1 and in table B-2 for Unit 2.

#### B.3 Alternate Toughness Criteria for the Farley Primary Loop Material on a Component by Component Basis

The alternate toughness criteria for the Farley Unit 1 and 2 cast primary loop material may be obtained by applying the methodology of reference 4-6 to the KCU values of tables B-1 and B-2. First, it is observed that 44 of the 50 heats fall into category 1, i.e., they are at least as tough as [ ]<sup>a,c,e</sup>. The remaining heats fall into category 2. Typical toughness calculations using the methodology of reference 4-6 are given below for a category 2 heat.

For example, [ ]<sup>a,c,e</sup> (the reducing elbow at the steam generator inlet nozzle of Farley Unit 1) has the calculated end-of-service life KCU at room temperature of [ ]<sup>a,c,e</sup> daJ/cm<sup>2</sup> which falls below that of [ ]<sup>a,c,e</sup>. The  $\delta$ -ferrite content is [ ]<sup>a,c,e</sup>. By reference 4-6, the [

],<sup>a,c,e</sup> Since the end-of-service life KCU exceeds the fully aged KCU, the heat falls into category 2. Thus:

$$J_{Ic} = [ ]^{a,c,e}$$

$$T_{mat} = [ ]^{a,c,e}$$

and

$$J_{max} = [ ]^{a,c,e}$$

The fracture toughness values for each heat of material was calculated as formulated in references 4-6. These values are also given in tables B-1 and B-2.

#### B.4 References

B-1 Letter: Dominic C., DiIanni, NRC to D. M. Musolf, Northern States Power Company, dated December 22, 1986, Docket Nos. 50-282 and 50-306.



TABLE B-1  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 1

a.c.e

TABLE B-1 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 1

a, c, e




TABLE B-1 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 1

a,c,e

TABLE B-1 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 1

a.c.e

TABLE B-1 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 1

a, c, e

TABLE B-1 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 1

a, c, e





TABLE B-1 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 1

a, c, e

TABLE B-1 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 1

a, c, e





a,c,e

TABLE B-2  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 2

a, c, e

TABLE B-2 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 2

a, c, e

TABLE B-2 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 2

a, c, e

TABLE B-2 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 2

a, c, e

TABLE B-2 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 2

a, c, e

TABLE B-2 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 2

a,c,e


TABLE B-2 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 2

a.c.e



TABLE B-2 (Cont'd)  
CHEMISTRY AND FRACTURE TOUGHNESS PROPERTIES  
OF THE MATERIAL HEATS OF FARLEY UNIT 2

a, c, e



a.c.e