

February 20, 1991

Donald F. Schnell  
Senior Vice President  
Nuclear

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

ULNRC- 2368

Gentlemen:

DOCKET NUMBER 50-483  
CALLAWAY PLANT  
AMENDMENT NUMBER 57


- References: 1. ULNRC-2196 dated 4-12-90  
2. ULNRC-2244 dated 7-9-90  
3. OL Amendment No. 57 and NRC SER  
dated 9-20-90

Amendment Number 57 to the Callaway Facility Operating License No. NPP-30 approved Technical Specification changes to allow the replacement of the resistance temperature detector (RTD) bypass system with an RTD/thermowell system mounted directly into the hot and cold legs of the reactor coolant system (RCS). Reference 1 submitted the original amendment application. Reference 2 supplemented the setpoint calculations of Reference 1 with an updated RCS flow measurement uncertainty calculation. Reference 2 also committed to compare post-modification calorimetric data against the most recent pre-modification calorimetric data to assess the effects of RTD bypass elimination on T-Hot at Callaway.

The requested information is attached. With regard to the other commitments discussed in the Reference 3 SER, both the active and spare elements of the new dual element Weed RTDs were response time tested using the Loop Current Step Response (LCSR) methodology after the RTDs were installed and one newly calibrated RTD will be installed at Refuel 6 (in the fall of 1993), and alternating refuelings thereafter, to ensure that RTD drift remains random in nature (i.e., not in the same direction).

If you have any questions on the attachment, please contact us.

Very truly yours,

  
Donald F. Schnell

GYJ/dls  
Attachment

1/1  
A001

, cc: T. A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Dr. J. O. Cermak  
CFA, Inc.  
4 Professional Drive (Suite 110)  
Gaithersburg, MD 20879

R. C. Knop  
Chief, Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Bruce Bartlett  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
RR#1  
Steedman, Missouri 65077

M. D. Lynch (2)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop 13E21  
11555 Rockville Pike  
Rockville, MD 20852

Manager, Electric Department  
Missouri Public Service Commission  
P.O. Box 360  
Jefferson City, MO 65102

COMPARISON OF RCS TEMPERATURE INDICATION  
PRE & POST RTD BYPASS LOOP ELIMINATION

6-16-89 Pre-modification (taken at 99.8% power)

	LOOP 1	LOOP 2	LOOP 3	LOOP 4
T-Hot	617.2°F	617.5°F	615.9°F	616.3°F
T-Cold	558.4°F	558.1°F	558.6°F	557.6°F

Average T-Hot = 616.7°F

Average T-Cold = 558.2°F

1-22-91 Post-modification (taken at 99.6% power)

	LOOP 1	LOOP 2	LOOP 3	LOOP 4
T-Hot	618.5°F	616.0°F	618.1°F	616.7°F
T-Cold	558.7°F	557.9°F	558.9°F	557.6°F

Average T-Hot = 617.3°F

Average T-Cold = 558.3°F

During the meeting held at NRC offices on July 20, 1990 to discuss RTD Bypass Elimination, slides were presented depicting the effect on T-Hot of the RTD Bypass Elimination at Salem Units 1 and 2. The change in T-Hot was -0.12°F and +0.48°F for Units 1 and 2, respectively. The former was stated by PSE&G and ABB/CE to be well within the accuracy of the data. The latter was stated by PSE&G and ABB/CE to be within the accuracy of the calorimetric. Similar conclusions can be drawn for Callaway as were drawn for Salem Unit 2.