



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

November 10, 1982

Mr. R.C. Haynes  
Director, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 82-036/01T-0  
ER 100450 FILE 841-23  
PLA- 1392

Docket No. 50-387  
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-036/01T-0. This event was determined to be reportable per Technical Specification 6.9.1.8.e, in that both High Pressure Coolant Injection steam line sensors which detect a break were found above the allowable value.

H.W. Keiser  
Superintendent of Plant-Susquehanna

DGM/cw

Attachment

cc: A. Schwencer  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

8211290293 821110  
PDR ADDCK 05000387  
S PDR

IE-22