

Unit 2

LICENSEE EVENT REPORT

Report No. 82-036/01T

CONTROL BLOCK: ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	P	A	P	B	S	2	2	0	0	-	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4		5
7	8	LICENSEE CODE 14						LICENSE NUMBER 25									LICENSE TYPE 30					CAT 58 57						

0	1	L	6	0	5	0	-	0	2	7	7	7	7	1	0	2	4	8	2	8	1	1	0	5	8	2	9
7	8	REPORT SOURCE 60				DOCKET NUMBER 68								EVENT DATE 74				REPORT DATE 80									

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

② During plant start-up, with primary coolant pressure at 832 psig, the 71J relief valve opened. Reactor power at the time was approximately 1%. During this transient, the torus volume increased <1% above the maximum Technical Specification limit of 127,300 cubic feet. During the transient, all ECCS systems operated properly. No release of activity occurred during this event.

0	9	C	C	11	E	12	B	13	V	A	L	V	E	X	14	P	15	B	16
7	8	SYSTEM CODE 9		9	CAUSE CODE 11		CAUSE SUBCODE 12		COMPONENT CODE 13					COMP. SUBCODE 19		VALVE SUBCODE 20			
17	LER/RO REPORT NUMBER 21		EVENT YEAR 22		23	SEQUENTIAL REPORT NO. 24				27	OCCURRENCE CODE 28		29	REPORT TYPE 30		31	REVISION NO. 32		
18	19	20	21	HOURS 22				23	ATTACHMENT SUBMITTED 41		24	PRIME COMP. SUPPLIER 43		COMPNENT MANUFACTURER 44		26	47		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ⑳

⑩ The relief valve, model 6" F, manufactured by Targetrock, will be sent to a vendor to determine cause of this spurious opening. The 71J relief valve was replaced. The torus was pumped down to normal volume. An inspection of the downstream piping was conducted and no discrepancies were identified.

1	5	C	0	0	1	29	NA	30	A	31	Operator Observation ⑳					
7	8	FACILITY STATUS 8		% POWER 10			OTHER STATUS 13		METHOD OF DISCOVERY 45		DISCOVERY DESCRIPTION 46					

1	6	Z	33	Z	34	NA				NA					
7	8	RELEASED OF RELEASE 10				AMOUNT OF ACTIVITY 35				LOCATION OF RELEASE 36					

1	7	0	0	0	Z	38	NA			
7	8	PERSONNEL EXPOSURES NUMBER 9				11	DESCRIPTION 39			

1	8	0	0	0		40	NA			
7	8	PERSONNEL INJURIES NUMBER 11				DESCRIPTION 41				

1	9	Z	42	NA				8211290303	821108	PDR	ADOCK	05000277	PDR	
7	8	LOSS OF OR DAMAGE TO FACILITY TYPE 10										DESCRIPTION 43		

2	0	Y	44	Report Shutdown: 10/27/82, Report Start: <u> </u>														
7	8	PUBLICITY ISSUED DESCRIPTION 45																

NAME OF PREPARER: M. J. Cooney
PHONE: (215) 841-5020