



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

ENERGY OPERATIONS, INC.

DOCKET NO. 50-368

ARKANSAS NUCLEAR ONE, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 113  
License No. NPF-6

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Energy Operations, Inc. (the licensee) dated October 17, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-6 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 113, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas P. Gwynn, Acting Director  
Project Directorate IV-1  
Division of Reactor Projects III, IV, and V  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: January 29, 1991

ATTACHMENT TO LICENSE AMENDMENT NO.113

FACILITY OPERATING LICENSE NO. NPF-6

DOCKET NO. 50-368

Revise the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE PAGE

3/4 7-22

INSERT PAGE

3/4 7-22

This page intentionally left blank.

## PLANT SYSTEMS

### 3/4.7.8 HYDRAULIC SHOCK SUPPRESSORS (SNUBBERS)

#### LIMITING CONDITION FOR OPERATION

---

3.7.8 All snubbers shall be OPERABLE. The only snubbers excluded from this requirement are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed, would have no adverse effect on any safety-related system.

APPLICABILITY: MODES 1, 2, 3 and 4. MODES 5 and 6 for snubbers located on systems required OPERABLE in those MODES.

ACTION: With one or more applicable snubbers inoperable, within 72 hours replace or restore the inoperable snubber(s) to OPERABLE status and perform an engineering evaluation per Specification 4.7.8.f on the attached component, or declare the attached system inoperable and follow the appropriate ACTION statement for that system.

#### SURVEILLANCE REQUIREMENTS

---

4.7.8 Each applicable snubber shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program and the requirements of Specification 4.0.5.

a. Inspection Types

As used in this specification, type of snubber shall mean snubbers of the same design and manufacturer, irrespective of capacity.

Snubbers are categorized as inaccessible or accessible during reactor operation.

b. Visual Inspections

Visual inspections shall be performed in accordance with the following schedule:

<u>No. Inoperable Snubbers per Inspection Period</u>	<u>Subsequent Visual Inspection Period</u>
0	18 months $\pm$ 25%
1	12 month $\pm$ 25%*
2	6 months $\pm$ 25%
3, 4	124 days $\pm$ 25%
5, 6, 7	62 days $\pm$ 25%
8 or more	31 days $\pm$ 25%

The snubbers may be categorized into groups based on type and accessibility. Each group may be inspected independently in accordance with the above schedule.

\*For inaccessible snubbers, the inspection due November 7, 1990 (12 month  $\pm$ 25% from November 7, 1989) may be extended thru the 1991 refueling outage, in no case later than May 7, 1991.