

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A | L | J | M | F | I | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T
0 1 | REPORT SOURCE | 1 | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 4 | 8 | 7 | 1 | 0 | 2 | 5 | 8 | 2 | 3 | 1 | 1 | 2 | 2 | 8 | 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0830 on 10/25/82 during the performance of FNP-1-STP-109.0 (Power Range Neutron
0 3 | Flux Channel Calibration), the overtemperature-delta temperature instrumentation loop
0 4 | associated with TI 432A was declared inoperable due to its reading being out of toler-
0 5 | ance with the other channels. Tech. Spec. 3.3.1, in part, requires TI 432A to be
0 6 | operable. Tech. Spec. 3.3.1 action statement requirements were met. Health/safety of
0 7 | the public was not affected.

0 9 | SYSTEM CODE | I | A | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | X | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | I | 15 | VALVE SUBCODE | Z | 16

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was due to dirty contacts on printed circuit card C3-125. The contacts were
1 1 | cleaned and TI 432A was declared operable at 1414 on 10/25/82.

1 5 | FACILITY STATUS | F | 22 | % POWER | 0 | 4 | 7 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Surveillance Test | 32

1 6 | ACTIVITY CONTENT | Z | 33 | RELEASED OF RELEASE | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36

1 7 | PERSONNEL EXPOSURES | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39

1 8 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41

1 9 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | DESCRIPTION | N/A | 43

2 0 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | N/A | 45 | 8211290518 821122 PDR ADOCK 05000348 S PDR | NRC USE ONLY