

NOV 02 1982

Docket No. 99900783/82-01

Taylor Forge
Gulf & Western Manufacturing Company
ATTN: Mr. J. A. Sider
Plant Manager
4735 West 14th Street
Cicero, Illinois 60650

Gentlemen:

This refers to the inspection conducted by Mr. J. T. Conway of this office on August 16-20, 1982, of your facility at Cicero, Illinois, associated with the manufacture of nuclear flanges and to the discussions of our findings with Mr. E. J. Razim at the conclusion of the inspection.

This inspection was made as a result of the 10 CFR Part 50.55(e) notification reported by Pennsylvania Power & Light Company relating to inadequate thickness of main steam relief valve discharge line flanges furnished to the Susquehanna Steam Electric Station.

Areas examined and our findings are discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector.

During the inspection it was found that the implementation of your QA program failed to meet certain NRC requirements. The specific findings and references to the pertinent requirements are identified in the enclosures to this letter.

Please provide us within 30 days from the date of this letter a written statement containing: (1) a description of steps that have been or will be taken to correct these items; (2) a description of steps that have been or will be taken to prevent recurrence; and (3) the date your corrective actions and preventive measures were or will be completed. Consideration may be given to extending your response time for a good cause shown.

The response requested by this letter is not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

RIV
CI: R&CPS
JTC Conway/rf
10/13/82

SC: R&CPS
IBarnes
10/5/82

BC: VPB
UPotapovs
10/5/82

AD: V&TP
RLB angart
10/14/82

D: ES
EHJohnson
10/1/82

RA: RIV
JTCollins
10/19/82

8211290519 821102
PDR GA999 EMVGULW
99900783 FDR

1021

Red mark
10/19

P/1/1/82
Jan

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within 10 days from the date of this letter of your intention to file a request for withholding; and (b) submit within 25 days from the date of this letter a written application to this office to withhold such information. If your receipt of this letter has been delayed such that less than 7 days are available for your review, please notify this office promptly so that a new due date may be established. Consistent with Section 2.790(b)(1), any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons on the basis which it is claimed that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 10 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, the report will be placed in the Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Uldis Potapovs, Chief
Vendor Program Branch

Enclosure:

1. Appendix A - Notice of Nonconformance
2. Appendix B - Inspection Report No. 99900783/82-01
3. Appendix C - Inspection Data Sheets (3 Pages)

bcc:

IE Files

AEOD

NRC:PDR

OAB

Reg. Administrators, I, II, III, IV, V

EHJohnson, RIV

RLBangart, RIV

ASME

NBB&PVI