

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | S | G | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 4 | 1 | 6 | 7 | 1 | 0 | 2 | 4 | 8 | 2 | 8 | 1 | 1 | 2 | 3 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE TICKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | During shutdown on October 24, 1982, fire door 1A307 in the Control Building,
0 3 | separating the North passageway and the Division II Switchgear room, would not latch.
0 4 | This door is required to be closed and latched at all times. In accordance with
0 5 | Technical Specification 3.7.7.a, an LCO was entered, and an hourly fire watch was
0 6 | established. There was no effect on the health and safety of the public. This
0 7 | event did not constitute a threat to plant safety.

0 9 | A | B | 11 | X | 12 | Z | 13 | X | X | X | X | X | X | 14 | Z | 15 | Z | 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

17 | 8 | 2 | 21 | 22 | 1 | 1 | 6 | 23 | 24 | 0 | 3 | 25 | L | 26 | 0 | 27
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
0 18 | E | 19 | Z | 19 | 20 | Z | 21 | 22 | 0 | 0 | 0 | 0 | 23 | N | 24 | N | 25 | Z | 26 | Z | 9 | 9 | 9 | 26
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The locking mechanism for the door would not engage properly. Maintenance adjusted
1 1 | the locking mechanism, and the door engaged properly. Work was completed, and the
1 2 | LCO was lifted on October 24, 1982. All corrective action is considered complete.
1 3 | This is being submitted as a final report.

1 5 | G | 28 | 0 | 0 | 0 | 29 | NA | 30 | Z | 31 | Security Personnel | 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | 42 | NA | 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N | 44 | 8211290556 821123 | PDR ADOCK 05000416 | S | PDR | NRC USE ONLY
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
ISSUED DESCRIPTION

NAME OF PREPARER Original signed by John M. Albert

PHONE _____