



REPROCESSED ORIGINAL
Certified By MAP

Public Service Electric and Gas Company P.O. Box E Hancocks Bridge, New Jersey 03038

Salem Generating Station

November 15, 1982

Mr. R. C. Haynes
Regional Administrator
USNRC
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Haynes:

REPORTABLE OCCURRENCE 82-085/01P
SALEM NO. 1 UNIT LER

This letter is to confirm our verbal report to the NRC Headquarters on Sunday, November 14, 1982, advising of a potential reportable occurrence in accordance with the Technical Specifications, Section 3.7.10.1.

Due to planned maintenance on No. 12 Station Power Transformer, the automatic starting feature on both Nos. 1 and 2 Diesel Fire Pumps was disabled. Both pumps were operable in the manual mode of operation; an operator was stationed at the pumps to start them manually if required.

No. 12 Station Power Transformer was returned to service on November 14, and the automatic starting feature was regained. A detailed report will be submitted in the time period specified by the Technical Specifications.

Sincerely yours,

H. J. Midura
General Manager -
Salem Operations

RF:ks

CC: Distribution

8211290557 821115
PDR ADOCK 05000272
S PDR

TEL9