



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GPU NUCLEAR CORPORATION

AND

JERSEY CENTRAL POWER & LIGHT COMPANY

DOCKET NO. 50-219

OYSTER CREEK NUCLEAR GENERATING STATION

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 147
License No. DPR-16

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by GPU Nuclear Corporation, et al., (the licensee), dated May 7, 1990, as supplemented September 14, 1990 and December 13, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9102270242 910220
PDR ADDCK 05000219
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Provisional Operating License No. DPR-16 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 147, are hereby incorporated in the license. GPU Nuclear Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

for Alexander W. Diemerick
John F. Stolz, Director
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 20, 1991

TABLE OF CONTENTS

Section 1	Definitions	Page
1.1	Operable - Operability	1.0-1
1.2	Operating	1.0-1
1.3	Power Operation	1.0-1
1.4	Startup Mode	1.0-1
1.5	Run Mode	1.0-1
1.6	Shutdown Condition	1.0-1
1.7	Cold Shutdown	1.0-2
1.8	Place in Shutdown Condition	1.0-2
1.9	Place in Cold Shutdown Condition	1.0-2
1.10	Place in Isolated Condition	1.0-2
1.11	Refuel Mode	1.0-2
1.12	Refueling Outage	1.0-2
1.13	Primary Containment Integrity	1.0-2
1.14	Secondary Containment Integrity	1.0-3
1.15	Deleted	1.0-3
1.16	Rated Flux	1.0-3
1.17	Reactor Thermal Power-To-Water	1.0-3
1.18	Protective Instrumentation Logic Definitions	1.0-3
1.19	Instrumentation Surveillance Definitions	1.0-4
1.20	FDSAR	1.0-4
1.21	Core Alteration	1.0-4
1.22	Minimum Critical Power Ratio	1.0-4
1.23	Staggered Test Basis	1.0-4
1.24	Surveillance Requirements	1.0-5
1.25	Fire Suppression Water System	1.0-5
1.26	Fraction of Limiting Power Density (FLPD)	1.0-5
1.27	Maximum Fraction of Limiting Power Density (MFLPD)	1.0-5
1.28	Fraction of Rated Power (FRP)	1.0-6
1.29	Top of Active Fuel (TAF)	1.0-6
1.30	Reportable Event	1.0-6
1.31	Identified Leakage	1.0-6
1.32	Unidentified Leakage	1.0-6
1.33	Process Control Plan	1.0-6
1.34	Augmented Offgas System (AOG)	1.0-6
1.35	Member of the Public	1.0-6
1.36	Offsite Dose Calculation Manual	1.0-6
1.37	Purge	1.0-7
1.38	Exclusion Area	1.0-7
1.39	Reactor Vessel Pressure Testing	1.0-7
1.40	Substantive Changes	1.0-7
1.41	Dose Equivalent I-131	1.0-7
1.42	Average Planar Linear Heat Generation Rate	1.0-7
1.43	Core Operating Limits Report	1.0-8
1.44	Local Linear Heat Generation Rate	1.0-8
Section 2	Safety Limits and Limiting Safety System Settings	Page
2.1	Safety Limit - Fuel Cladding Integrity	2.1-1
2.2	Safety Limit - Reactor Coolant System Pressure	2.2-1
2.3	Limiting Safety System Settings	2.3-1

1.19 INSTRUMENTATION SURVEILLANCE DEFINITIONS

A. Channel Check

A qualitative determination of acceptable operability by observation of channel behavior during operation. This determination shall include, where possible, comparison of the channel with other independent channels measuring the same variable.

B. Channel Test

Injection of a simulated signal into the channel to verify its proper response including, where applicable, alarm and/or trip initiating action.

C. Channel Calibration

Adjustment of channel output such that it responds, with acceptable range and accuracy, to known values of the parameter which the channel measures. Calibration shall encompass the entire channel, including equipment actuation, alarm or trip.

D. Source Check

A SOURCE CHECK is the qualitative assessment of channel response when the channel sensor is exposed to a source of radioactivity.

1.20 FDSAR

Oyster Creek Unit No. 1 Facility Description and Safety Analysis Report as amended by revised pages and figure changes contained in Amendments 14, 31 and 45.*

1.21 CORE ALTERATION

A core alteration is the addition, removal, relocation or other manual movement of fuel or controls in the reactor core. Control rod movement with the control rod drive hydraulic system is not defined as a core alteration.

1.22 CRITICAL POWER RATIO

The critical power ratio is the ratio of that power in a fuel assembly which is calculated, by application of an NRC approved CPR correlation, to cause some point in that assembly to experience boiling transition divided by the actual assembly operating power.

1.23 STAGGERED TEST BASIS

A Staggered Test Basis shall consist of:

- A. A test schedule for n systems, subsystems, trains or other designated components obtained by dividing the specified test interval into n equal subintervals.

*Per Errata dtd. 4-9-69
OYSTER CREEK

1.37 PURGE

PURGE OR PURGING is the controlled process of discharging air or gas from a confinement and replacing it with air or gas.

1.38 EXCLUSION AREA

EXCLUSION AREA is defined in 10 CFR part 100.3(2). As used in these technical specification, the Exclusion Area boundary is the perimeter line around the OCNCS beyond which the land is neither owned, leased, nor otherwise subject to control by GPU (ref. ODCM Figure 1-1). The area outside the Exclusion Area is termed OFFSITE.

1.39 REACTOR VESSEL PRESSURE TESTING

System pressure testing required by ASME Code Section XI, Article IWA-5000, including system leakage and hydrostatic test, with reactor vessel completely water solid, core not critical and section 3.2.A satisfied.

1.40 SUBSTANTIVE CHANGES

SUBSTANTIVE CHANGES are those which affect the activities associated with a document or the document's meaning or intent. Examples of non-substantive changes are: (1) correcting spelling, (2) adding (but not deleting) sign-off spaces, (3) blocking in notes, cautions, etc., (4) changes in corporate and personnel titles which do not reassign responsibilities and which are not referenced in the Appendix A Technical Specifications, and (5) changes in nomenclature or editorial changes which clearly do not change function, meaning or intent.

1.41 DOSE EQUIVALENT I-131

DOSE EQUIVALENT I-131 shall be that concentration of I-131 microcuries per gram which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in Table E-7 or Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluences for the Purpose of Evaluating Compliance with 10 CFR Part 40 Appendix I".

1.42 AVERAGE PLANAR LINEAR HEAT GENERATION RATE

The AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR) shall be applicable to a specific planar height and is equal to the sum of the heat generation rate per unit length of fuel rod for all the fuel rods in the specified bundle at the specified height divided by the number of fuel rods in the fuel bundle at that height.

1.43 CORE OPERATING LIMITS REPORT

The Oyster Creek CORE OPERATING LIMITS REPORT (COLR) is the document that provides core operating limits for the current operating reload cycle. These cycle-specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.9.1.f. Plant operation within these operating limits is addressed in individual specifications.

1.44 LOCAL LINEAR HEAT GENERATION RATE

The LOCAL LINEAR HEAT GENERATION RATE (LLHGR) shall be applicable to a specific planar height and is equal to the AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR) at the specified height multiplied by the local peaking factor at that height.

3.10 CORE LIMITS

Applicability: Applies to core conditions required to meet the Final Acceptance Criteria for Emergency Core Cooling Performance.

Objective: To assure conformance to the peak clad temperature limitations during a postulated loss-of-coolant accident as specified in 10 CFR 50.46 (January 4, 1974) and to assure conformance to the operating limits for local linear heat generation rate and minimum critical power ratio.

Specification:

A. Average Planar LHGR

During power operation the maximum AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR) for each fuel type as a function of exposure shall not exceed the limits specified in the CORE OPERATING LIMITS REPORT (COLR).

If at any time during power operation it is determined by normal surveillance that the limiting value for APLHGR is being exceeded, action shall be initiated to restore operation to within the prescribed limits. If the APLHGR is not returned to within the prescribed limits within two (2) hours, action shall be initiated to bring the reactor to the cold shutdown condition within 36 hours. During this period surveillance and corresponding action shall continue until reactor operation is within the prescribed limits at which time power operation may be continued.

B. Local LHGR

During power operation, the Local LINEAR HEAT GENERATION RATE (LHGR) of any rod in any fuel assembly, at any axial location shall not exceed the maximum allowable LHGR limits specified in the COLR.

If at any time during operation it is determined by normal surveillance that the limiting value of LHGR is being exceeded, action shall be initiated to restore operation to within the prescribed limits. If the LHGR is not returned to within the prescribed limits within two (2) hours, action shall be initiated to bring the reactor to the cold shutdown condition within 36 hours. During this period, surveillance and corresponding action shall continue until reactor operation is within the prescribed limits at which time power operation may be continued.

C. Minimum Critical Power Ratio (MCPR)

During steady state power operation the MINIMUM CRITICAL POWER RATIO (MCPR) shall be equal to or greater than the MCPR limit as specified in the COLR.

When APRM status changes due to instrument failure (APRM or LPRM input failure), the MCPR requirement for the degraded condition shall be met within a time interval of eight (8) hours, provided that the control rod block is placed in operation during this interval.

For core flows other than rated, the nominal value for MCPR shall be increased by a factor of k_f , where k_f is specified in the COLR.

If at any time during power operation it is determined by normal surveillance that the limiting value for MCPR is being exceeded for reasons other than instrument failure, action shall be initiated to restore operation to within the prescribed limits. If the steady state MCPR is not returned to within the prescribed limits within two (2) hours, action shall be initiated to bring the reactor to the cold shutdown condition within 36 hours. During this period, surveillance and corresponding action shall continue until reactor operation is within the prescribed limit at which time power operation may be continued.

Bases:

The Specification for average planar LHGR assures that the peak cladding temperature following the postulated design basis loss-of-coolant accident will not exceed the 2200°F limit specified in 10 CFR 50.46. The analytical methods and assumptions used in evaluating the fuel design limits are presented in FSAR Chapter 4.

LOCA analyses are performed for each fuel design at selected exposure points to determined APLHGR limits that meet the PCT and maximum oxidation limits of 10 CFR 50.46. The analysis is performed using GE calculational models which are consistent with the requirements of 10 CFR 50, Appendix K.

The PCT following a postulated LOCA is primarily a function of the average heat generation rate of all the rods of a fuel assembly at any axial location and is not strongly influenced by the rod to rod power distribution within an assembly. Since expected location variations in power distribution within a fuel assembly affect the calculated peak clad temperature by less than $\pm 20^\circ\text{F}$ relative to the peak temperature for a typical fuel design, the limit on

the average linear heat generation rate is sufficient to assure that calculated temperatures are below the limits specified in 10 CFR 50.46.

The maximum average planar LHGR limits for the various fuel types currently being used are specified in the COLR. The MAPLHGR limits for both five-loop and four-loop operation with the idle loop unisolated are shown. Four-loop operation with the idle loop isolated (suction, discharge and discharge bypass valves closed) requires that a MAPLHGR multiplier of 0.98 be applied to all fuel types. Additional requirements for isolated loop operation are given in Specification 3.3.F.2.

Fuel design evaluations are performed to demonstrate that the cladding Δ plastic strain and other fuel design limits are not exceeded during anticipated operational occurrences for operation with LHGRs up to the operating limit LHGR.

The analytical methods and assumptions used in evaluating the anticipated operational occurrences to establish the operating limit MCPR are presented in the FSAR, Chapters 4, 6 and 15 and in Technical Specification 6.9.1.f. To assure that the Safety Limit MCPR is not exceeded during any moderate frequency transient event, limiting transients have been analyzed to determine the largest reduction in Critical Power Ratio (CPR). The types of transients evaluated are pressurization, positive reactivity insertion and coolant temperature decrease. The operational MCPR limit is selected to provide margin to accommodate transients and uncertainties in monitoring the core operating state, manufacturing, and in the critical power correlation itself. This limit is derived by addition of the CPR for the most limiting transient to the safety limit MCPR designated in Specification 2.1.

The APRM response is used to predict when the rod block occurs in the analysis of the rod withdrawal error transient. The transient rod position at the rod block and corresponding MCPR can be determined. The MCPR has been evaluated for different APRM responses which would result from changes in the APRM status as a consequence of bypassed APRM channel and/or failed/bypassed LPRM inputs. The steady state MCPR required to protect the minimum transient CPR for the worst case APRM status condition (APRM Status 1) is determined in the rod withdrawal error transient analysis. The steady state MCPR values for APRM status conditions 1, 2, and 3 will be evaluated each cycle. For those cycles where the rod withdrawal error transient is not the most severe transient the MCPR Value for APRM status conditions 1, 2, and 3 will be the same and be equal to the limiting transient MCPR value.

The time interval of Eight (8) hours to adjust the steady state of MCPR to account for a degradation in the APRM status is justified on the basis of instituting a control rod block which precludes the possibility of experiencing a rod withdrawal error transient since rod withdrawal is physically prevented. This time interval is adequate to allow the operator to either increase the MCPR to the appropriate value or to upgrade the status of the APRM system while in a condition which prevents the possibility of this transient occurring.

Transients analyzed each fuel cycle will be evaluated with respect to the operational MCPR limit specified in the COLR.

The purpose of the k_f factor is to define operating limits at other than rated flow conditions. At less than 100% flow the required MCPR is the product of the operating limit MCPR and the k_f factor. Specifically, the k_f factor provides the required thermal margin to protect against a flow increase transient.

The k_f factor curves, as shown in the COLR, were developed generically using the flow control line corresponding to rated thermal power at rated core flow. For the manual flow control mode, the k_f factors were calculated such that at the maximum flow state (as limited by the pump scoop tube set point) and the corresponding core power (along the rated flow control line), the limiting bundle's relative power was adjusted until the MCPR was slightly above the Safety Limit. Using this relative bundle power, the MCPR's were calculated at different points along the rated flow control line corresponding to different core flows. The ratio of the MCPR calculated at a given point of core flow, divided by the operating limit MCPR determines the value of k_f .

- (4) a summary of meteorological data collected during the year shall be included in the report submitted within 60 days after January 1 of each year. Alternatively, summary meteorological data may be retained by GPU Nuclear and made available to the NRC upon request.
- e. Annual Radiological Environmental Report: A report of radiological environmental surveillance activities during each year shall be submitted before May 1 of the following year. Each report shall include the following information required in Specification 4.16 for radiological environmental surveillance:
- (1) a summary description of the radiological environmental monitoring program,
 - (2) a map and a table of distances and directions (compass azimuth) of locations of sampling stations from the reactor,
 - (3) results of analyses of samples and of radiation measurements, (In the event some results are not available, the reasons shall be explained in the report. In the event the missing results are obtained, they shall be reported to the NRC as soon as is reasonable.)
 - (4) deviation(s) from the environmental sampling schedule in Table 4.16.1.
 - (5) identification of environmental samples analyzed when instrumentation was not capable of meeting detection capability in Table 4.16.2.
 - (6) a summary of the results of the land use survey.
 - (7) a summary of the results of licensee participation in an NRC approved inter-laboratory crosscheck program for environmental samples.
 - (8) results of dose evaluations to demonstrate compliance with 40 CFR Part 190.10a.
- f. CORE OPERATING LIMITS REPORT (COLR)
1. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle for the following:
 - a. The AVERAGE PLANNED LINEAR HEAT GENERATION RATE (APLHGR) for Specification 3.10.A
 - b. The K_f core flow adjustment factor for Specification 3.10.C.
 - c. The MINIMUM CRITICAL POWER RATIO (MCPR) for Specification 3.10.C

d. The LOCAL LINEAR HEAT GENERATION RATE (LLHGR) for Specification 3.10.B.

and shall be documented in the COLR.

2. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents.
 - a. GPUN Nuclear (GPUN) Topical Report (TR) 020, Methods for the Analysis of Boiling Water Reactors Lattice Physics, (The approved revision at the time reload analyses are performed shall be identified in the COLR.)
 - b. GPUN TR 021, Methods for the Analysis of Boiling Water Reactors Steady State Physics, (The approved revision at the time reload analyses are performed shall be identified in the COLR.)
 - c. GPUN TR 033, Methods for the Generation of Core Kinetics Data for RETRAN-02, (The approved revision at the time reload analyses are performed shall be identified in the COLR.)
 - d. GPUN TR 040, Steady-State and Quasi-Steady-State Methods Used in the Analysis of Accidents and Transients, (The approved revision at the time reload analyses are performed shall be identified in the COLR.)
 - e. GPUN TR 045, BWR-2 Transient Analysis Model Using the Retran Code, (The approved revision at the time reload analyses are performed shall be identified in the COLR.)
 - f. NEDE-31462P and NEDE-31462, Oyster Creek Nuclear Generating Station SAFER/CORECOOL/GESTR-LOCA Loss-of-Coolant Accident Analysis, (The approved revision at the time reload analyses are performed shall be identified in the COLR.)
 - g. NEDE-24011, General Electric Standard Application for Reactor Fuel, (The approved revision at the time reload analyses are performed shall be identified in the COLR.)
 - h. NEDE-24195, General Electric Reload Fuel Application for Oyster Creek, (The approved revision at the time reload analyses are performed shall be identified in the COLR.)
 - i. XN-75-55-(A); XN-75-55, Supplement 1-(A); XN-75-55, Supplement 2-(A), Revision 2, "Exxon Nuclear Company WREM-Based NJP-BWR ECCS Evaluation Model and Application to the Oyster Creek Plant," April 1977

j. XN-75-36(NP)-(A); XN-75-36(NP), Supplement 1-(A), "Spray Cooling Heat Transfer Phase Test Results, ENC - 8x8 BWR Fuel 60 and 63 Active Rods, Interim Report," October 1975

3. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, transient analysis limits, and accident analysis limits) of the safety analysis are met.
4. The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements shall be provided, upon issuance for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

Basis: 6.9.1.e

An annual report of radiological environmental surveillance activities includes factual data summarizing results of activities required by the surveillance program. In order to aid interpretation of the data, GPUN may choose to submit analysis of trends and comparative non regional radiological environmental data. In addition, the licensee may choose to discuss previous radiological environmental data as well as the observed radiological environmental impacts of station operation (if any) on the environment.

6.9.2 REPORTABLE EVENTS

The submittal of Licensee Event Reports shall be accomplished in accordance with the requirements set forth in 10 CFR 50.73.