



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

October 29, 1982
4410-82-L-0039

Office of Inspection and Enforcement
Attn: Mr. Ronald C. Haynes, Director
Region I
US Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

DESIGNATED ORIGINAL

Certified By *J. J. Martin*

Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Investigation Report 50-320/79-10

This letter is submitted to fulfill a commitment relative to procedure review in Item 1 of Inspection Report 50-320/79-10. Specifically, GPU committed that in the periodic review of procedures that applicable procedures will be reviewed to assure that redundant safety trains will be verified operable prior to removing one train from service and that the one removed from service will be verified operable after the reason for its removal from service is completed. This review has been completed as committed. A listing of procedures reviewed is attached for your convenience.

The reviews were integrated within the Periodic Procedure Review (PPR) program required by Technical Specification 6.8.2. The programmatic review was performed by evaluating each procedure against a set of 6 criteria, one of which corresponds to the above commitment (operability verification). The method of review and the applicable criteria the procedures were reviewed against are recorded and maintained in GPU's files. These files are available for NRC inspection. For each procedure for which a revision was determined necessary, a Procedure Change Request (PCR) was initiated to incorporate the necessary change(s). The revision(s) may have been initiated by any 1 or more of the 6 criteria. Many of the recently initiated PCR's are still being processed. Therefore, GPU will inform you by November 30, 1982, when corrective actions (i.e. PCR's) will be completed for all changes relevant to the operability verification criteria.

Sincerely,

B. K. Kanga

B. K. Kanga
Director, TMI-2

8211290607 821118
PDR ADOCK 05000320
g PDR

BKK/SDC/jep

Attachment

CC: Mr. L. H. Barrett, Deputy Program Director - TMI Program Office
Dr. B. J. Snyder, Program Director - TMI Program Office (w/o attachment)