NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | CASOS2 (2) | 00-00000-00 (3) | 41111 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T
01 | REPORT SOURCE L (6) | 05000361 (7) | 102182 (8) | 111782 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 3, the Condensate Storage Tank T-121 water level fell below the
03 Technical Specification 3.7.1.3 limit. There was no consequence to public health
04 and safety since there was no significant decay heat in the core, and also adequate
05 inventory was maintained in Tank T-120.
06
07
08

09 | SYSTEM CODE HH (11) | CAUSE CODE B (12) | CAUSE SUBCODE A (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR 82 | — | SEQUENTIAL REPORT NO. 130 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION F (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Inadequate makeup water control to Tank T-121 and a more restrictive than necessary
11 Technical Specification limit were the cause. Corrective actions include Technical
12 Specification change approved by NRC on October 26, 1982, improved level indication
to facilitate control, and a design change to install automatic level control systems
(expected to be installed prior to 100% power operation). See also LER's 82-044,
13 -049, -050, -051, -053, -057, -068, -071, -074, -079, -082, -095, -097, -102, -104,
14 -106, -108, -109, -110, -111, -112, -116, -117, -124 and -129.

15 | FACILITY STATUS B (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 | NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 | NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 | TYPE Z (42) | DESCRIPTION NA

PUBLICITY
20 | ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8211290653 821117
PDR ADOCK 05000361
S PDR

NAME OF PREPARER H. B. Ray PHONE 714/492-7700