

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C T H N P 1 | 0 0 - 0 0 0 0 0 0 - 0 0 0 | 4 1 1 1 1 | _____
7 8 9 14 15 25 26 30 57 CAT 58

CONT
0 1 | REPORT SOURCE | L | 0 5 0 - 0 2 1 3 | 1 0 1 5 8 2 | 1 1 0 9 8 2 |
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a watch tour, operator observed pinhole leak on pipe joint next to "B"
0 3 | charging pump recirculation throttle valve CH-V-275. In service charging train was
0 4 | shifted to the "A" unit for investigation and pipe joint repair. There was no
0 5 | hazard to the public as the small release of radioactive coolant was confined to the
0 6 | primary auxiliary building with closed, filtered ventilation.
0 7 |
0 8 |

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE |
7 8 9 10 11 12 13 18 19 20
C J | E | B | Z Z Z Z Z Z | Z | Z |
(11) (12) (13) (14) (15) (16)
17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO. |
7 8 21 22 23 24 26 27 28 29 30 31 32
8 2 | | 0 0 9 | / | 0 3 | L | | 0 |
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME CUMP. SUPPLIER | COMPONENT MANUFACTURER |
33 34 35 36 37 40 41 42 43 44 47
B | X | Z | Z | 0 0 0 0 | N | N | Z | Z 9 9 9 |
(18) (19) (20) (21) (22) (23) (24) (25) (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | With pipe joint isolated by valving out the "B" charging train, weld repair was
1 1 | completed. The charging train was tested and returned to service the same working
1 2 | day as the event. Engineering is reviewing the joint failure for possible indication
1 3 | that piping rearrangement would be appropriate for long term reliability.
1 4 |

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION |
7 8 9 10 12 13 44 45 46 80
E | 1 0 0 | N/A | A | Operator observation.

1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE |
7 8 9 10 11 44 45 80
Z | Z | N/A

1 7 | PERSONNEL EXPOSURES | DESCRIPTION |
7 8 9 11 12 13 80
0 0 0 | Z | N/A

1 8 | PERSONNEL INJURIES | DESCRIPTION |
7 8 9 11 12 80
0 0 0 | | N/A

1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION |
7 8 9 10 80
Z | | N/A

2 0 | PUBLICITY ISSUED | DESCRIPTION |
7 8 9 10 80
N | | N/A

8211290659 821109
PDR ADOCK 05000213
S PDR

NRC USE ONLY

NAME OF PREPARER: R. Z. Test

PHONE: (203) 267-2556