NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE (2)	N C B E P 1
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
CON'T 0 1	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 - 0 3 2 5
	EVENT DATE (8)	1 0 2 0 8 2
	REPORT DATE (9)	1 1 1 8 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During plant operation, while performing routine surveillance testing, it was dis-
0 3 covered that PCIV RHR process sample valve, 1-E11-F079A, would not fully close when
0 4 given a closure command. This event did not affect the health and safety of the
0 5 public.
0 6 Technical Specifications 3.6.3, 6.9.1.9b
0 7
0 8

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
S D	E	X	V A L V O P	E	Z

LER/RO REPORT NUMBER (17)	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 2	—	1 1 1	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
E	Z	Z	Z	0 0 0 0	N	Y	L	L 0 3 7

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 An unutilized limit switch actuator arm on the valve operator was found mispositioned
1 1 such that it interfered with the valve operator and prevented full closure of the
1 2 valve. The subject actuator arm was repositioned to allow full closure of the valve
1 3 and the valve, Model No. 611WA36, was satisfactorily tested for operation and returned
1 4 to service. No reason for the misplaced actuator arm could be determined.

	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
1 5	E	0 5 8	NA	A	Operational Event

	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z	Z	NA	NA

PERSONNEL EXPOSURES

	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
1 7	0 0 0	Z	NA

PERSONNEL INJURIES

	NUMBER (40)	DESCRIPTION (41)
1 8	0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE (42)	DESCRIPTION
1 9	Z	NA

PUBLICITY

	ISSUED (44)	DESCRIPTION	NRC USE ONLY
2 0	N	NA	

8211290726 821118
PDR ADOCK 05000325
S PDR

NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521

GPO 917-926