



Commonwealth Edison

Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-82-522

November 16, 1982

J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137


Reference: Quad-Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
Appendix A, Section 4.2.D.1

Enclosed please find Reportable Occurrence Report Number RO 82-35/03L-0
for Quad-Cities Nuclear Power Station.

This report is submitted to you in accordance with the requirements of
Technical Specification 6.6.B.2.a; an instrument setpoint for an
engineered safety system which was found to be in excess of the Technical
Specification limit, but which does not prevent the system from
performing its design function.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION


N. J. Kalivianakis
Station Superintendent

NJK:HGL/bb

Enclosure

cc T. J. Rausch
N. Chrissotimos
INPO Records Center