

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | 1 | L | Q | A | D | 1 | 2 | 0 | 0 | 0 | - | 0 | 0 | 0 | - | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ 5
7 8 9 14 15 25 26 30 57 58

CON'T
0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 5 | 4 | 7 | 1 | 0 | 2 | 1 | 0 | 2 | 8 | 1 | 1 | 1 | 6 | 0 | 2 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On October 21, 1982, the Automatic Steam Jet Air Ejector Off Gas Isolation, once
0 3 | per operating cycle, surveillance, QOS 5400-1, was performed. During the surveil-
0 4 | lance, the off gas isolation valves failed to close within 15 minutes as required
0 5 | by Technical Specification 4.2.D.1. The off gas retention time, at a typical flow
0 6 | rate (40 SCFM), is greater than one and one half hours for both Krypton and Xenon
0 7 | isotopes. Therefore, the Operator would have had ample time to isolate the system
0 8 | from the Control Room if it had been necessary. There was no affect on safe
0 9 | plant operation as a result of this occurrence.
7 8 9

0 9 | M | B | 11 | E | 12 | A | 13 | R | E | L | A | Y | X | 14 | 1 | 15 | Z | 16 |
7 8 9 10 11 12 13 18 19 20
17 | LER/RO | 3 | 2 | 21 | 0 | 3 | 5 | 24 | 0 | 3 | 28 | L | 30 | 0 | 32 |
7 8 21 22 23 24 26 27 28 29 30 31 32
E | 18 | G | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | N | 23 | Y | 24 | H | 25 | G | 0 | 0 | 0 | 26
7 8 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The 15 minute off gas system isolation delay timer, 1-1705-23 (Model 502374GAJCE1AD)
1 1 | was set off-scale, just past the 100% (15 minute) point, but when last tested, the
1 2 | timer isolated the system in 15 minutes. Thus, the timer setpoint apparently drifted
1 3 | sufficiently to prevent the isolation signal contacts from closing. Since the timer
1 4 | was already set at or just above its normal delay range, only a small setpoint drift
1 5 | was necessary to prevent the timer from providing its design function. The timer was
1 6 | set at 91% of scale (13 minutes & 39 seconds) and successfully tested. In addition,
1 7 | a change to procedure QOS 5400-1 has been initiated which provides a maximum timer
1 8 | setpoint of 95% of scale and verification that it is locked in that position.
7 8 9

1 5 | H | 28 | 0 | 0 | 0 | 29 | NA | 30 | B | 31 | Routine Surveillance | 32
7 8 9 10 12 13 44 45 46 80

1 6 | Z | 33 | Z | 34 | NA | 35 | IIA | 36
7 8 9 10 11 44 45 80

1 7 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39
7 8 9 11 12 13 80

1 8 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 11 12 80

1 9 | Z | 42 | NA | 43
7 8 9 10 80

2 0 | N | 44 | 8211290741 821116 PDR ADOCK 05000254 PDR | NRC USE ONLY
7 8 9 10 68 69 80-91 7-926

NAME OF PREPARER J Eagle

PHONE 309-654-2241, ext 170