



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

November 12, 1982

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-037/01T-0
ER 100450 FILE 841-23
PLA-1396

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-037/01T-0. This event was determined to be reportable per License Condition 2.G(a), in that the Reactor Recirculation Pump Discharge Valves were cycled in excess of the allowable number as stated in the SER and referenced in the Operating License.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

cc: A. Schwencer
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655