

January 31, 1991

P137

Mr. Wade Green  
Institute of Nuclear Power Operations  
Suite 1500, 1100 Circle 75 Parkway  
Atlanta, Georgia 30339-3064

Dear Mr. Green:

Enclosed for your information is our biweekly listing of generic communications being considered or under development by the NRC staff. These include Bulletins (type coded BL on the list), Information Notices (IN) and Generic Letters (GL). Temporary Instructions, that cover the special NRC inspection effort resulting from certain generic communications, are listed with the type code TI. This listing includes all proposed generic communications that had been reported to us by January 31, 1991. The dates given are the ending dates for the quarter during which we expect the listings to be issued.

Generic communications that have been issued or cancelled are retained on the list for one biweekly cycle. Those issues to be dropped from the list are identified by a notation in brackets giving the status change.

Sincerely,

Original Signed By  
Carl H. Berlinger

Carl H. Berlinger, Chief  
Generic Communications Branch  
Division of Operational Events Assessment  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

DISTRIBUTION w/enclosure:

- All NRC Division Directors
- All NRC Branch Chiefs
- WTRussell, NRR
- CERossi, NRR
- CHBerlinger, NRR
- OGCB Members
- TMendiola, NRR
- RFraleay, ACRS
- JLieberman, OE
- PDR
- Central Files
- DCB
- DOEA R/F
- OGCB R/F
- DKirkpatrick R/F
- SRichardson, DOE
- RBarber, DOE
- ENcwstrup, DOE

|            |         |
|------------|---------|
| 9102060284 | 910131  |
| PDR        | ORG     |
|            | EPSINPO |
|            | PDR     |

Document Name: LETTER TO GREEN *AB*  
 OGCB:DOEA:NRR C/OGCB:DOEA:NRR  
 DKirkpatrick CHBerlinger  
 01/31/91 *DCX* 01/31/91

*J* F03  
 RD-25  
 INPO

PROPOSED GENERIC COMMUNICATIONS  
IN PREPARATION WITHIN THE NRC

| TP ORIGINATING OFFICE | SUBJECT  | CONTACT            | PHONE             | EST DATE QTR END |
|-----------------------|--|--------------------|-------------------|------------------|
| IN NRR/DRIS<br>RVIB   | [ISSUANCE UNDER REEVALUATION]<br>ENVIRONMENTAL QUALIFICATION OF<br>LIMITORQUE MOV ACTUATOR &<br>MARATHON 1600 TERMINAL BLOCKS      | Steve<br>Alexander | (301)<br>492-0995 | 03/31/91         |
| GL NRR/DEST<br>ESGB   | NRR RECOMMENDATION ON ISI OF<br>MARK I & II STEEL CONTAINMENTS,<br>REFUELING CAVITIES & ASSOCIATED<br>DRAINAGE SYSTEMS             | Chen P. Tan        | (301)<br>492-3315 | 06/30/91         |
| GL NRR/DEST<br>SELB   | RESOLUTION OF GI B-56, DIESEL<br>RELIABILITY   | Om P.<br>Chopra    | (301)<br>492-0781 | 03/31/91         |
| TI NRR/DEST<br>EMEB   | INSPECTION OF IMPLEMENTATION OF<br>GENERIC LETTER 89-10: "SAFETY<br>RELATED MOTOR OPERATED VALVE<br>TESTING AND SURVEILLANCE"      | Tom<br>Scarborough | (301)<br>492-0794 | 06/30/91         |
| GL NRR/DEST<br>SPLB   | CONTROL ROOM HABITABILITY<br>SYSTEMS   | Charles<br>Nichols | (301)<br>492-0856 | 03/31/91         |
| IN NRR/DOEA<br>OGCB   | DIESEL GENERATOR FUEL OIL<br>OXIDATION   | Vernon<br>Hodge    | (301)<br>492-1861 | 06/30/91         |
| TI NRR/DEST<br>EMEB   | INSPECTION OF IMPLEMENTATION OF<br>GL 89-04: "GUIDANCE ON<br>DEVELOPING ACCEPTABLE INSERVICE<br>TESTING PROGRAMS"                  | Ted<br>Sullivan    | (301)<br>492-3270 | 03/31/91         |
| GL RES/DSIR<br>EIB    | POTENTIAL CONCERNS REGARDING<br>PWR REACTOR VESSEL DESIGN<br>ADEQUACY UNDER NATURAL<br>CONVECTION COOLDOWN TRANSIENT<br>CONDITIONS | Joel Page          | (301)<br>492-3941 | 06/30/91         |
| BL NRR/DRIS<br>RVIB   | NONCONFORMING MATERIALS<br>SUPPLIED BY MEREDITH<br>CORPORATION, (PRESSURE VESSEL<br>NUCLEAR) OF HILLSIDE NEW JERSEY                | R.<br>Cilimberg    | (301)<br>492-0945 | 03/31/91         |
| GL RES/DSIR<br>EIB    | RESOLUTION OF GI-29, BOLTING<br>DEGRADATION OR FAILURE IN<br>NUCLEAR POWER PLANTS  | T. Y. Chang        | (301)<br>492-3922 | 03/31/91         |
| GL RES/DSIR<br>EIB    | RESOLUTION OF GI A-30, ADEQUACY<br>OF SAFETY-RELATED DC POWER<br>SUPPLIES  | Dale<br>Thatcher   | (301)<br>492-3935 | 03/31/91         |

PROPOSED GENERIC COMMUNICATIONS  
IN PREPARATION WITHIN THE NRC

| TP ORIGINATING OFFICE | SUBJECT  | CONTACT            | PHONE          | EST DATE QTR END |
|-----------------------|--|--------------------|----------------|------------------|
| GL RES/DSIR EIB       | RESOLUTION OF GI 48, LCOS FOR CLASS 1E VITAL INSTRUMENT BUS AND GI 49 INTERLOCKS AND LCO FOR CLASS 1E TIE BREAKERS     | Dale Thatcher      | (301) 492-3935 | 03/31/91         |
| GL NRR/DOEA OTSB      | LINE ITEM TECH SPEC IMPROVEMENT: CHANGING TECHNICAL SPECIFICATION SURVEILLANCE INTERVALS FROM 18 TO 24 MONTHS          | Tom Dunning        | (301) 492-1189 | 03/31/91         |
| GL NRR/DOEA OTSB      | [ISSUANCE UNDER REEVALUATION] LINE-ITEM TECH SPEC IMPROVEMENT - DIESEL GENERATOR TESTING                               | Ed Tomlinson       | (301) 492-3150 | 03/31/91         |
| IN NRR/DRIS VIB       | INADEQUATE VENDOR ESTABLISHMENT AND IMPLEMENTATION OF 10CFR PART 21 PROCEDURES   | Joe Petrosino      | (301) 492-0979 | 03/31/91         |
| IN NRR/DRIS RVIB      | [ISSUED 02/05/91 AS IN 91-09] COUNTERFEITING OF CRANE VALVES   | Steven M. Matthews | (301) 492-3191 | 03/31/91         |
| BL NRR/DRIS RVIB      | [ISSUANCE UNDER REEVALUATION] MALFUNCTION OF BORG-WARNER BOLTED BONNET CHECK VALVES CAUSED BY FAILURE OF THE SWING ARM | Robert Pettis Jr.  | (301) 492-3214 | 03/31/91         |
| IN NRR/DOEA OEAB      | INADEQUATE SEPARATION OF NON-CLASS-1E UV/UF CIRCUITRY FROM REACTOR PROTECTION CIRCUITRY AT TROJAN                      | Walton Jensen      | (301) 492-1157 | 03/31/91         |
| BL NRR/DET EMCB       | STEAM GENERATOR TUBE EXPANSION TRANSITION CRACKING   | Emmett Murphy      | (301) 492-0710 | 06/30/91         |
| IN NRR/DST SICB       | INSTALLATION OF DIGITAL MICROPROCESSORS INTO SAFETY SYSTEMS VIA 10 CFR 50.59   | James Stewart      | (301) 492-0824 | 03/31/91         |
| IN NRR/DST SICB       | MISAPPLICATION OF TEMPERATURE CONTROLLER LEADS TO TECHNICAL SPECIFICATION ACTION AT NUCLEAR POWER PLANT                | Jerry Mauck        | (301) 492-3248 | 03/31/91         |
| IN AEOD               | OPERATIONAL EXPERIENCE ON BUS TRANSFER   | Subinoy Mazumdar   | (301) 492-4308 | 03/31/91         |

PROPOSED GENERIC COMMUNICATIONS  
IN PREPARATION WITHIN THE NRC

| TP ORIGINNG<br>OFFICE | SUBJECT  | CONTACT            | PHONE             | EST DATE<br>QTR END |
|-----------------------|--|--------------------|-------------------|---------------------|
| GL NRR/DEST<br>SELB   | GROUNDS IN DIRECT CURRENT<br>DISTRIBUTION SYSTEMS  | F. Burrows         | (301)<br>492-3260 | 03/31/91            |
| IN NRR\DRIS<br>RSGB   | BACKGROUND INVESTIGATION FOR<br>GRANTING UNSCORTED ACCESS  | Nancy Ervin        | (301)<br>492-0946 | 03/31/91            |
| GL NRR\DRIS<br>RSGB   | REPORTING OF SAFEGUARDS EVENTS   | Nancy Ervin        | (301)<br>492-0946 | 03/31/91            |
| IN REGION II          | SEIMENS-ITE MOLDED CASE CIRCUIT<br>BREAKER FAILURES  | Steve<br>Alexander | (301)<br>492-0995 | 03/31/91            |
| IN NRR/DRSP<br>PD5    | [ISSUANCE UNDER REEVALUATION]<br>INSERVICE INSPECTION OF PAINTED<br>REACTOR COOLANT PUMP FLYWHEELS                       | Roby B.<br>Bevan   | (301)<br>492-1361 | 03/31/91            |
| IN NRR/DET<br>EMCB    | STRESS CORROSION CRACKING OF<br>STEAM GENERATOR MECHANICAL<br>PLUGS SUPPLIED BY WESTINGHOUSE                             | Emmett<br>Murphy   | (301)<br>492-0710 | 03/31/91            |
| IN AEOD               | SUPPLEMENT 1 TO IN 89-32:<br>TESTING POWER OPERATED RELIEF<br>VALVES WITH ALTERNATE PNEUMATIC<br>SUPPLY                  | Vern Hodge         | (301)<br>492-1861 | 03/31/91            |
| IN AEOD               | SUPPLEMENT 1 TO IN 89-90:<br>ADDITIONAL FACTORS AFFECTING<br>THE SET POINT OF SAFETY RELIEF<br>VALVES                    | L. Mark<br>Padovan | (301)<br>492-4445 | 03/31/91            |
| IN NRR/DOEA<br>OGCB   | CANCELLATION OF MOV USERS GROUP<br>SPONSORED MOV DIAGNOSTIC SYSTEM<br>VALIDATION TESTING                                 | R. J.<br>Kiessel   | (301)<br>492-0840 | 03/31/91            |
| IN DREP/PRAB          | POTENTIAL FOR INTERSYSTEM LOSS<br>OF COOLANT ACCIDENT OUTSIDE OF<br>THE CONTAINMENT                                      | Sammy Diab         | (301)<br>492-1078 | 03/31/91            |
| IN REGION I           | EMERGENCY DIESEL GENERATOR<br>TESTING DEFICIENCIES   | C. H.<br>Woodward  | (215)<br>337-5261 | 03/31/91            |
| IN NRR/DRIS<br>VIB    | [ISSUED 02/04/91 AS IN 91-07]<br>MAINTENANCE DEFICIENCY<br>ASSOCIATED WITH GE CUSTOM 8000<br>HORIZONTAL INDUCTION MOTORS | Kamal Naidu        | (301)<br>492-0980 | 03/31/91            |
| IN AEOD/ROAB          | [ISSUED 01/28/91 AS IN 91-04]<br>REACTOR SCRAM AT LOW POWER<br>FOLLOWING ERRONEOUS CONTROL ROD<br>WITHDRAWAL             | E. Trager          | (301)<br>492-4496 | 03/31/91            |

PROPOSED GENERIC COMMUNICATIONS  
IN PREPARATION WITHIN THE NRC

| TP ORIGINATING OFFICE | SUBJECT  | CONTACT            | PHONE             | EST DATE QTR END |
|-----------------------|--|--------------------|-------------------|------------------|
| IN NRR/DRIS<br>RVIB   | SUPPLEMENT 1 TO IN 90-43:<br>MECHANICAL INTERFERENCE WITH<br>THERMAL TRIP FUNCTION IN GE<br>MOULDED-CASE CIRCUIT BREAKERS          | Steve<br>Alexander | (301)<br>492-0995 | 03/31/91         |
| IN NRR/DRIS<br>RVIB   | PROBLEMS WITH GE AK2 CIRCUIT<br>BREAKERS EXPERIENCED AT ST<br>LUCIE AND MAIN YANKEE  | Steve<br>Alexander | (301)<br>492-0995 | 03/31/91         |
| GL NMSS               | REPORTING MISHAPS INVOLVING LOW<br>LEVEL WASTE FORMS PREPARED FOR<br>DISPOSAL  | Michael<br>Tokar   | (301)<br>492-0590 | 03/31/91         |
| GL NRR/DST<br>SRXB    | SUPPLEMENT 1 TO GENERIC LETTER<br>88-17: LOSS OF DECAY HEAT<br>REMOVAL   | Warren Lyon        | (301)<br>492-0892 | 03/31/91         |
| IN REGION II          | [ISSUED 01/30/91 AS IN 91-05]<br>INTERGRANULAR STRESS CORROSION<br>CRACKING IN PWR SAFETY<br>INJECTION ACCUMULATOR NOZZLES         | James L.<br>Coley  | (404)<br>331-5584 | 03/31/91         |
| IN NMSS               | [NEW] RECENT SAFETY-RELATED<br>INCIDENTS AT LARGE IRRADIATORS  | Susan L.<br>Greene | (301)<br>492-0686 | 03/31/91         |
| IN NRR/DRP<br>PD1-4   | [NEW] OVERSPEED TRIP OF TERRY<br>TURBINES DUE TO INITIAL SHAFT<br>ROTATION   | D. H. Jaffe        | (301)<br>492-1494 | 03/31/91         |
| IN NRR/DLPG<br>LOLB   | [NEW] [ISSUED 02/05/91 AS IN<br>91-08] MEDICAL EXAMINATIONS FOR<br>LICENSED OPERATORS  | David Lange        | (301)<br>492-3171 | 03/31/91         |
| IN NRR/DRIS<br>VIB    | [NEW] IN 90-43, SUPP 1:<br>MECHANICAL INTERFERENCE WITH<br>THERMAL TRIP FUNCTION IN GE<br>MOLDED-CASE CIRCUIT BREAKERS             | Steve<br>Alexander | (301)<br>492-0995 | 03/31/91         |
| IN REGION II          | [NEW] HYDROGEN WATER CHEMISTRY<br>SUSPECTED AS CAUSE OF HIGH DOSE<br>RATES MEASURED IN DRYWELL AND<br>ACTOR BUILDING AT HATCH UNIT | Deborah<br>Seymour | (404)<br>331-2605 | 03/31/91         |