

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | P | A | B | V | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
8 9 14 15 25 26 37 CAT 58

CON'T
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 4 | 7 | 1 | 0 | 2 | 3 | 8 | 2 | 8 | 1 | 1 | 1 | 0 | 8 | 2 | 9
8 80 81 88 89 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0445 hours on 10/23/82, an operator noticed rod E-11 (shutdown bank B)
0 3 | indicated misalignment. Primary voltage readings also indicated misalign-
0 4 | ment and the rod was declared inoperable. Power operation continued as
0 5 | per the applicable action statement of Tech Spec 3.1.3.1. A subsequent
0 6 | investigation by the test crew determined that no rod misalignment had
0 7 | occurred. The faulty indication was due to instrument power supply
0 8 | voltage drift. There were no safety implications.

0 9 | SYSTEM CODE: R B (11) CAUSE CODE: E (12) CAUSE SUBCODE: E (13) COMPONENT CODE: I N S T R U (14) COMP. SUBCODE: P (15) VALVE SUBCODE: Z (16)
17 | LER/RO REPORT NUMBER: 8 2 (21) EVENT YEAR: 8 2 (22) SEQUENTIAL REPORT NO.: 0 4 6 (24) OCCURRENCE CODE: 0 3 (28) REPORT TYPE: L (30) REVISION NO.: 0 (32)
ACTION TAKEN: E (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS: 0 0 0 0 (22) ATTACHMENT SUBMITTED: Y (23) NPRD-4 FORM SUB.: N (24) PRIME COMP. SUPPLIER: N (25) COMPONENT MANUFACTURER: W 1 2 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The primary voltage power supply to rod E-11 position indication had drifted
1 1 | low resulting in low analog position and primary voltage position indic-
1 2 | lation. The voltage supply was adjusted to the high voltage limit and rod
1 3 | E-11 position indication returned within its allowed tolerance band.
1 4 | Following the adjustment the rod was declared operable at 0608 hours.

1 5 | FACILITY STATUS: E (28) % POWER: 0 0 5 (29) OTHER STATUS: N/A (30) METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION: Operator Observation (32)

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE: Z (33) Z (34) AMOUNT OF ACTIVITY: N/A (35) LOCATION OF RELEASE: N/A (36)

1 7 | PERSONNEL EXPOSURES NUMBER: 0 0 0 (37) TYPE: Z (38) DESCRIPTION: N/A (39)

1 8 | PERSONNEL INJURIES NUMBER: 0 0 0 (40) DESCRIPTION: N/A (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z (42) DESCRIPTION: N/A (43) 8211290762 821105 PDR ADOCK 05000334 PDR

2 0 | PUBLICITY ISSUED: N (44) DESCRIPTION: N/A (45) NRC USE ONLY

Attachment To LER 82-046/03L
Beaver Valley Power Station
Duquesne Light Company
Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.