

DIST:
 Document Control (STN 50-456/457)
 NRC PDR
 L PDR
 PRC System
 NSIC
 LB#1 Rdg.
 JYoungblood
 MRushbrook
 LOlshan
 DEisenhut/RPurple
 MJambor (SL #208)
 PHungerbuhler
 ELJordan, IE
 JMTaylor, IE
 ACRS (16)

NOV 19 1982

Docket Nos.: STN 50-456
 and STN 50-457

MEMORANDUM FOR: A. Bert Davis, Deputy Regional Administrator, Region III
 FROM: Darrell G. Eisenhut, Director, Division of Licensing, NRR
 SUBJECT: COMMONWEALTH EDISON COMPANY - BRAIDWOOD STATION, UNITS 1
 AND 2, POSSIBLE MATERIAL FALSE STATEMENT

Your memorandum of October 1, 1982 asked NRR's assistance in determining the acceptability of the applicant's installation of the reactor coolant pumps and steam generators. As you point out, Paragraph V of Appendix B to 10 CFR 50 requires that activities affecting quality be prescribed by documented instructions, procedures, or drawings. Furthermore, Section 5 of Standard Review Plan 17.1, "Quality Assurance During the Design and Construction Phases," also requires documented instructions, procedures and drawings for activities affecting quality. Therefore, had we known that the licensee was going to install this equipment without procedures or instructions, our decision on the adequacy of this installation and the FSAR would have been influenced. We would have required that the installation be done with documented instructions, procedures and drawings.

Original signed by
 Darrell G. Eisenhut

Darrell G. Eisenhut, Director
 Division of Licensing
 Office of Nuclear Reactor Regulation

8211300445 821119
 PDR ADOCK 05000456
 A PDR

*SEE PREVIOUS ORG FOR CONCURRENCES

retyped 11/9-1g OFFICE SURNAME DATE	DL:LB#1 LOlshan/lq 10/18/82	DL:LB#1* BJYoungblood 10/18/82	DL:AD/L TNovak 10/18/82	DL:DIR DEisenhut 11/5/82			
---	-----------------------------------	--------------------------------------	-------------------------------	--------------------------------	--	--	--



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

*scope 11/3
lee*

Docket Nos.: STN 50-456
and STN 50-457

MEMORANDUM FOR: A. Bert Davis, Deputy Regional Administrator
Region III

FROM: Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

SUBJECT: COMMONWEALTH EDISON COMPANY - BRAIDWOOD STATION,
UNITS 1 AND 2, POSSIBLE MATERIAL FALSE STATEMENT

Your memorandum of October 1, 1982 asked NRR's assistance in determining the acceptability of the applicant's installation of the reactor coolant pumps and steam generators. As you point out, Paragraph V of Appendix B to 10 CFR 50 requires that activities affecting quality be prescribed by documented instructions, procedures, or drawings. Furthermore, Section 5 of Standard Review Plan 17.1, "Quality Assurance During the Design and Construction Phases," also requires documented instructions, procedures and drawings for activities affecting quality. Therefore, had we known that the licensee was going to install this equipment without procedures or instructions, our decision on the adequacy of this installation and the FSAR would have been influenced. ~~While requirements in addition to those discussed above should not be necessary, to state that we would have been more explicit with regard to a specific procedure or a lack thereof would be conjectural at this time.~~ *we would have required that the*

We trust this response is adequate and satisfies your schedular requirements. You informed us by telephone that a response by October 20, 1982 would be sufficient.

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

installation to be done with documented instructions, procedures and drawings.

DISTRIBUTION

Document Control - (STN50-456/457)
 NRC PDR
 L PDR
 PRC System
 NSIC
 LB#1 Reading
 BYoungblood
 MRushbrook
 L01shan
 DEisenhut/RPurple

MJambor(DL#208)
 PHungerbuhler
 ELJordan,I&E
 JMTaylor,I&E
 ACRS(16)

Docket Nos. STN 50-456
 and STN 50-457

MEMORANDUM FOR: A. Bert Davis, Deputy Regional Administrator
 Region III, I&E

FROM: Darrell G. Eisenhut, Director
 Division of Licensing, ONRR

SUBJECT: COMMONWEALTH EDISON COMPANY - BRAIDWOOD STATION,
 UNITS 1 & 2, POSSIBLE MATERIAL FALSE STATEMENT

Your memorandum of October 1, 1982, asked NRR's assistance in determining the acceptability of the applicant's installation of the reactor coolant pumps and steam generators. As you point out, Paragraph V of Appendix B to 10 CFR 50 requires that activities affecting quality be prescribed by documented instructions, procedures, or drawings. Furthermore, Section 5 of Standard Review Plan 17.1, "Quality Assurance During the Design and Construction Phases," also requires documented instructions, procedures, and drawings for activities affecting quality. Therefore, had we known that the licensee was going to install this equipment without procedures or instructions, our decision on the adequacy of this installation and the FSAR would have been influenced. While requirements in addition to those discussed above should not be necessary, to state that we could have been more explicit with regard to a specific procedure or a lack thereof would be conjectural at this time.

Darrell G. Eisenhut, Director
 Division of Licensing
 Office of Nuclear Reactor Regulation

*SEE PREVIOUS CONCURRENCE FOR INITIALS

retype 11/3 1gb	OFFICE ▶	DL:LB#1 *	DL:LB#1 *	DL:L *	DL		
SURNAME ▶		L01shan:cw	JYoungblood	TNovak	DEisenhut		
DATE ▶		10/18/82	10/18/82	10/18/82	11/ /82		

Docket Nos.: STN 50-456
and STN 50-457

MEMORANDUM FOR: A. Bert Davis, Deputy Regional Administrator
Region III

FROM: Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

SUBJECT: COMMONWEALTH EDISON COMPANY - BRAIDWOOD STATION,
UNITS 1 AND 2, POSSIBLE MATERIAL FALSE STATEMENT

Your memorandum of October 1, 1982 asked NRR's assistance in determining the acceptability of the applicant's installation of the reactor coolant pumps and steam generators. As you point out, Paragraph V of Appendix B to 10 CFR 50 requires that activities affecting quality be prescribed by documented instructions, procedures, or drawings. Furthermore, Section 5 of Standard Review Plan 17.1, "Quality Assurance During the Design and Construction Phases," also requires documented instructions, procedures and drawings for activities affecting quality. Therefore, had we known that the licensee was going to install this equipment without procedures or instructions, our decision on the adequacy of this installation and the FSAR would have been influenced. While requirements in addition to those discussed above should not be necessary, to state that we would have been more explicit with regard to a specific procedure or a lack thereof would be conjectural at this time.

We trust this response is adequate and satisfies your schedular requirements. You informed us by telephone that a response by October 20, 1982 would be sufficient.

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

DISTRIBUTION:

Document Control (STN 50-456/50-457)
NRC PDR LB#1 Rdg DEisenhut/RPurple ELJordan, DEQA:IE
L PDR BJYoungblood MJambor (DL #208) JMTaylor, DRP:IE
TERA MRushbrook TNovak/LBerry
NSIC LOlshan PHungerbuhler

*SEE PREVIOUS PAGE FOR CONCURRENCES

OFFICE	DL:LB#1	DL:LB#1	DL:LB#1	DL:DIR		
SURNAME	LOlshan:cw*	BJYoungblood*	TNovak*	DEisenhut		
DATE	10/18/82	10/18/82	10/18/82	11/ /82		

Docket Nos.: STN 50-456
STN 50-457

MEMORANDUM FOR: A. Bert Davis, Deputy Regional Administrator
Region III

FROM: Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

SUBJECT: COMMONWEALTH EDISON COMPANY - BRAIDWOOD STATION,
UNITS 1 AND 2 - POSSIBLE MATERIAL FALSE STATEMENT

Your memorandum of October 1, 1982 asked NRR's assistance in determining the acceptability of the applicant's installation of the reactor coolant pumps and steam generators. As you point out, Paragraph V of Appendix B to 10 CFR 50 requires that activities affecting quality be prescribed by documented instructions, procedures, or drawings. Furthermore, Section 5 of Standard Review Plan 17.1, "Quality Assurance During the Design and Construction Phases," also requires documented instructions, procedures and drawings for activities affecting quality. Therefore, had we known that the licensee was going to install this equipment without procedures or instructions, our decision on the adequacy of this installation and the FSAR would have been influenced.

We trust this response is adequate and satisfies your scheduler requirements. You informed us by telephone that a response by October 20, 1982 would be sufficient.

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

DISTRIBUTION:

Document Control (50-454/50-455/50-456/50-457)
NRC PDR DEisenhut/R. Purple
L PDR MJambor (DL # 208)
TERA TNovak/LBerry
NSIC PHungerbuhler
LB#1 Rdg ELJordan, DEQA:IE
JYoungblood JMTaylor, DRP:IE
MRushbrook
LOIshan

OFFICE	DL:LB#1	DL:LB#1	DL:AD/L	DL:DIR		
SURNAME	LOIshan:cw	JYoungblood	TNovak	DEisenhut		
DATE	10/19/82	10/18/82	10/18/82	/ /82		