

February 1, 1991

Docket Nos. 50-445
and 50-446

Mr. William J. Cahill, Jr.
Executive Vice President, Nuclear
TU Electric Company
400 North Olive Street, L.B. 81
Dallas, Texas 75201

DISTRIBUTION

Docket File	PDIV-2 Reading
NRC PDR	PDIV-2 Plant File
Local PDR	EJordan
BBoger	ACRS (10)
MVirgilio	DChamberlain
CGrimms	EPeyton
OGC	DLaBarge

Dear Mr. Cahill:

SUBJECT: RESPONSE TO GENERIC LETTER 90-03 FOR COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 (TAC NOS. 76223 AND 76224)

On March 20, 1990, the Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 90-03, "Relaxation of Staff Position in Generic Letter 83-28, Item 2.2, Part 2, Vendor Interface for Safety-Related Components." The GL requested that all licensees and applicants review their present vendor interface programs and modify them as necessary using the guidance supplied in GL 90-03.

By letters dated September 27, 1990, and December 10, 1990, TU Electric responded to GL 90-03 and indicated that the vendor interface programs identified in the GL had been reviewed. As stated in NUREG-0797, Supplement No. 23, "Safety Evaluation Report Related to the Operation of Comanche Peak Steam Electric Station, Units 1 and 2," the licensee committed to implement the Vendor Equipment Technical Information Program (VETIP), and has already established programs with Westinghouse, the Nuclear Steam Supply System (NSSS) vendor, and with Transamerica Delaval, the diesel generator vendor. The licensee's program also calls for establishing vendor interface agreements with suppliers of other safety-related equipment as part of the procurement process for spare and replacement parts.

The licensee's program meets the guidance outlined in GL 90-03, and is acceptable. This completes NRC staff review of the licensee's response to GL 90-03.

Sincerely,

(ORIGINAL SIGNED BY)

James W. Clifford, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

OFC	: PDIV-2/LA	: PDIV-2/PM	: PDIV-2/D	:
NAME	: EPeyton	: JClifford	: CGrimms	:
DATE	: 1/31/91	: 1/31/91	: 2/1/91	:

OFFICIAL RECORDS COPY
Document Name: RESPONSE TO GL 9003

9102070066 910201
PDR ADOCK 05000445
P PDR

DF01
1/0

Mr. William J. Cahill, Jr.

- 2 -

February 1, 1991

cc:

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 1029
Granbury, Texas 76048

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Ms. Billie Pirner Garde, Esq.
Robinson, Robinson, et al
103 East College Avenue
Appleton, Wisconsin 54911

Mrs. Juanita Ellis, President
Citizens Association for Sound Energy
1426 South Polk
Dallas, Texas 75224

E. F. Ottney
P. O. Box 1777
Glen Rose, Texas 76043

Mr. Roger D. Walker
Manager, Nuclear Licensing
Texas Utilities Electric Company
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Texas Utilities Electric Company
c/o Bethesda Licensing
3 Metro Center, Suite 610
Bethesda, Maryland 20814

William A. Burchette, Esq.
Counsel for Tex-La Electric
Cooperative of Texas
Jordan, Schulte, & Burchette
1025 Thomas Jefferson Street, N.W.
Washington, D.C. 20007

GDS Associates, Inc.
Suite 720
1850 Parkway Place
Marietta, Georgia 30067-8237

Jack R. Newman, Esq.
Newman & Holtzinger
1615 L Street, N.W.
Suite 1000
Washington, D.C. 20036

Chief, Texas Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, Texas 78756

Honorable George Crump
County Judge
Glen Rose, Texas 76043