

February 5, 1991

Docket No. 50-213

Distribution:

Mr. Edward J. Mroczka
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Docket File
NRC & Local PDRs
PD I-4 Plant File
SVarga
EGGreeriman
SNorris
AWang
OGC
EJordan
ACRS (10)
CWHehl

Dear Mr. Mroczka:

SUBJECT: HADDAM NECK PLANT - STATION BLACKOUT RULE, REQUEST FOR
ADDITIONAL INFORMATION (TAC NO. 68551)

The NRC has reviewed Connecticut Yankee Atomic Power Company's (CYAPCO/licensee) responses to our request for additional information dated March 30, 1990. Based on our review of your responses, the staff has determined that additional information is necessary to complete our review. Enclosed are additional questions regarding your submittals. The NRC proposes to discuss these questions with your staff in a conference call within 30 days with a written response to follow at a date to be determined.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than 10 respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

15/

Alan Wang, Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

9102070152 910205
PDR ADOCK 05000213
P PDR

OFC	:PDI-4:LA	:PDI-4:PM	:PDI-4:D	:	:
NAME	:SNorris	:AWang <i>AW</i>	:JFSto <i>JF</i>	:	:
DATE	:1/29/91	:1/9/91	:2/4/91	:	:

DF01
11

OFFICIAL RECORD COPY
Document Name: TAC NO. 68551

68551
7

Mr. Edward J. Mroczka
Connecticut Yankee Atomic Power Company

Haddam Neck Plant

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Manager
Generation Facilities Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President
Nuclear Operations
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

D. O. Nordquist
Director of Quality Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06106

Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary
Energy Division
Office of Policy and Management
80 Washington Street
Hartford, Connecticut 06106

Board of Selectmen
Town Hall
Haddam, Connecticut 06103

J. P. Stetz, Nuclear Station Director
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
RFD 1, Post Office Box 127E
East Hampton, Connecticut 06424

J. T. Shedlosky, Resident Inspector
Haddam Neck Plant
c/o U. S. Nuclear Regulatory Commission
Post Office Box 116
East Haddam Post Office
East Haddam, Connecticut 06423

G. H. Bouchard, Nuclear Unit Director
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
RFD 1, Post Office Box 127E
East Hampton, Connecticut 06424

ENCLOSURE

QUESTIONS ON HADDAM NECK SBO SUBMITTAL*
WITH EMPHASIS ON THE FOLLOWING ITEMS

1. Justify the use of ESW "1" instead of ESW "5" from NUMARC 87-00 Table 3-2. Assuming the ESW "1" characterization is based on site weather data, the justification should include a description of the data collected, the period of data collection (years), any significant lapses of data gathering, and the results of the evaluation of the data.
2. Describe the steps necessary to utilize water from the primary water storage tank for decay heat removal. Must the water be pumped to the demineralized water storage tank using the primary water transfer pump or other pump? If so, identify the power source for the pump.
3. Verify that the utilization of the fire pump as a condensate source is feasible considering the pump's NPSH under all conditions, and the degree of fouling possible with debris in the river water.
4. Discuss the amount of the intended RCS cooldown and provide the assessment that calculates the amount of condensate needed for the cooldown.
5. Describe the expected method of steam removal from the secondary side. If the atmospheric steam dump valves are to be utilized, are they power (air) operated, or manually manipulated? If the valves are manually operated, has the habitability and communications facilities of the area of the valves been evaluated and determined to be adequate?
6. Discuss the effect of a loss of ventilation for four hours in the room(s) that contain the battery and inverters.
7. Provide a list of containment isolation valves of concern, the specific actions required for each valve to ensure containment isolation during an SBO, and the procedures which contain the requirements to perform these actions. The valves of concern are those that cannot be excluded using the criteria given RG 1.155 or NUMARC 87-00.

December 27, 1990