

February 4, 1991

Docket No. 50-344

DISTRIBUTION

Mr. James E. Cross  
Vice President, Nuclear  
Portland General Electric Company  
121 S.W. Salmon Street  
Portland, Oregon 97204

Docket Files	NRC & LPDRs
PD5 Reading	PD5 Plant
BBoger	MVirgilio
DFoster	RBevan
DHagan	OGC
GHill (4)	Wanda Jones
JCalvo	ACRS (10)
GPA/PA	OC/LFMB
JBradfute	RZimmerman, RV (4)

Dear Mr. Cross:

SUBJECT: ISSUANCE OF AMENDMENT NO.168 TO FACILITY OPERATING LICENSE  
NO. NPF-1 FOR THE TROJAN NUCLEAR PLANT (TAC NO. 74836)

The Commission has issued the enclosed Amendment No. 168 to Facility Operating License No. NPF-1 for Trojan Nuclear Plant. The amendment consists of changes to the Technical Specifications (TS) in response to your application (LCA-177) dated June 12, 1989.

The amendment revises Trojan Technical Specifications (TTS) Table 4.7-1. The values of the valve orifice size listed in Table 4.7-1, lines a and b, are changed from Q=11.05 square inches to Q=12.174 square inches, the actual area.

A copy of the related Safety Evaluation is also enclosed. A notice of issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

Original signed by:

Roby B. Bevan, Project Manager  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 168 to License No. NPF-1
2. Safety Evaluation

cc w/enclosures:  
See next page

\*See previous concurrence

DF01  
11

OFC	: LA/PD5/DRPW	: PE/PD5/DRPW	: PM/PD5/DRPW	: OGC	: D/PD5/DRPW	::
NAME	: DFoster	: JBradfute:sg	: RBevanRBB	: CBarth*	: Dyer JUK	::
DATE	: 2/4/91	: 2/4/91	: 2/4/91	: 2/1/91	: 2/4/91	:

OFFICIAL RECORD COPY  
Document Name: TROJAN AMD 74836

Mr. James E. Cross Trojan Nuclear Plant  
Portland General Electric Company

cc:  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Trojan Nuclear Plant  
Post Office Box 0  
Rainier, Oregon 97048

Mr. Michael J. Sykes, Chairman  
Board of County Commissioners  
Columbia County  
St. Helens, Oregon 97501

Mr. David Stewart-Smith  
Oregon Department of Energy  
Salem, Oregon 97310

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596