



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PORTLAND GENERAL ELECTRIC COMPANY
THE CITY OF EUGENE, OREGON
PACIFIC POWER AND LIGHT COMPANY
DOCKET NO. 50-344
TROJAN NUCLEAR PLANT
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 168
License No. NPF-1

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Portland General Electric Company, et al. (licensees) dated June 12, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-1 is hereby amended to read as follows:

- (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 168, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



James E. Dyer, Director
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 4, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 168

TO FACILITY OPERATING LICENSE NO. NPF-1

DOCKET NO. 50-344

Revise Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change.

REMOVE

3/4 7-4

INSERT

3/4 7-4

TABLE 6.7-1
STEAM LINE SAFETY VALVES PER LOOP

	<u>VALVE NUMBER</u>				<u>LIFT SETTING</u>	<u>ALLOWABLE VALUE (+2%)</u>	<u>ORIFICE SIZE</u>
	<u>A</u>	<u>B</u>	<u>C</u>	<u>D</u>			
a.	PSV-2211,	PSV-2231,	PSV-2251,	PSV-2271	1170 psig	1147-1193 psig	Q = 12.174 sq. inches
b.	PSV-2212,	PSV-2232,	PSV-2252,	PSV-2272	1200 psig	1176-1224 psig	Q = 12.174 sq. inches
c.	PSV-2213,	PSV-2233,	PSV-2253,	PSV-2273	1210 psig	1186-1234 psig	R = 16.0 sq. inches
d.	PSV-2214,	PSV-2234,	PSV-2254,	PSV-2274	1220 psig	1196-1244 psig	R = 16.0 sq. inches
e.	PSV-2215,	PSV-2235,	PSV-2255,	PSV-2275	1230 psig	1206-1254 psig	R = 16.0 sq. inches