



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 22, 1982

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Inoperable Containment  
Ventilation System Effluent  
Flowrate Monitor  
Reference: LER 82-081/99 X-1  
AECM-82/564

NOV 28 1982  
RECEIVED  
ATLANTA, GEORGIA

During the performance of the Containment Cooling Pre-Operational Test on September 16, 1982, discrepancies were found in the indications given by the Containment Ventilation System Effluent Flowrate Monitor. The monitor was subsequently declared inoperable. This report is being submitted pursuant to Technical Specification 3.3.7.12 and as a followup to LER 82-081/03 L-0, dated October 18, 1982. Attached is LER 82-081/99 X-1 with supplementary information.

Yours truly,

*J.P. McGaughey, Jr.*  
FOR J.P. McGaughey, Jr.

JPM:sap  
Attachment

- cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

IE22

8212020033 821122  
PDR ADOCK 05000416  
S PDR