



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-369

McGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 140
License No. NPF-9

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-9 filed by the Duke Power Company (licensee) dated November 4, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9402180075 940210
PDR ADDCK 05000369
P PDR

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 140, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Loren R. Plisco, Acting Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: February 10, 1994



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-370

McGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 122
License No. NPF-17

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-17 filed by the Duke Power Company (licensee) dated November 4, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.122 , are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Loren R. Plisco, Acting Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: February 10, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 140

FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

AND

TO LICENSE AMENDMENT NO. 122

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change.

Remove Page

3/4 7-13

Insert Page

3/4 7-13

PLANT SYSTEMS

3/4.7.6 CONTROL AREA VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.6 Two independent Control Area Ventilation Systems shall be OPERABLE.

APPLICABILITY: ALL MODES

ACTION: (Units 1 and 2)

MODES 1, 2, 3 and 4:

- a. With one Control Area Ventilation System inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, restore the inoperable system to OPERABLE status within 7* days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With the heaters tested in 4.7.6.b and 4.7.6.e.4 inoperable, restore the inoperable heaters to OPERABLE status within 7 days, or file a Special Report in accordance with Specification 6.9.2 within 30 days, specifying the reason for inoperability and the planned actions to return the heaters to OPERABLE status.

MODES 5 and 6:

- a. With one Control Area Ventilation System inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, restore the inoperable system to OPERABLE status within 7 days or initiate and maintain operation of the remaining OPERABLE Control Area Ventilation System in the recirculation mode; and
- b. With both Control Area Ventilation Systems inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, or with the OPERABLE Control Area Ventilation System, required to be in the recirculation mode by ACTION a., not capable of being powered by an OPERABLE emergency power source, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.
- c. The provisions of Specification 3.0.4 are not applicable.
- d. With the heaters tested in 4.7.6.b and 4.7.6.e.4 inoperable, restore the inoperable heaters to OPERABLE status within 7 days, or file a Special Report in accordance with Specification 6.9.2 within 30 days, specifying the reason for inoperability and the planned actions to return the heaters to OPERABLE status.

* A one time allowed outage time extension to 14 days is granted for each train, one at a time, to allow for maintenance on the chiller package of each train. No transport of toxic gas containers on site is to occur during this time.