



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 24, 1982

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Failure to Satisfy  
Requirements of  
T.S.3.8.1.1.f  
LER 82-103/01 X-1  
AECM-82/570

During shutdown on October 22, 1982, while reviewing documentation declaring HPCS Division III Diesel Generator inoperative, it was discovered the requirements of Technical Specification 3.8.1.1.f were not satisfied. This report is being submitted as a follow-up to LER 82-103/01 T-0, dated November 5, 1982. Attached is LER 82-103/01 X-1 with supplementary information.

Yours truly,

*[Handwritten signature]*  
FOR J.P. Mcgaughy JR.

JPM:sap  
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8212020058 821124  
PDR ADOCK 05000416  
S PDR

NOV 26 2:05  
USNRC REGION II  
ATLANTA, GEORGIA

IE22